



#126-1617

HEALTH, SAFETY & RISK MANAGEMENT  
 Michael O'Rourke  
 Program Administrator

175 Route 32 North • New Paltz, NY 12561  
 Telephone: 845-255-1400 • Facsimile: 845-255-3826  
 Email: morourke@ulsterboces.org



## Environmental Hygiene Report

Attn: Maria C. Rice  
 Superintendent of Schools  
 New Paltz Central School District  
 196 Main Street, New Paltz, NY 12561  
 Prepared by: Michael O'Rourke, RPIH – No. 0500399

<b>Location(s)</b>	High School
<b>Project No.</b>	126-1617
<b>Site Visit(s)</b>	October 29, 2016
<b>Report Date</b>	December 21, 2016
<b>Investigator(s)</b>	Michael O'Rourke Brian Colandrea

**Ulster County BOCES Health, Safety & Risk Management does not assert that all potential health or safety hazards at this site were evaluated during this survey. This survey is strictly limited to that which is identified in the Project Scope of the report.**

**BRINGING ULSTER COUNTY SCHOOLS TOGETHER TO ENHANCE TEACHING & LEARNING**

Ellenville Central Schools • Highland Central Schools • Kingston City Schools • New Paltz Central Schools •  
 Onteora Central Schools • Rondout Valley Central Schools • Saugerties Central Schools • Walkkill Central Schools

# TABLE OF CONTENTS

Executive Summary	1
Project Scope	1
Materials & Methods	1
Results Summary	2
Discussion	3
Comments & Recommendations	4
References	4
Appendix A	Laboratory Report(s)
Appendix B	Caution Signage

**Author's Note:** Parenthetical numerals at the end of a sentence reference the work with the corresponding notation in the **References** section. *Please read this report in its entirety, including any attached appendices, to fully understand this investigation.*

## **Executive Summary**

Per the requirements of Subpart 67-4: Lead Testing in School Drinking Water, we sampled water outlets in the New Paltz Central School District's High School on October 22, 2016. The regulation defines a water outlet as one that is currently or may potentially be used for cooking or drinking. We identified a total of 164 such water outlets in the high school. There were 10 other locations sampled at the high school using the DOH's protocol prior to the enactment of the law. Of these 174 locations, 53 exceeded the 15 parts per billion (ppb) action level. Per 67-4.4, these outlets must be taken out of service until remediation and re-testing indicate that the lead levels are at or below the action level. If a location, like a toilet room sink, is needed for hygiene purposes signage can be posted (see **Appendix B**) instructing building occupants this water is not intended for drinking purposes. Please note that this is a short-term solution only. We are still awaiting the official guidance from the state, but it is anticipated that lab fixtures that exceeded the action level will not have to be replaced so long as certain conditions are met.

## **Project Scope**

Identify appropriate potable water sampling locations and collect samples from these locations at New Paltz High School for analysis for lead content. Review the data and information and prepare a written report for the New Paltz Central School District.

## **Materials & Methods**

All samples were collected from the type of plumbing fixtures where potable water is commonly drawn using the NYSDOH protocol. First-draw samples for lead were collected after

the water had sat in the pipes for at least eight hours. All samples were collected in 250 ml containers provided by EnviroTest Laboratories in Newburgh, NY. The samples were returned to the laboratory two days after sampling for analysis per the lab's directives. EnviroTest is NYS ELAP-approved (#10142) for potable and non-potable water analysis.

## **Results Summary**

All sample results and other data were reported to the administration of the local educational agency (LEA) via phone, fax, or e-mail as they became available to our department. **See Appendix A for full laboratory reports.**

### **Water Samples that Exceeded Action Level**

**October 29, 2016**

#### **New Paltz High School**

<b>Sample</b>	<b>Location</b>	<b>Result (ppb)</b>
03	Men's TR Sink Faucet Outside Main Office	190
05	Room 180 Sink Faucet	70
35	Room 121 Large Sink Faucet Right	22
36	Room 131 S. Wall Left Sink Faucet	41
37	Room 131 S. Wall Middle Sink Faucet	62
38	Room 131 S. Wall Right Sink Faucet	23
39	Room 131 N. Wall Left Sink Faucet	100
40	Room 131 N. Wall Middle Sink Faucet	100
41	Room 131 N. Wall Right Sink Faucet	46
43	Room 133 S. Wall Left Sink Faucet	90
44	Room 133 S. Wall Middle Sink Faucet	32
45	Room 133 S. Wall Right Sink Faucet	37
46	Room 133 N. Wall Left Sink Faucet	65
47	Room 133 N. Wall Middle Sink Faucet	95
48	Room 133 N. Wall Right Sink Faucet	38
80	Room 213 W. Wall 2 <sup>nd</sup> From Left Sink Faucet	51
83	Room 211 E. Wall Left Sink Faucet	27
84	Room 211 E. Wall Center Sink Faucet	24
85	Room 211 E. Wall Right Sink Faucet	18
86	Room 211 Left Bench SE Sink Faucet	30
87	Room 211 Left Bench NE Sink Faucet	30
88	Room 211 Left Bench SW Sink Faucet	53
89	Room 211 Left Bench NW Sink Faucet	28
91	Room 211 Center Bench NE Sink Faucet	26
97	Room 211 Right Bench NW Sink Faucet	16
99	Room 214 E. Wall Left Sink Faucet	51

100	Room 212 Instructor's Sink Faucet	35
102	Room 212 E. Wall Left Bench SW Sink Faucet	20
103	Room 212 E. Wall Left Bench NE Sink Faucet	23
104	Room 212 E. Wall Left Bench SE Sink Faucet	25
107	Room 212 E. Wall Center Bench NE Sink Faucet	25
112	Room 212 E. Wall Right Bench SE Sink Faucet	16
115	Room 212 W. Wall Center Bench SE Sink Faucet	34
118	Room 212 W. Wall Center Bench NW Sink Faucet	22
121	Room 212 W. Wall Right Bench SW Sink Faucet	30
122	Room 212 W. Wall Right Bench NW Sink Faucet	23
124	Room 209 Instructor's Sink Faucet	48
126	Room 209 W. Wall Left Bench NE Sink Faucet	19
127	Room 209 W. Wall Left Bench SW Sink Faucet	18
128	Room 209 W. Wall Left Bench NW Sink Faucet	18
133	Room 209 W. Wall Right Bench SE Sink Faucet	17
141	Room 209 E. Wall Center Bench SW Sink Faucet	17
145	Room 209 E. Wall Right Bench SW Sink Faucet	25
148	Room 207 Instructor's Sink Faucet	27
152	Room 231 N. Wall Left Sink Faucet	39
153	Room 231 N. Wall Center Sink Faucet	37
154	Room 231 N. Wall Right Sink Faucet	72
155	Room 231 S. Wall Left Sink Faucet	99
156	Room 231 S. Wall Center Sink Faucet	160
157	Room 231 S. Wall Right Sink Faucet	36
159	Room 233 Sink Faucet	31
161	Room 246M Sink Faucet	34
162	Room 246W Sink Faucet	63

## Discussion

In order to be used as healthful fluid for human consumption, water must be free from organisms that are capable of causing disease and from minerals and organic substances that could produce adverse physiological effects. (1) The Safe Drinking Water Act sets maximum contaminant levels (MCLs) for numerous contaminants. These include various inorganic, volatile organic, and synthetic organic compounds. Public water systems are required to do initial and periodic testing of their source water.

## Comments & Recommendations

Per the requirements of Subpart 67-4: Lead Testing in School Drinking Water, we sampled water outlets in the New Paltz Central School District's High School on October 22, 2016. This was two days prior to the 10/31/16 deadline for Grade 6-12 schools. The regulation defines a water outlet as one that is currently or may potentially be used for cooking or drinking. We identified a total of 164 such water outlets in the high school. There were 10 other locations sampled at the high school using the DOH's protocol prior to the enactment of the law. Of these 174 locations, 53 exceeded the 15 parts per billion (ppb) action level. Per 67-4.4, these outlets must be taken out of service until remediation and re-testing indicate that the lead levels are at or below the action level. If a location, like a toilet room sink, is needed for hygiene purposes signage can be posted (see **Appendix B**) instructing building occupants this water is not intended for drinking purposes. Please note that this is a short-term solution only. The vast majority of outlets that exceeded 15 ppb were laboratory sink. We are still awaiting the official guidance from the state, but it is anticipated that lab fixtures that exceeded the action level will not have to be replaced so long as certain conditions are met.

## References

1. **American Water Works Association:** *Water Quality and Treatment*. New York, NY: McGraw-Hill, 1990
2. **Bailey, R.A. et. al.:** *Chemistry of the Environment*. New York, NY: Academic Press, 1978.
3. **USEPA:** *3Ts for Reducing Lead in Drinking Water in Schools*. Washington, DC: USEPA, 2006.

# **APPENDIX A**

## Laboratory Reports

## **ANALYTICAL REPORT**

Job Number: 420-112577-1

SDG Number: New Paltz CSD - High School

Job Description: Ulster BOCES

For:

Ulster BOCES

175 Roue 32 North

New Paltz, NY 12561

Attention: Michael O'Rourke



---

Meredith W Ruthven

Customer Service Manager

mruthven@envirotestlaboratories.com

12/08/2016

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories Inc. certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative.

EnviroTest Laboratories, Inc. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554



## METHOD SUMMARY

Client: Ulster BOCES

Job Number: 420-112577-1  
SDG Number: New Paltz CSD - High School

<b>Description</b>	<b>Lab Location</b>	<b>Method</b>	<b>Preparation Method</b>
<b>Matrix: Water</b>			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200

### Lab References:

EnvTest = EnviroTest

### Method References:

EPA = US Environmental Protection Agency

## METHOD / ANALYST SUMMARY

Client: Ulster BOCES

Job Number: 420-112577-1  
SDG Number: New Paltz CSD - High School

<b>Method</b>	<b>Analyst</b>	<b>Analyst ID</b>
EPA 200.8 Rev.5.4	Palentino, Gus J	GJP
EPA 200.8 Rev.5.4	Sirico, Derek	DS

## SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-112577-1  
SDG Number: New Paltz CSD - High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112577-1	01 - Library Sink Faucet	Drinking Water	10/28/2016 0640	10/31/2016 0935
420-112577-2	02 - main Office Water Fountain	Drinking Water	10/28/2016 0643	10/31/2016 0935
420-112577-3	03 - Men's TR Sink Faucet Outside Main Office	Drinking Water	10/28/2016 0643	10/31/2016 0935
420-112577-4	04 - Women's TR Sink Faucet Outside Main Office	Drinking Water	10/28/2016 0644	10/31/2016 0935
420-112577-5	05 - Room 180 Sink Faucet	Drinking Water	10/28/2016 0645	10/31/2016 0935
420-112577-6	06 - Room 184W Left Sink Faucet	Drinking Water	10/28/2016 0647	10/31/2016 0935
420-112577-7	07 - Room 184 W Center Sink Faucet	Drinking Water	10/28/2016 0647	10/31/2016 0935
420-112577-8	08 - Room 184W Right Sink Faucet	Drinking Water	10/28/2016 0604	10/31/2016 0935
420-112577-9	09 - Room 184M Left Sink Faucet	Drinking Water	10/28/2016 0648	10/31/2016 0935
420-112577-10	10 - Room 184M Center Sink Faucet	Drinking Water	10/28/2016 0648	10/31/2016 0935
420-112577-11	11 - Room 184 M Right Sink Faucet	Drinking Water	10/28/2016 0648	10/31/2016 0935
420-112577-12	12 - Room 116W Sink Faucet Left	Drinking Water	10/28/2016 0652	10/31/2016 0935
420-112577-13	13 -Room 116W Sink Faucet 2nd from Left	Drinking Water	10/28/2016 0652	10/31/2016 0935
420-112577-14	14 -Room 116W Sink Faucet 2nd from right	Drinking Water	10/28/2016 0653	10/31/2016 0935
420-112577-15	15 - Room 116W Sink Faucet Right	Drinking Water	10/28/2016 0653	10/31/2016 0935
420-112577-16	16 - Room 116M Left Sink Faucet	Drinking Water	10/28/2016 0654	10/31/2016 0935
420-112577-17	17 - Room 116M Middle Sink Faucet	Drinking Water	10/28/2016 0654	10/31/2016 0935
420-112577-18	18 - Room 116M Right Sink Faucet	Drinking Water	10/28/2016 0654	10/31/2016 0935
420-112577-19	19 - Room 115B Sink Faucet	Drinking Water	10/28/2016 0657	10/31/2016 0935
420-112577-20	20 - Room 115B TR Sink Faucet	Drinking Water	10/28/2016 0657	10/31/2016 0935
420-112577-21	21 - Room 115B Small TR Sink Faucet	Drinking Water	10/28/2016 0700	10/31/2016 0935
420-112577-22	22 - Room 117 2-Bay Left Sink Faucet	Drinking Water	10/28/2016 0701	10/31/2016 0935
420-112577-23	23 - Room 117 2-Bay 2nd from left Sink Faucet	Drinking Water	10/28/2016 0702	10/31/2016 0935
420-112577-24	24 - Room 117 2-Bay 3rd from left Sink Faucet	Drinking Water	10/28/2016 0702	10/31/2016 0935
420-112577-25	25 - Room 117 2-Bay 3rd from right Sink Faucet	Drinking Water	10/28/2016 0702	10/31/2016 0935
420-112577-26	26 - Room 117 2-Bay 2nd From Right Sink Faucet	Drinking Water	10/28/2016 0702	10/31/2016 0935
420-112577-27	27 - Room 117 Sink Sink Faucet	Drinking Water	10/28/2016 0702	10/31/2016 0935
420-112577-28	28 - Room 119 Sink Faucet	Drinking Water	10/28/2016 0704	10/31/2016 0935

## SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-112577-1  
SDG Number: New Paltz CSD - High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112577-29	29 - Room 119 Dark Room Left Sink Faucet	Drinking Water	10/28/2016 0706	10/31/2016 0935
420-112577-30	30 - Room 119 Dark Room Middle Sink Faucet	Drinking Water	10/28/2016 0706	10/31/2016 0935
420-112577-31	31 - Room 119 Dark Room Right Sink Faucet	Drinking Water	10/28/2016 0706	10/31/2016 0935
420-112577-32	32 - Room 121 Small Sink Faucet	Drinking Water	10/28/2016 0708	10/31/2016 0935
420-112577-33	33 - Room 121 Large Sink Faucet Left	Drinking Water	10/28/2016 0709	10/31/2016 0935
420-112577-34	34 - Room 121 Large Sink Faucet Middle	Drinking Water	10/28/2016 0709	10/31/2016 0935
420-112577-35	35 - Room 121 large Sink Faucet right	Drinking Water	10/28/2016 0709	10/31/2016 0935
420-112577-36	36 - Room 131 South Wall left Sink Faucet	Drinking Water	10/28/2016 0713	10/31/2016 0935
420-112577-37	37 - Room 131 South Wall Middle Sink Faucet	Drinking Water	10/28/2016 0714	10/31/2016 0935
420-112577-38	38 - Room 131 South Wall Right Sink Faucet	Drinking Water	10/28/2016 0714	10/31/2016 0935
420-112577-39	39 - Room 131 North Wall Left Sink Faucet	Drinking Water	10/28/2016 0715	10/31/2016 0935
420-112577-40	40 - Room 131 North Wall Middle Sink Faucet	Drinking Water	10/28/2016 0715	10/31/2016 0935
420-112577-41	41 - Room 131 North Wall Right Sink Faucet	Drinking Water	10/28/2016 0715	10/31/2016 0935
420-112577-42	42 - Room 132 Sink Faucet	Drinking Water	10/28/2016 0717	10/31/2016 0935
420-112577-43	43 - Room 133 South Wall Left Sink Faucet	Drinking Water	10/28/2016 0718	10/31/2016 0935
420-112577-44	44 - Room 133 South Wall Middle Sink Faucet	Drinking Water	10/28/2016 0718	10/31/2016 0935
420-112577-45	45 - Room 133 South Wall Right Sink Faucet	Drinking Water	10/28/2016 0718	10/31/2016 0935
420-112577-46	46 - Room 133 North Wall Left Sink Faucet	Drinking Water	10/28/2016 0719	10/31/2016 0935
420-112577-47	47 - Room 133 North Wall Middle Sink Faucet	Drinking Water	10/28/2016 0719	10/31/2016 0935
420-112577-48	48 - Room 133 North Wall Right Sink Faucet	Drinking Water	10/28/2016 0719	10/31/2016 0935
420-112577-49	49 - Room 146M Sink Faucet	Drinking Water	10/28/2016 0721	10/31/2016 0935
420-112577-50	50 - Room 146W Sink Faucet	Drinking Water	10/28/2016 0721	10/31/2016 0935
420-112577-51	51 - Room 152M Sink Faucet	Drinking Water	10/28/2016 0723	10/31/2016 0935
420-112577-52	52 - Room 152W Sink Faucet	Drinking Water	10/28/2016 0723	10/31/2016 0935
420-112577-53	53 - Boy's Locker room Left Sink Faucet	Drinking Water	10/29/2016 1135	10/31/2016 0935
420-112577-54	54 - Boy's Locker room Right Sink Faucet	Drinking Water	10/29/2016 1135	10/31/2016 0935
420-112577-55	55 - Boy's Locker Room TR Sink Faucet	Drinking Water	10/29/2016 1136	10/31/2016 0935

## SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-112577-1  
SDG Number: New Paltz CSD - High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112577-56	56 - Boy's Locker Room PE TR Sink Faucet	Drinking Water	10/29/2016 1137	10/31/2016 0935
420-112577-57	57 - Boy's Locker Room Coach's TR Sink Faucet	Drinking Water	10/29/2016 1138	10/31/2016 0935
420-112577-58	58 - Girl's Locker Room Water Fountain	Drinking Water	10/29/2016 1141	10/31/2016 0935
420-112577-59	59 - Girl's locker Room Left Sink Faucet	Drinking Water	10/29/2016 1142	10/31/2016 0935
420-112577-60	60 - Girl's Locker Room Right Sink Faucet	Drinking Water	10/29/2016 1142	10/31/2016 0935
420-112577-61	61 - Girl's Locker Room Coach's TR Sink Faucet	Drinking Water	10/29/2016 1142	10/31/2016 0935
420-112577-62	62 - Cafeteria Lower Water Fountain	Drinking Water	10/29/2016 1146	10/31/2016 0935
420-112577-63	63 - Kitchen 3-bay Sink Left Faucet	Drinking Water	10/29/2016 1149	10/31/2016 0935
420-112577-64	64 - Kitchen 3-bay Sink Center Faucet	Drinking Water	10/29/2016 1150	10/31/2016 0935
420-112577-65	65 -Kitchen 3-bay Sink Right Faucet	Drinking Water	10/29/2016 1150	10/31/2016 0935
420-112577-66	66 - Kitchen N. Wall handwashing Sink Faucet	Drinking Water	10/29/2016 1151	10/31/2016 0935
420-112577-67	67 - Kitchen north wall Sink Faucet	Drinking Water	10/29/2016 1151	10/31/2016 0935
420-112577-68	68 - Kitchen Sprayer sink	Drinking Water	10/29/2016 1152	10/31/2016 0935
420-112577-69	69 - Kitchen Handwashing sink near sprayer	Drinking Water	10/29/2016 1152	10/31/2016 0935
420-112577-70	70 - Lower Water fountain outside Gym B	Drinking Water	10/29/2016 1157	10/31/2016 0935
420-112577-71	71 - Lower water fountain outside room 165	Drinking Water	10/29/2016 1159	10/31/2016 0935
420-112577-72	72 - Room 216M Left Sink Faucet	Drinking Water	10/29/2016 1203	10/31/2016 0935
420-112577-73	73 - Room 216M Center Sink Faucet	Drinking Water	10/29/2016 1204	10/31/2016 0935
420-112577-74	74 - Room 216M Right Sink Faucet	Drinking Water	10/29/2016 1204	10/31/2016 0935
420-112577-75	75 - Room 216 Left Sink Faucet	Drinking Water	10/29/2016 1205	10/31/2016 0935
420-112577-76	76 - Room 216 2nd from left Sink Faucet	Drinking Water	10/29/2016 1205	10/31/2016 0935
420-112577-77	77 - Room 216 2nd from Right Sink Faucet	Drinking Water	10/29/2016 1206	10/31/2016 0935
420-112577-78	78 - Room 216 Right Sink Faucet	Drinking Water	10/29/2016 1206	10/31/2016 0935
420-112577-79	79 - Room 213 W. Wall Left Sink Faucet	Drinking Water	10/29/2016 1208	10/31/2016 0935
420-112577-80	80 - Room 213 W. Wall 2nd From left Sink Faucet	Drinking Water	10/29/2016 1208	10/31/2016 0935
420-112577-81	81 - Room 213 W. Wall 2nd from right Sink Faucet	Drinking Water	10/29/2016 1209	10/31/2016 0935
420-112577-82	82 - Room 213 W. Wall Right Sink Faucet	Drinking Water	10/29/2016 1209	10/31/2016 0935

## SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-112577-1  
SDG Number: New Paltz CSD - High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112577-83	83 - Room 211 E. Wall Left Sink Faucet	Drinking Water	10/29/2016 1211	10/31/2016 0935
420-112577-84	84 - Room 211 E. Wall Center Sink Faucet	Drinking Water	10/29/2016 1212	10/31/2016 0935
420-112577-85	85 - Room 211 E. Wall Right Sink Faucet	Drinking Water	10/29/2016 1212	10/31/2016 0935
420-112577-86	86 - Room 211 Left bench SE Sink Faucet	Drinking Water	10/29/2016 1213	10/31/2016 0935
420-112577-87	87 - Room 211 Left Bench NE Sink Faucet	Drinking Water	10/29/2016 1214	10/31/2016 0935
420-112577-88	88 - Room 211 Left Bench SW Sink Faucet	Drinking Water	10/29/2016 1214	10/31/2016 0935
420-112577-89	89 - Room 211 Left Bench NW Sink Faucet	Drinking Water	10/29/2016 1214	10/31/2016 0935
420-112577-90	90 - Room 211 Center Bench SE Sink Faucet	Drinking Water	10/29/2016 1215	10/31/2016 0935
420-112577-91	91 - Room 211 Center Bench NE Sink Faucet	Drinking Water	10/29/2016 1215	10/31/2016 0935
420-112577-92	92 - Room 211 Center Bench SW Sink Faucet	Drinking Water	10/29/2016 1215	10/31/2016 0935
420-112577-93	93 - Room 211 Center Bench NW Sink Faucet	Drinking Water	10/29/2016 1216	10/31/2016 0935
420-112577-94	94 - Room 211 Right Bench SE Sink Faucet	Drinking Water	10/29/2016 1217	10/31/2016 0935
420-112577-95	95 - Room 211 Right Bench NE Sink Faucet	Drinking Water	10/29/2016 1217	10/31/2016 0935
420-112577-96	96 - Room 211 Right Bench SW Sink Faucet	Drinking Water	10/29/2016 1217	10/31/2016 0935
420-112577-97	97 - Room 211 Right Bench NW Sink Faucet	Drinking Water	10/29/2016 1217	10/31/2016 0935
420-112577-98	98 - Room 214 Instructor's Sink Faucet	Drinking Water	10/29/2016 1220	10/31/2016 0935
420-112577-99	99 - Room 214 East Wall Left Sink Faucet	Drinking Water	10/29/2016 1221	10/31/2016 0935
420-112577-100	100 - Room 212 Instructor's Sink Faucet	Drinking Water	10/29/2016 1223	10/31/2016 0935
420-112577-101	101 - Room 212 E. Wall Left Bench NW Sink Faucet	Drinking Water	10/29/2016 1226	10/31/2016 0935
420-112577-102	102 - Room 212 E. Wall Left Bench SW Sink Faucet	Drinking Water	10/29/2016 1227	10/31/2016 0935
420-112577-103	103 - Room 212 E. Wall Left Bench NE Sink Faucet	Drinking Water	10/29/2016 1227	10/31/2016 0935
420-112577-104	104 - Room 212 E. Wall Left Bench SE Sink Faucet	Drinking Water	10/29/2016 1227	10/31/2016 0935
420-112577-105	105 - Room 213 E. Wall Center bench NW Sink Faucet	Drinking Water	10/29/2016 1227	10/31/2016 0935
420-112577-106	106 - Room 213 E. Wall Center bench SW Sink Faucet	Drinking Water	10/29/2016 1228	10/31/2016 0935

## SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-112577-1  
SDG Number: New Paltz CSD - High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112577-107	107 - Room 213 E. Wall Center bench NE Sink Faucet	Drinking Water	10/29/2016 1228	10/31/2016 0935
420-112577-108	108 - Room 213 E. Wall Center bench SE Sink Faucet	Drinking Water	10/29/2016 1228	10/31/2016 0935
420-112577-109	109 - Room 213 E. Wall Right Bench NW Sink Faucet	Drinking Water	10/29/2016 1229	10/31/2016 0935
420-112577-110	110 - Room 213 E. Wall Right Bench SW Sink Faucet	Drinking Water	10/29/2016 1229	10/31/2016 0935
420-112577-111	111 - Room 213 E. Wall Right Bench NE Sink Faucet	Drinking Water	10/29/2016 1229	10/31/2016 0935
420-112577-112	112 - Room 213 E. Wall Right Bench SE Sink Faucet	Drinking Water	10/29/2016 1229	10/31/2016 0935
420-112577-113	113 - Room 212 W. Wall Left Bench SW Sink Faucet	Drinking Water	10/29/2016 1230	10/31/2016 0935
420-112577-114	114 - Room 212 W. Wall Left Bench NW Sink Faucet	Drinking Water	10/29/2016 1230	10/31/2016 0935
420-112577-115	115 - Room 212 W. Wall Left Bench SE Sink Faucet	Drinking Water	10/29/2016 1231	10/31/2016 0935
420-112577-116	116 - Room 212 W. Wall Left Bench NE Sink Faucet	Drinking Water	10/29/2016 1231	10/31/2016 0935
420-112577-117	117 - Room 212 W. Wall Center Bench SW Sink Faucet	Drinking Water	10/29/2016 1231	10/31/2016 0935
420-112577-118	118 - Room 212 W. Wall Center Bench NW Sink Faucet	Drinking Water	10/29/2016 1231	10/31/2016 0935
420-112577-119	119 - Room 212 W. Wall Right Bench SE Sink Faucet	Drinking Water	10/29/2016 1233	10/31/2016 0935
420-112577-120	120 - Room 212 W. Wall Right Bench NE Sink Faucet	Drinking Water	10/29/2016 1233	10/31/2016 0935
420-112577-121	121 - Room 212 W. Wall Right Bench SW Sink Faucet	Drinking Water	10/29/2016 1233	10/31/2016 0935
420-112577-122	122 - Room 212 W. Wall Right Bench NW Sink Faucet	Drinking Water	10/29/2016 1233	10/31/2016 0935
420-112577-123	123 - Room 211A Prep Room Sink Faucet	Drinking Water	10/29/2016 1235	10/31/2016 0935
420-112577-124	124 - Room 209 Instructor's Sink Faucet	Drinking Water	10/29/2016 1236	10/31/2016 0935
420-112577-125	125 - Room 209 W. Wall Left Bench SE Sink Faucet	Drinking Water	10/29/2016 1238	10/31/2016 0935

## SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-112577-1  
SDG Number: New Paltz CSD - High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112577-126	126 - Room 209 W. Wall Left Bench NE Sink Faucet	Drinking Water	10/29/2016 1238	10/31/2016 0935
420-112577-127	127 - Room 209 W. Wall Left Bench SW Sink Faucet	Drinking Water	10/29/2016 1238	10/31/2016 0935
420-112577-128	128 - Room 209 W. Wall Left Bench NW Sink Faucet	Drinking Water	10/29/2016 1238	10/31/2016 0935
420-112577-129	129 - Room 209 W. Wall Center Bench SE Sink Faucet	Drinking Water	10/29/2016 1239	10/31/2016 0935
420-112577-130	130 - Room 209 W. Wall Center Bench NE Sink Faucet	Drinking Water	10/29/2016 1239	10/31/2016 0935
420-112577-131	131 - Room 209 W. Wall Center Bench SW Sink Faucet	Drinking Water	10/29/2016 1239	10/31/2016 0935
420-112577-132	132 - Room 209 W. Wall Center Bench NW Sink Faucet	Drinking Water	10/29/2016 1239	10/31/2016 0935
420-112577-133	133 - Room 209 W. Wall Right Bench SE Sink Faucet	Drinking Water	10/29/2016 1240	10/31/2016 0935
420-112577-134	134 - Room 209 W. Wall Right Bench NE Sink Faucet	Drinking Water	10/29/2016 1240	10/31/2016 0935
420-112577-135	135 - Room 209 W. Wall Right Bench SW Sink Faucet	Drinking Water	10/29/2016 1240	10/31/2016 0935
420-112577-136	136 - Room 209 W. Wall Right Bench NW Sink Faucet	Drinking Water	10/29/2016 1240	10/31/2016 0935
420-112577-137	137 - Room 209 E. Wall Left Bench SW Sink Faucet	Drinking Water	10/29/2016 1241	10/31/2016 0935
420-112577-138	138 - Room 209 E. Wall Left Bench NE Sink Faucet	Drinking Water	10/29/2016 1241	10/31/2016 0935
420-112577-139	139 - Room 209 E. Wall Left Bench SE Sink Faucet	Drinking Water	10/29/2016 1241	10/31/2016 0935
420-112577-140	140 - Room 209 E. Wall Center Bench NW Sink Faucet	Drinking Water	10/29/2016 1243	10/31/2016 0935
420-112577-141	141 - Room 209 E. Wall Center Bench SW Sink Faucet	Drinking Water	10/29/2016 1243	10/31/2016 0935
420-112577-142	142 - Room 209 E. Wall Center Bench NE Sink Faucet	Drinking Water	10/29/2016 1243	10/31/2016 0935
420-112577-143	143 - Room 209 E. Wall Center Bench SE Sink Faucet	Drinking Water	10/29/2016 1243	10/31/2016 0935



## SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-112577-1  
SDG Number: New Paltz CSD - High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112577-144	144 - Room 209 E. Wall Right Bench NW Sink Faucet	Drinking Water	10/29/2016 1244	10/31/2016 0935
420-112577-145	145 - Room 209 E. Wall Right Bench SW Sink Faucet	Drinking Water	10/29/2016 1244	10/31/2016 0935
420-112577-146	146 - Room 209 E. Wall Right Bench NE Sink Faucet	Drinking Water	10/29/2016 1244	10/31/2016 0935
420-112577-147	147 - Room 209 E. Wall Right Bench SE Sink Faucet	Drinking Water	10/29/2016 1244	10/31/2016 0935
420-112577-148	148 - Room 207 Instructor's Sink Faucet	Drinking Water	10/29/2016 1247	10/31/2016 0935
420-112577-149	149 - Room 207 West Wall Center Sink Faucet	Drinking Water	10/29/2016 1248	10/31/2016 0935
420-112577-150	150 - Room 204M Sink Faucet	Drinking Water	10/29/2016 1249	10/31/2016 0935
420-112577-151	151 - Room 204W Sink Faucet	Drinking Water	10/29/2016 1250	10/31/2016 0935
420-112577-152	152 - Room 231 N. Wall Left Sink Faucet	Drinking Water	10/29/2016 1255	10/31/2016 0935
420-112577-153	153 - Room 231 N. Wall Center Sink Faucet	Drinking Water	10/29/2016 1255	10/31/2016 0935
420-112577-154	154 - Room 231 N. Wall Right Sink Faucet	Drinking Water	10/29/2016 1255	10/31/2016 0935
420-112577-155	155 - Room 231 S. Wall Left Sink Faucet	Drinking Water	10/29/2016 1256	10/31/2016 0935
420-112577-156	156 - Room 231 S. Wall Center Sink Faucet	Drinking Water	10/29/2016 1257	10/31/2016 0935
420-112577-157	157 - Room 131 S. Wall Right Sink Faucet	Drinking Water	10/29/2016 1257	10/31/2016 0935
420-112577-158	158 - Room 232 Sink Faucet	Drinking Water	10/29/2016 1258	10/31/2016 0935
420-112577-159	159 - Room 233 Sink Faucet	Drinking Water	10/29/2016 1259	10/31/2016 0935
420-112577-160	160 - Lower Water Fountain near Room 242	Drinking Water	10/29/2016 1301	10/31/2016 0935
420-112577-161	161 - Room 246M Sink Faucet	Drinking Water	10/29/2016 1302	10/31/2016 0935
420-112577-162	162 - Room 246W Sink Faucet	Drinking Water	10/29/2016 1303	10/31/2016 0935
420-112577-163	163 - Room 252M Sink Faucet	Drinking Water	10/29/2016 1303	10/31/2016 0935
420-112577-164	164 - Room 252W Sink Faucet	Drinking Water	10/29/2016 1304	10/31/2016 0935

Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 01 - Library Sink Faucet  
**Lab Sample ID:** 420-112577-1

Date Sampled: 10/28/2016 0640  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1210	
Prep Method: 200			Date Prepared:	11/21/2016 1600	
Pb	1.0	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 02 - main Office Water Fountain  
**Lab Sample ID:** 420-112577-2

Date Sampled: 10/28/2016 0643  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1215	
Prep Method: 200			Date Prepared:	11/21/2016 1600	
Pb	9.8	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 03 - Men's TR Sink Faucet Outside Main Office  
**Lab Sample ID:** 420-112577-3

Date Sampled: 10/28/2016 0643  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1215	
Prep Method: 200			Date Prepared:	11/21/2016 1600	
Pb	190 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 04 - Women's TR Sink Faucet Outside Main  
**Lab Sample ID:** 420-112577-4

Date Sampled: 10/28/2016 0644  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1216	
Prep Method: 200			Date Prepared:	11/21/2016 1600	
Pb	3.9	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 05 - Room 180 Sink Faucet  
**Lab Sample ID:** 420-112577-5

Date Sampled: 10/28/2016 0645  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1217	
Prep Method: 200			Date Prepared:	11/21/2016 1600	
Pb	70	g	ug/L	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 06 - Room 184W Left Sink Faucet  
**Lab Sample ID:** 420-112577-6

Date Sampled: 10/28/2016 0647  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1218	
Prep Method: 200			Date Prepared:	11/21/2016 1600	
Pb	3.6	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 07 - Room 184 W Center Sink Faucet  
**Lab Sample ID:** 420-112577-7

Date Sampled: 10/28/2016 0647  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1219	
Prep Method: 200			Date Prepared:	11/21/2016 1600	
Pb	2.9	ug/L	1.0	1.0	1.0



Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 08 - Room 184W Right Sink Faucet  
**Lab Sample ID:** 420-112577-8

Date Sampled: 10/28/2016 0604  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1219	
Prep Method: 200			Date Prepared:	11/21/2016 1600	
Pb	2.7	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 09 - Room 184M Left Sink Faucet  
**Lab Sample ID:** 420-112577-9

Date Sampled: 10/28/2016 0648  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1220	
Prep Method: 200			Date Prepared:	11/21/2016 1600	
Pb	4.2	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 10 - Room 184M Center Sink Faucet  
**Lab Sample ID:** 420-112577-10

Date Sampled: 10/28/2016 0648  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1222	
Prep Method: 200			Date Prepared:	11/21/2016 1600	
Pb	3.9	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 11 - Room 184 M Right Sink Faucet  
**Lab Sample ID:** 420-112577-11

Date Sampled: 10/28/2016 0648  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1223	
Prep Method: 200			Date Prepared:	11/21/2016 1600	
Pb	5.0	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 12 - Room 116W Sink Faucet Left  
**Lab Sample ID:** 420-112577-12

Date Sampled: 10/28/2016 0652  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1224	
Prep Method: 200			Date Prepared:	11/21/2016 1600	
Pb	4.9	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 13 -Room 116W Sink Faucet 2nd from Left  
**Lab Sample ID:** 420-112577-13

Date Sampled: 10/28/2016 0652  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1225	
Prep Method: 200			Date Prepared:	11/21/2016 1600	
Pb	3.8	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 14 -Room 116W Sink Faucet 2nd from right  
**Lab Sample ID:** 420-112577-14

Date Sampled: 10/28/2016 0653  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1226	
Prep Method: 200			Date Prepared:	11/21/2016 1600	
Pb	4.9	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 15 - Room 116W Sink Faucet Right  
**Lab Sample ID:** 420-112577-15

Date Sampled: 10/28/2016 0653  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1226	
Prep Method: 200			Date Prepared:	11/21/2016 1600	
Pb	2.2	ug/L	1.0	1.0	1.0



Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 16 - Room 116M Left Sink Faucet  
**Lab Sample ID:** 420-112577-16

Date Sampled: 10/28/2016 0654  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1227	
Prep Method: 200			Date Prepared:	11/21/2016 1600	
Pb	4.7	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 17 - Room 116M Middle Sink Faucet  
**Lab Sample ID:** 420-112577-17

Date Sampled: 10/28/2016 0654  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1228	
Prep Method: 200			Date Prepared:	11/21/2016 1600	
Pb	4.7	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 18 - Room 116M Right Sink Faucet  
**Lab Sample ID:** 420-112577-18

Date Sampled: 10/28/2016 0654  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1229	
Prep Method: 200			Date Prepared:	11/21/2016 1600	
Pb	4.9	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 19 - Room 115B Sink Faucet  
**Lab Sample ID:** 420-112577-19

Date Sampled: 10/28/2016 0657  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1229	
Prep Method: 200			Date Prepared:	11/21/2016 1600	
Pb	2.1	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 20 - Room 115B TR Sink Faucet  
**Lab Sample ID:** 420-112577-20

Date Sampled: 10/28/2016 0657  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1232	
Prep Method: 200			Date Prepared:	11/21/2016 1600	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 21 - Room 115B Small TR Sink Faucet  
**Lab Sample ID:** 420-112577-21

Date Sampled: 10/28/2016 0700  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1233	
Prep Method: 200			Date Prepared:	11/21/2016 1700	
Pb	3.8	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 22 - Room 117 2-Bay Left Sink Faucet  
**Lab Sample ID:** 420-112577-22

Date Sampled: 10/28/2016 0701  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1236	
Prep Method: 200			Date Prepared:	11/21/2016 1700	
Pb	3.4	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 23 - Room 117 2-Bay 2nd from left Sink Faucet  
**Lab Sample ID:** 420-112577-23

Date Sampled: 10/28/2016 0702  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1236	
Prep Method: 200			Date Prepared:	11/21/2016 1700	
Pb	2.1	ug/L	1.0	1.0	1.0



Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 24 - Room 117 2-Bay 3rd from left Sink Faucet  
**Lab Sample ID:** 420-112577-24

Date Sampled: 10/28/2016 0702  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1237	
Prep Method: 200			Date Prepared:	11/21/2016 1700	
Pb	3.2	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 25 - Room 117 2-Bay 3rd from right Sink Faucet  
**Lab Sample ID:** 420-112577-25

Date Sampled: 10/28/2016 0702  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1238	
Prep Method: 200			Date Prepared:	11/21/2016 1700	
Pb	3.1	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 26 - Room 117 2-Bay 2nd From Right Sink  
**Lab Sample ID:** 420-112577-26

Date Sampled: 10/28/2016 0702  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1239	
Prep Method: 200			Date Prepared:	11/21/2016 1700	
Pb	1.5	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 27 - Room 117 Sink Sink Faucet  
**Lab Sample ID:** 420-112577-27

Date Sampled: 10/28/2016 0702  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1241	
Prep Method: 200			Date Prepared:	11/21/2016 1700	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 28 - Room 119 Sink Faucet  
**Lab Sample ID:** 420-112577-28

Date Sampled: 10/28/2016 0704  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1242	
Prep Method: 200			Date Prepared:	11/21/2016 1700	
Pb	1.3	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 29 - Room 119 Dark Room Left Sink Faucet  
**Lab Sample ID:** 420-112577-29

Date Sampled: 10/28/2016 0706  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1243	
Prep Method: 200			Date Prepared:	11/21/2016 1700	
Pb	7.5	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 30 - Room 119 Dark Room Middle Sink Faucet  
**Lab Sample ID:** 420-112577-30

Date Sampled: 10/28/2016 0706  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1243	
Prep Method: 200			Date Prepared:	11/21/2016 1700	
Pb	1.1	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 31 - Room 119 Dark Room Right Sink Faucet  
**Lab Sample ID:** 420-112577-31

Date Sampled: 10/28/2016 0706  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1244	
Prep Method: 200			Date Prepared:	11/21/2016 1700	
Pb	2.2	ug/L	1.0	1.0	1.0



Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 32 - Room 121 Small Sink Faucet  
**Lab Sample ID:** 420-112577-32

Date Sampled: 10/28/2016 0708  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1245	
Prep Method: 200			Date Prepared:	11/21/2016 1700	
Pb	2.0	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 33 - Room 121 Large Sink Faucet Left  
**Lab Sample ID:** 420-112577-33

Date Sampled: 10/28/2016 0709  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1246	
Prep Method: 200			Date Prepared:	11/21/2016 1700	
Pb	10	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 34 - Room 121 Large Sink Faucet Middle  
**Lab Sample ID:** 420-112577-34

Date Sampled: 10/28/2016 0709  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1246	
Prep Method: 200			Date Prepared:	11/21/2016 1700	
Pb	3.1	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 35 - Room 121 large Sink Faucet right  
**Lab Sample ID:** 420-112577-35

Date Sampled: 10/28/2016 0709  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1247	
Prep Method: 200			Date Prepared:	11/21/2016 1700	
Pb	22 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 36 - Room 131 South Wall left Sink Faucet  
**Lab Sample ID:** 420-112577-36

Date Sampled: 10/28/2016 0713  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1248	
Prep Method: 200			Date Prepared:	11/21/2016 1700	
Pb	41 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 37 - Room 131 South Wall Middle Sink Faucet  
**Lab Sample ID:** 420-112577-37

Date Sampled: 10/28/2016 0714  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1250	
Prep Method: 200			Date Prepared:	11/21/2016 1700	
Pb	62 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 38 - Room 131 South Wall Right Sink Faucet  
**Lab Sample ID:** 420-112577-38

Date Sampled: 10/28/2016 0714  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1252	
Prep Method: 200			Date Prepared:	11/21/2016 1700	
Pb	23 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 39 - Room 131 North Wall Left Sink Faucet  
**Lab Sample ID:** 420-112577-39

Date Sampled: 10/28/2016 0715  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1253	
Prep Method: 200			Date Prepared:	11/21/2016 1700	
Pb	100 g	ug/L	1.0	1.0	1.0



Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 40 - Room 131 North Wall Middle Sink Faucet  
**Lab Sample ID:** 420-112577-40

Date Sampled: 10/28/2016 0715  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	12/02/2016 0957	
Prep Method: 200			Date Prepared:	11/23/2016 1000	
Pb	100	g	ug/L	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 41 - Room 131 North Wall Right Sink Faucet  
**Lab Sample ID:** 420-112577-41

Date Sampled: 10/28/2016 0715  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1253	
Prep Method: 200			Date Prepared:	11/21/2016 1700	
Pb	46 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 42 - Room 132 Sink Faucet  
**Lab Sample ID:** 420-112577-42

Date Sampled: 10/28/2016 0717  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1254	
Prep Method: 200			Date Prepared:	11/21/2016 1800	
Pb	1.1	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 43 - Room 133 South Wall Left Sink Faucet  
**Lab Sample ID:** 420-112577-43

Date Sampled: 10/28/2016 0718  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1257	
Prep Method: 200			Date Prepared:	11/21/2016 1800	
Pb	90 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 44 - Room 133 South Wall Middle Sink Faucet  
**Lab Sample ID:** 420-112577-44

Date Sampled: 10/28/2016 0718  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1300	
Prep Method: 200			Date Prepared:	11/21/2016 1800	
Pb	32 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 45 - Room 133 South Wall Right Sink Faucet  
**Lab Sample ID:** 420-112577-45

Date Sampled: 10/28/2016 0718  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1300	
Prep Method: 200			Date Prepared:	11/21/2016 1800	
Pb	37 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 46 - Room 133 North Wall Left Sink Faucet  
**Lab Sample ID:** 420-112577-46

Date Sampled: 10/28/2016 0719  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1301	
Prep Method: 200			Date Prepared:	11/21/2016 1800	
Pb	65 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 47 - Room 133 North Wall Middle Sink Faucet  
**Lab Sample ID:** 420-112577-47

Date Sampled: 10/28/2016 0719  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1302	
Prep Method: 200			Date Prepared:	11/21/2016 1800	
Pb	95 g	ug/L	1.0	1.0	1.0



Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 48 - Room 133 North Wall Right Sink Faucet  
**Lab Sample ID:** 420-112577-48

Date Sampled: 10/28/2016 0719  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1303	
Prep Method: 200			Date Prepared:	11/21/2016 1800	
Pb	38 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 49 - Room 146M Sink Faucet  
**Lab Sample ID:** 420-112577-49

Date Sampled: 10/28/2016 0721  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1303	
Prep Method: 200			Date Prepared:	11/21/2016 1800	
Pb	5.8	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 50 - Room 146W Sink Faucet  
**Lab Sample ID:** 420-112577-50

Date Sampled: 10/28/2016 0721  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1304	
Prep Method: 200			Date Prepared:	11/21/2016 1800	
Pb	3.9	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 51 - Room 152M Sink Faucet  
**Lab Sample ID:** 420-112577-51

Date Sampled: 10/28/2016 0723  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1305	
Prep Method: 200			Date Prepared:	11/21/2016 1800	
Pb	2.9	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 52 - Room 152W Sink Faucet  
**Lab Sample ID:** 420-112577-52

Date Sampled: 10/28/2016 0723  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1306	
Prep Method: 200			Date Prepared:	11/21/2016 1800	
Pb	2.1	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 53 - Boy's Locker room Left Sink Faucet  
**Lab Sample ID:** 420-112577-53

Date Sampled: 10/29/2016 1135  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1306	
Prep Method: 200			Date Prepared:	11/21/2016 1800	
Pb	14	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 54 - Boy's Locker room Right Sink Faucet  
**Lab Sample ID:** 420-112577-54

Date Sampled: 10/29/2016 1135  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1309	
Prep Method: 200			Date Prepared:	11/21/2016 1800	
Pb	12	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 55 - Boy's Locker Room TR Sink Faucet  
**Lab Sample ID:** 420-112577-55

Date Sampled: 10/29/2016 1136  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1310	
Prep Method: 200			Date Prepared:	11/21/2016 1800	
Pb	4.0	ug/L	1.0	1.0	1.0



Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 56 - Boy's Locker Room PE TR Sink Faucet  
**Lab Sample ID:** 420-112577-56

Date Sampled: 10/29/2016 1137  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1310	
Prep Method: 200			Date Prepared:	11/21/2016 1800	
Pb	7.8	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 57 - Boy's Locker Room Coach's TR Sink  
**Lab Sample ID:** 420-112577-57

Date Sampled: 10/29/2016 1138  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1311	
Prep Method: 200			Date Prepared:	11/21/2016 1800	
Pb	3.0	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 58 - Girl's Locker Room Water Fountain  
**Lab Sample ID:** 420-112577-58

Date Sampled: 10/29/2016 1141  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1312	
Prep Method: 200			Date Prepared:	11/21/2016 1800	
Pb	11	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 59 - Girl's locker Room Left Sink Faucet  
**Lab Sample ID:** 420-112577-59

Date Sampled: 10/29/2016 1142  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1313	
Prep Method: 200			Date Prepared:	11/21/2016 1800	
Pb	5.0	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 60 - Girl's Locker Room Right Sink Faucet  
**Lab Sample ID:** 420-112577-60

Date Sampled: 10/29/2016 1142  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1313	
Prep Method: 200			Date Prepared:	11/21/2016 1800	
Pb	5.5	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 61 - Girl's Locker Room Coach's TR Sink Faucet  
**Lab Sample ID:** 420-112577-61

Date Sampled: 10/29/2016 1142  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1314	
Prep Method: 200			Date Prepared:	11/21/2016 1800	
Pb	4.9	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 62 - Cafeteria Lower Water Fountain  
**Lab Sample ID:** 420-112577-62

Date Sampled: 10/29/2016 1146  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1519	
Prep Method: 200			Date Prepared:	11/22/2016 0845	
Pb	4.1	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 63 - Kitchen 3-bay Sink Left Faucet  
**Lab Sample ID:** 420-112577-63

Date Sampled: 10/29/2016 1149  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1524	
Prep Method: 200			Date Prepared:	11/22/2016 0845	
Pb	2.9	ug/L	1.0	1.0	1.0



Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 64 - Kitchen 3-bay Sink Center Faucet  
**Lab Sample ID:** 420-112577-64

Date Sampled: 10/29/2016 1150  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1525	
Prep Method: 200			Date Prepared:	11/22/2016 0845	
Pb	3.5	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 65 -Kitchen 3-bay Sink Right Faucet  
**Lab Sample ID:** 420-112577-65

Date Sampled: 10/29/2016 1150  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1525	
Prep Method: 200			Date Prepared:	11/22/2016 0845	
Pb	1.6	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 66 - Kitchen N. Wall handwashing Sink Faucet  
**Lab Sample ID:** 420-112577-66

Date Sampled: 10/29/2016 1151  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1526	
Prep Method: 200			Date Prepared:	11/22/2016 0845	
Pb	3.6	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 67 - Kitchen north wall Sink Faucet  
**Lab Sample ID:** 420-112577-67

Date Sampled: 10/29/2016 1151  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1527	
Prep Method: 200			Date Prepared:	11/22/2016 0845	
Pb	2.0	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 68 - Kitchen Sprayer sink  
**Lab Sample ID:** 420-112577-68

Date Sampled: 10/29/2016 1152  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1528	
Prep Method: 200			Date Prepared:	11/22/2016 0845	
Pb	1.3	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 69 - Kitchen Handwashing sink near sprayer  
**Lab Sample ID:** 420-112577-69

Date Sampled: 10/29/2016 1152  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1528	
Prep Method: 200			Date Prepared:	11/22/2016 0845	
Pb	3.3	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 70 - Lower Water fountain outside Gym B  
**Lab Sample ID:** 420-112577-70

Date Sampled: 10/29/2016 1157  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1529	
Prep Method: 200			Date Prepared:	11/22/2016 0845	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 71 - Lower water fountain outside room 165  
**Lab Sample ID:** 420-112577-71

Date Sampled: 10/29/2016 1159  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1532	
Prep Method: 200			Date Prepared:	11/22/2016 0845	
Pb	1.0 U	ug/L	1.0	1.0	1.0



Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 72 - Room 216M Left Sink Faucet  
**Lab Sample ID:** 420-112577-72

Date Sampled: 10/29/2016 1203  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1532	
Prep Method: 200			Date Prepared:	11/22/2016 0845	
Pb	6.5	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 73 - Room 216M Center Sink Faucet  
**Lab Sample ID:** 420-112577-73

Date Sampled: 10/29/2016 1204  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1533	
Prep Method: 200			Date Prepared:	11/22/2016 0845	
Pb	6.3	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 74 - Room 216M Right Sink Faucet  
**Lab Sample ID:** 420-112577-74

Date Sampled: 10/29/2016 1204  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1534	
Prep Method: 200			Date Prepared:	11/22/2016 0845	
Pb	7.9	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 75 - Room 216 Left Sink Faucet  
**Lab Sample ID:** 420-112577-75

Date Sampled: 10/29/2016 1205  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1535	
Prep Method: 200			Date Prepared:	11/22/2016 0845	
Pb	4.2	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 76 - Room 216 2nd from left Sink Faucet  
**Lab Sample ID:** 420-112577-76

Date Sampled: 10/29/2016 1205  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1535	
Prep Method: 200			Date Prepared:	11/22/2016 0845	
Pb	5.7	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 77 - Room 216 2nd from Right Sink Faucet  
**Lab Sample ID:** 420-112577-77

Date Sampled: 10/29/2016 1206  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1536	
Prep Method: 200			Date Prepared:	11/22/2016 0845	
Pb	4.0	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 78 - Room 216 Right Sink Faucet  
**Lab Sample ID:** 420-112577-78

Date Sampled: 10/29/2016 1206  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1537	
Prep Method: 200			Date Prepared:	11/22/2016 0845	
Pb	6.4	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 79 - Room 213 W. Wall Left Sink Faucet  
**Lab Sample ID:** 420-112577-79

Date Sampled: 10/29/2016 1208  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1538	
Prep Method: 200			Date Prepared:	11/22/2016 0845	
Pb	9.8	ug/L	1.0	1.0	1.0



Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 80 - Room 213 W. Wall 2nd From left Sink  
**Lab Sample ID:** 420-112577-80

Date Sampled: 10/29/2016 1208  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1539	
Prep Method: 200			Date Prepared:	11/22/2016 0845	
Pb	51 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 81 - Room 213 W. Wall 2nd from right Sink  
**Lab Sample ID:** 420-112577-81

Date Sampled: 10/29/2016 1209  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1541	
Prep Method: 200			Date Prepared:	11/22/2016 0845	
Pb	9.3	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 82 - Room 213 W. Wall Right Sink Faucet  
**Lab Sample ID:** 420-112577-82

Date Sampled: 10/29/2016 1209  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1542	
Prep Method: 200			Date Prepared:	11/22/2016 0905	
Pb	2.6	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 83 - Room 211 E. Wall Left Sink Faucet  
**Lab Sample ID:** 420-112577-83

Date Sampled: 10/29/2016 1211  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1545	
Prep Method: 200			Date Prepared:	11/22/2016 0905	
Pb	27 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 84 - Room 211 E. Wall Center Sink Faucet  
**Lab Sample ID:** 420-112577-84

Date Sampled: 10/29/2016 1212  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1545	
Prep Method: 200			Date Prepared:	11/22/2016 0905	
Pb	24 F	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 85 - Room 211 E. Wall Right Sink Faucet  
**Lab Sample ID:** 420-112577-85

Date Sampled: 10/29/2016 1212  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1546	
Prep Method: 200			Date Prepared:	11/22/2016 0905	
Pb	18 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 86 - Room 211 Left bench SE Sink Faucet  
**Lab Sample ID:** 420-112577-86

Date Sampled: 10/29/2016 1213  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1547	
Prep Method: 200			Date Prepared:	11/22/2016 0905	
Pb	30 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 87 - Room 211 Left Bench NE Sink Faucet  
**Lab Sample ID:** 420-112577-87

Date Sampled: 10/29/2016 1214  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1548	
Prep Method: 200			Date Prepared:	11/22/2016 0905	
Pb	30 g	ug/L	1.0	1.0	1.0



Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 88 - Room 211 Left Bench SW Sink Faucet  
**Lab Sample ID:** 420-112577-88

Date Sampled: 10/29/2016 1214  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1550	
Prep Method: 200			Date Prepared:	11/22/2016 0905	
Pb	53 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 89 - Room 211 Left Bench NW Sink Faucet  
**Lab Sample ID:** 420-112577-89

Date Sampled: 10/29/2016 1214  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1551	
Prep Method: 200			Date Prepared:	11/22/2016 0905	
Pb	28 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 90 - Room 211 Center Bench SE Sink Faucet  
**Lab Sample ID:** 420-112577-90

Date Sampled: 10/29/2016 1215  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1552	
Prep Method: 200			Date Prepared:	11/22/2016 0905	
Pb	12	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 91 - Room 211 Center Bench NE Sink Faucet  
**Lab Sample ID:** 420-112577-91

Date Sampled: 10/29/2016 1215  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1552	
Prep Method: 200			Date Prepared:	11/22/2016 0905	
Pb	26 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 92 - Room 211 Center Bench SW Sink Faucet  
**Lab Sample ID:** 420-112577-92

Date Sampled: 10/29/2016 1215  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1553	
Prep Method: 200			Date Prepared:	11/22/2016 0905	
Pb	9.0	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 93 - Room 211 Center Bench NW Sink Faucet  
**Lab Sample ID:** 420-112577-93

Date Sampled: 10/29/2016 1216  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1554	
Prep Method: 200			Date Prepared:	11/22/2016 0905	
Pb	12	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 94 - Room 211 Right Bench SE Sink Faucet  
**Lab Sample ID:** 420-112577-94

Date Sampled: 10/29/2016 1217  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1555	
Prep Method: 200			Date Prepared:	11/22/2016 0905	
Pb	13	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 95 - Room 211 Right Bench NE Sink Faucet  
**Lab Sample ID:** 420-112577-95

Date Sampled: 10/29/2016 1217  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1556	
Prep Method: 200			Date Prepared:	11/22/2016 0905	
Pb	14	ug/L	1.0	1.0	1.0



Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 96 - Room 211 Right Bench SW Sink Faucet  
**Lab Sample ID:** 420-112577-96

Date Sampled: 10/29/2016 1217  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1556	
Prep Method: 200			Date Prepared:	11/22/2016 0905	
Pb	15	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 97 - Room 211 Right Bench NW Sink Faucet  
**Lab Sample ID:** 420-112577-97

Date Sampled: 10/29/2016 1217  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1557	
Prep Method: 200			Date Prepared:	11/22/2016 0905	
Pb	16 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 98 - Room 214 Instructor's Sink Faucet  
**Lab Sample ID:** 420-112577-98

Date Sampled: 10/29/2016 1220  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1559	
Prep Method: 200			Date Prepared:	11/22/2016 0905	
Pb	12	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 99 - Room 214 East Wall Left Sink Faucet  
**Lab Sample ID:** 420-112577-99

Date Sampled: 10/29/2016 1221  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1600	
Prep Method: 200			Date Prepared:	11/22/2016 0905	
Pb	51 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 100 - Room 212 Instructor's Sink Faucet  
**Lab Sample ID:** 420-112577-100

Date Sampled: 10/29/2016 1223  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1601	
Prep Method: 200			Date Prepared:	11/22/2016 0905	
Pb	35 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 101 - Room 212 E. Wall Left Bench NW Sink  
**Lab Sample ID:** 420-112577-101

Date Sampled: 10/29/2016 1226  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1602	
Prep Method: 200			Date Prepared:	11/22/2016 0905	
Pb	15 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 102 - Room 212 E. Wall Left Bench SW Sink  
**Lab Sample ID:** 420-112577-102

Date Sampled: 10/29/2016 1227  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1602	
Prep Method: 200			Date Prepared:	11/22/2016 0925	
Pb	20 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 103 - Room 212 E. Wall Left Bench NE Sink  
**Lab Sample ID:** 420-112577-103

Date Sampled: 10/29/2016 1227  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1606	
Prep Method: 200			Date Prepared:	11/22/2016 0925	
Pb	23 g	ug/L	1.0	1.0	1.0



Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 104 - Room 212 E. Wall Left Bench SE Sink  
**Lab Sample ID:** 420-112577-104

Date Sampled: 10/29/2016 1227  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1606	
Prep Method: 200			Date Prepared:	11/22/2016 0925	
Pb	25 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 105 - Room 213 E. Wall Center bench NW Sink  
**Lab Sample ID:** 420-112577-105

Date Sampled: 10/29/2016 1227  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1609	
Prep Method: 200			Date Prepared:	11/22/2016 0925	
Pb	10	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 106 - Room 213 E. Wall Center bench SW Sink  
**Lab Sample ID:** 420-112577-106

Date Sampled: 10/29/2016 1228  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1609	
Prep Method: 200			Date Prepared:	11/22/2016 0925	
Pb	15	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 107 - Room 213 E. Wall Center bench NE Sink  
**Lab Sample ID:** 420-112577-107

Date Sampled: 10/29/2016 1228  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1610	
Prep Method: 200			Date Prepared:	11/22/2016 0925	
Pb	25 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 108 - Room 213 E. Wall Center bench SE Sink  
**Lab Sample ID:** 420-112577-108

Date Sampled: 10/29/2016 1228  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1611	
Prep Method: 200			Date Prepared:	11/22/2016 0925	
Pb	10	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 109 - Room 213 E. Wall Right Bench NW Sink  
**Lab Sample ID:** 420-112577-109

Date Sampled: 10/29/2016 1229  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1612	
Prep Method: 200			Date Prepared:	11/22/2016 0925	
Pb	9.5	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 110 - Room 213 E. Wall Right Bench SW Sink  
**Lab Sample ID:** 420-112577-110

Date Sampled: 10/29/2016 1229  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1612	
Prep Method: 200			Date Prepared:	11/22/2016 0925	
Pb	14	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 111 - Room 213 E. Wall Right Bench NE Sink  
**Lab Sample ID:** 420-112577-111

Date Sampled: 10/29/2016 1229  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1613	
Prep Method: 200			Date Prepared:	11/22/2016 0925	
Pb	15 g	ug/L	1.0	1.0	1.0



Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 112 - Room 213 E. Wall Right Bench SE Sink  
**Lab Sample ID:** 420-112577-112

Date Sampled: 10/29/2016 1229  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1614	
Prep Method: 200			Date Prepared:	11/22/2016 0925	
Pb	16 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 113 - Room 212 W. Wall Left Bench SW Sink  
**Lab Sample ID:** 420-112577-113

Date Sampled: 10/29/2016 1230  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1615	
Prep Method: 200			Date Prepared:	11/22/2016 0925	
Pb	7.4	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 114 - Room 212 W. Wall Left Bench NW Sink  
**Lab Sample ID:** 420-112577-114

Date Sampled: 10/29/2016 1230  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1616	
Prep Method: 200			Date Prepared:	11/22/2016 0925	
Pb	7.0	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 115 - Room 212 W. Wall Left Bench SE Sink  
**Lab Sample ID:** 420-112577-115

Date Sampled: 10/29/2016 1231  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1618	
Prep Method: 200			Date Prepared:	11/22/2016 0925	
Pb	34 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 116 - Room 212 W. Wall Left Bench NE Sink  
**Lab Sample ID:** 420-112577-116

Date Sampled: 10/29/2016 1231  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1619	
Prep Method: 200			Date Prepared:	11/22/2016 0925	
Pb	8.0	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 117 - Room 212 W. Wall Center Bench SW Sink  
**Lab Sample ID:** 420-112577-117

Date Sampled: 10/29/2016 1231  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1619	
Prep Method: 200			Date Prepared:	11/22/2016 0925	
Pb	8.3	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 118 - Room 212 W. Wall Center Bench NW Sink  
**Lab Sample ID:** 420-112577-118

Date Sampled: 10/29/2016 1231  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1620	
Prep Method: 200			Date Prepared:	11/22/2016 0925	
Pb	22 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 119 - Room 212 W. Wall Right Bench SE Sink  
**Lab Sample ID:** 420-112577-119

Date Sampled: 10/29/2016 1233  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1621	
Prep Method: 200			Date Prepared:	11/22/2016 0925	
Pb	9.7	ug/L	1.0	1.0	1.0



Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 120 - Room 212 W. Wall Right Bench NE Sink  
**Lab Sample ID:** 420-112577-120

Date Sampled: 10/29/2016 1233  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1622	
Prep Method: 200			Date Prepared:	11/22/2016 0925	
Pb	15	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 121 - Room 212 W. Wall Right Bench SW Sink  
**Lab Sample ID:** 420-112577-121

Date Sampled: 10/29/2016 1233  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1623	
Prep Method: 200			Date Prepared:	11/22/2016 0925	
Pb	30	g	ug/L	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 122 - Room 212 W. Wall Right Bench NW Sink  
**Lab Sample ID:** 420-112577-122

Date Sampled: 10/29/2016 1233  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/23/2016 1623	
Prep Method: 200			Date Prepared:	11/22/2016 0940	
Pb	23 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 123 - Room 211A Prep Room Sink Faucet  
**Lab Sample ID:** 420-112577-123

Date Sampled: 10/29/2016 1235  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1839	
Prep Method: 200			Date Prepared:	11/22/2016 0940	
Pb	13	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 124 - Room 209 Instructor's Sink Faucet  
**Lab Sample ID:** 420-112577-124

Date Sampled: 10/29/2016 1236  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1840	
Prep Method: 200			Date Prepared:	11/22/2016 0940	
Pb	48 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 125 - Room 209 W. Wall Left Bench SE Sink  
**Lab Sample ID:** 420-112577-125

Date Sampled: 10/29/2016 1238  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1840	
Prep Method: 200			Date Prepared:	11/22/2016 0940	
Pb	15 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 126 - Room 209 W. Wall Left Bench NE Sink  
**Lab Sample ID:** 420-112577-126

Date Sampled: 10/29/2016 1238  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1841	
Prep Method: 200			Date Prepared:	11/22/2016 0940	
Pb	19 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 127 - Room 209 W. Wall Left Bench SW Sink  
**Lab Sample ID:** 420-112577-127

Date Sampled: 10/29/2016 1238  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1842	
Prep Method: 200			Date Prepared:	11/22/2016 0940	
Pb	18 g	ug/L	1.0	1.0	1.0



Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 128 - Room 209 W. Wall Left Bench NW Sink  
**Lab Sample ID:** 420-112577-128

Date Sampled: 10/29/2016 1238  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1844	
Prep Method: 200			Date Prepared:	11/22/2016 0940	
Pb	18 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 129 - Room 209 W. Wall Center Bench SE Sink  
**Lab Sample ID:** 420-112577-129

Date Sampled: 10/29/2016 1239  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1845	
Prep Method: 200			Date Prepared:	11/22/2016 0940	
Pb	6.5	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 130 - Room 209 W. Wall Center Bench NE Sink  
**Lab Sample ID:** 420-112577-130

Date Sampled: 10/29/2016 1239  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1846	
Prep Method: 200			Date Prepared:	11/22/2016 0940	
Pb	11	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 131 - Room 209 W. Wall Center Bench SW Sink  
**Lab Sample ID:** 420-112577-131

Date Sampled: 10/29/2016 1239  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1847	
Prep Method: 200			Date Prepared:	11/22/2016 0940	
Pb	7.5	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 132 - Room 209 W. Wall Center Bench NW Sink  
**Lab Sample ID:** 420-112577-132

Date Sampled: 10/29/2016 1239  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1847	
Prep Method: 200			Date Prepared:	11/22/2016 0940	
Pb	6.8	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 133 - Room 209 W. Wall Right Bench SE Sink  
**Lab Sample ID:** 420-112577-133

Date Sampled: 10/29/2016 1240  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1848	
Prep Method: 200			Date Prepared:	11/22/2016 0940	
Pb	17 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 134 - Room 209 W. Wall Right Bench NE Sink  
**Lab Sample ID:** 420-112577-134

Date Sampled: 10/29/2016 1240  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1849	
Prep Method: 200			Date Prepared:	11/22/2016 0940	
Pb	11	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 135 - Room 209 W. Wall Right Bench SW Sink  
**Lab Sample ID:** 420-112577-135

Date Sampled: 10/29/2016 1240  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1850	
Prep Method: 200			Date Prepared:	11/22/2016 0940	
Pb	10	ug/L	1.0	1.0	1.0



Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 136 - Room 209 W. Wall Right Bench NW Sink  
**Lab Sample ID:** 420-112577-136

Date Sampled: 10/29/2016 1240  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1850	
Prep Method: 200			Date Prepared:	11/22/2016 0940	
Pb	13	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 137 - Room 209 E. Wall Left Bench SW Sink  
**Lab Sample ID:** 420-112577-137

Date Sampled: 10/29/2016 1241  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1851	
Prep Method: 200			Date Prepared:	11/22/2016 0940	
Pb	12	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 138 - Room 209 E. Wall Left Bench NE Sink  
**Lab Sample ID:** 420-112577-138

Date Sampled: 10/29/2016 1241  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1854	
Prep Method: 200			Date Prepared:	11/22/2016 0940	
Pb	6.6	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 139 - Room 209 E. Wall Left Bench SE Sink  
**Lab Sample ID:** 420-112577-139

Date Sampled: 10/29/2016 1241  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1854	
Prep Method: 200			Date Prepared:	11/22/2016 0940	
Pb	5.5	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 140 - Room 209 E. Wall Center Bench NW Sink  
**Lab Sample ID:** 420-112577-140

Date Sampled: 10/29/2016 1243  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1855	
Prep Method: 200			Date Prepared:	11/22/2016 0940	
Pb	7.2	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 141 - Room 209 E. Wall Center Bench SW Sink  
**Lab Sample ID:** 420-112577-141

Date Sampled: 10/29/2016 1243  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1856	
Prep Method: 200			Date Prepared:	11/22/2016 0940	
Pb	17 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 142 - Room 209 E. Wall Center Bench NE Sink  
**Lab Sample ID:** 420-112577-142

Date Sampled: 10/29/2016 1243  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1857	
Prep Method: 200			Date Prepared:	11/22/2016 1020	
Pb	11	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 143 - Room 209 E. Wall Center Bench SE Sink  
**Lab Sample ID:** 420-112577-143

Date Sampled: 10/29/2016 1243  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1900	
Prep Method: 200			Date Prepared:	11/22/2016 1020	
Pb	8.4	ug/L	1.0	1.0	1.0



Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 144 - Room 209 E. Wall Right Bench NW Sink  
**Lab Sample ID:** 420-112577-144

Date Sampled: 10/29/2016 1244  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1901	
Prep Method: 200			Date Prepared:	11/22/2016 1020	
Pb	12	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 145 - Room 209 E. Wall Right Bench SW Sink  
**Lab Sample ID:** 420-112577-145

Date Sampled: 10/29/2016 1244  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1903	
Prep Method: 200			Date Prepared:	11/22/2016 1020	
Pb	25 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 146 - Room 209 E. Wall Right Bench NE Sink  
**Lab Sample ID:** 420-112577-146

Date Sampled: 10/29/2016 1244  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1904	
Prep Method: 200			Date Prepared:	11/22/2016 1020	
Pb	7.9	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 147 - Room 209 E. Wall Right Bench SE Sink  
**Lab Sample ID:** 420-112577-147

Date Sampled: 10/29/2016 1244  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1904	
Prep Method: 200			Date Prepared:	11/22/2016 1020	
Pb	12	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 148 - Room 207 Instructor's Sink Faucet  
**Lab Sample ID:** 420-112577-148

Date Sampled: 10/29/2016 1247  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1905	
Prep Method: 200			Date Prepared:	11/22/2016 1020	
Pb	27 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 149 - Room 207 West Wall Center Sink Faucet  
**Lab Sample ID:** 420-112577-149

Date Sampled: 10/29/2016 1248  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1906	
Prep Method: 200			Date Prepared:	11/22/2016 1020	
Pb	6.9	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 150 - Room 204M Sink Faucet  
**Lab Sample ID:** 420-112577-150

Date Sampled: 10/29/2016 1249  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1907	
Prep Method: 200			Date Prepared:	11/22/2016 1020	
Pb	7.6	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 151 - Room 204W Sink Faucet  
**Lab Sample ID:** 420-112577-151

Date Sampled: 10/29/2016 1250  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1907	
Prep Method: 200			Date Prepared:	11/22/2016 1020	
Pb	2.4	ug/L	1.0	1.0	1.0



Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 152 - Room 231 N. Wall Left Sink Faucet  
**Lab Sample ID:** 420-112577-152

Date Sampled: 10/29/2016 1255  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1908	
Prep Method: 200			Date Prepared:	11/22/2016 1020	
Pb	39 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 153 - Room 231 N. Wall Center Sink Faucet  
**Lab Sample ID:** 420-112577-153

Date Sampled: 10/29/2016 1255  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1909	
Prep Method: 200			Date Prepared:	11/22/2016 1020	
Pb	37 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 154 - Room 231 N. Wall Right Sink Faucet  
**Lab Sample ID:** 420-112577-154

Date Sampled: 10/29/2016 1255  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1910	
Prep Method: 200			Date Prepared:	11/22/2016 1020	
Pb	72 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 155 - Room 231 S. Wall Left Sink Faucet  
**Lab Sample ID:** 420-112577-155

Date Sampled: 10/29/2016 1256  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 11/22/2016 1912		
Prep Method: 200			Date Prepared: 11/22/2016 1020		
Pb	99 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 156 - Room 231 S. Wall Center Sink Faucet  
**Lab Sample ID:** 420-112577-156

Date Sampled: 10/29/2016 1257  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1913	
Prep Method: 200			Date Prepared:	11/22/2016 1020	
Pb	160 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 157 - Room 131 S. Wall Right Sink Faucet  
**Lab Sample ID:** 420-112577-157

Date Sampled: 10/29/2016 1257  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1914	
Prep Method: 200			Date Prepared:	11/22/2016 1020	
Pb	36 g	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 158 - Room 232 Sink Faucet  
**Lab Sample ID:** 420-112577-158

Date Sampled: 10/29/2016 1258  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1914	
Prep Method: 200			Date Prepared:	11/22/2016 1020	
Pb	4.9	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 159 - Room 233 Sink Faucet  
**Lab Sample ID:** 420-112577-159

Date Sampled: 10/29/2016 1259  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1915	
Prep Method: 200			Date Prepared:	11/22/2016 1020	
Pb	31 g	ug/L	1.0	1.0	1.0



Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 160 - Lower Water Fountain near Room 242  
**Lab Sample ID:** 420-112577-160

Date Sampled: 10/29/2016 1301  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1916	
Prep Method: 200			Date Prepared:	11/22/2016 1020	
Pb	2.0	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 161 - Room 246M Sink Faucet  
**Lab Sample ID:** 420-112577-161

Date Sampled: 10/29/2016 1302  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1917	
Prep Method: 200			Date Prepared:	11/22/2016 1020	
Pb	34	g	ug/L	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Roue 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 162 - Room 246W Sink Faucet  
**Lab Sample ID:** 420-112577-162

Date Sampled: 10/29/2016 1303  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1917	
Prep Method: 200			Date Prepared:	11/22/2016 1040	
Pb	63	g	ug/L	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 163 - Room 252M Sink Faucet  
**Lab Sample ID:** 420-112577-163

Date Sampled: 10/29/2016 1303  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1922	
Prep Method: 200			Date Prepared:	11/22/2016 1040	
Pb	1.9	ug/L	1.0	1.0	1.0

Michael O'Rourke  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-112577-1  
Sdg Number: New Paltz CSD - High School

**Client Sample ID:** 164 - Room 252W Sink Faucet  
**Lab Sample ID:** 420-112577-164

Date Sampled: 10/29/2016 1304  
Date Received: 10/31/2016 0935  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/22/2016 1923	
Prep Method: 200			Date Prepared:	11/22/2016 1040	
Pb	1.4	ug/L	1.0	1.0	1.0

## DATA REPORTING QUALIFIERS

Client: Ulster BOCES

Job Number:  
Sdg Number: New Paltz CSD - High School

<b>Lab Section</b>	<b>Qualifier</b>	<b>Description</b>
Metals	F	MS or MSD exceeds the control limits
	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

## Certification Information

Client: Ulster BOCES

Job Number:

Sdg Number: New Paltz CSD - High School

---

**The following analytes are Not Part of the ELAP scope of accreditation:**

Sulfur, Tungsten, Silicon, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Phenolphthalein Alkalinity, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), Total Inorganic Carbon, Volatile Acids as Acetic Acid, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, Iron Bacteria, Salmonella, & Sulfur Reducing Bacteria.

**The following analytes are Not Part of ELAP Potable Water scope of accreditation:**

Cobalt (200.7, 200.8), Tin (200.7), Strontium (200.7), Gold (200.7), Platinum (200.7), Palladium (200.7), Titanium (200.7), Phosphorus (365.3), Nitrate-Nitrite (10-107-4-1C, 353.2), m-Xylene & p-Xylene (502.2, 524), Naphthalene (502.2), o-Xylene (502.2, 524), & Fecal Coliform (9222D).

**The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:**

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

**The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:**

Dissolved Organic Carbon (5310C), Mecoprop (8151A), & MCPA (8151A).

## Definitions and Glossary

Client: Ulster BOCES

Job Number:

Sdg Number: New Paltz CSD - High School

---

<u>Abbreviation</u>	<u>These commonly used abbreviations may or may not be present in this report.</u>
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.





**CHAIN OF CUSTODY**  
 Lab Name: EnviroTest Laboratories  
 Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

112577

REPORT# (Lab Use Only)

PROJECT REFERENCE New Paltz CSD - High School		PROJECT NO.	PROJECT LOCATION NPHS	MATRIX TYPE	REQUIRED ANALYSES						PAGE 1 of 1			
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN		40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	TURNAROUND TIME
CLIENT (SITE) PM S. Callahan - results to morourke@ulsterbooces.org		CLIENT PHONE 845-256-4090	CLIENT FAX	AQUEOUS (WATER)	NUMBER OF CONTAINERS SUBMITTED									NORMAL
CLIENT NAME New Paltz Central School District				COMPOSITE (C) OR GRAB (G) INDICATE										QUICK
CLIENT ADDRESS 196 Main Street, New Paltz, NY 12561				D (Drinking Water) or W (Waste Water) Indicate										VERBAL
COMPANY CONTRACTING THIS WORK (if applicable)				SOLID OR SEMISOLID										# OF COOLERS
				OTHER Specify										REMARKS
SAMPLE DATE	TIME	SAMPLE IDENTIFICATION	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP/DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP/DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP/DATE	TIME	
10/28/2016	6:40	01 - Library Sink Faucet	10/31/16	0935	Brian Clonan	Ulster BOCES		Brian Clonan	Ulster BOCES		Brian Clonan	Ulster BOCES		
	6:43	02 - Main Office Water Fountain		1304										
	6:43	03 - Men's TR Sink Faucet Outside Main Office												
	6:44	04 - Women's TR Sink Faucet Outside Main Office												
	6:45	05 - Room 180 Sink Faucet												
	6:47	06 - Room 184W Left Sink Faucet												
	6:47	07 - Room 184W Center Sink Faucet												
	6:47	08 - Room 184W Right Sink Faucet												
	6:48	09 - Room 184M Left Sink Faucet												
	6:48	10 - Room 184M Center Sink Faucet												
	6:48	11 - Room 184M Right Sink Faucet												
	6:52	12 - Room 116W Sink Faucet Left												
	6:52	13 - Room 116W Sink Faucet 2nd From Left												

RECEIVED FOR LABORATORY BY: (SIGNATURE) *[Signature]* DATE 10/31/16 TIME 0935 CUSTODY INTACT YES NO

LABORATORY REMARKS: ICE (Y/N) pH 7.7 Revisited by *[Signature]*

# EnviroTest Laboratories, Inc.

## CHAIN OF CUSTODY

REPORT# (Lab Use Only)

112577

Lab Name: EnviroTest Laboratories  
 Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE New Paltz CSD - High School		PROJECT NO.	PROJECT LOCATION NIPHS	MATRIX TYPE	REQUIRED ANALYSES						PAGE 1 of 2					
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN	OTHER Specify	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	TURNAROUND TIME		
CLIENT (SITE) PM S. Callahan - results to morourke@ulsterboce.com	CLIENT PHONE 845-256-4090	CLIENT FAX		AQUEOUS (WATER)										NORMAL		
CLIENT NAME New Paltz Central School District				COMPOSITE (C) OR GRAB (G) INDICATE										QUICK		
CLIENT ADDRESS 196 Main Street, New Paltz, NY 12561														VERBAL		
COMPANY CONTRACTING THIS WORK (if applicable):																
SAMPLE DATE		SAMPLE IDENTIFICATION			NUMBER OF CONTAINERS SUBMITTED						#OF COOLERS		REMARKS			
10/28/2016	6:53	14 - Room 116W Sink Faucet 2nd From Right			1	1	1	1	1	1	1	1	1	Lead (DW 200.8)		
	6:53	15 - Room 116W Sink Faucet Right			1	1	1	1	1	1	1	1	1	Lead (DW 200.8)		
	6:54	16 - Room 116M Left Sink Faucet			1	1	1	1	1	1	1	1	1	Lead (DW 200.8)		
	6:54	17 - Room 116M Middle Sink Faucet			1	1	1	1	1	1	1	1	1	Lead (DW 200.8)		
	6:54	18 - Room 116M Right Sink Faucet			1	1	1	1	1	1	1	1	1	Lead (DW 200.8)		
	6:56	19 - Room 115B Sink Faucet			1	1	1	1	1	1	1	1	1	Lead (DW 200.8)		
	6:57	20 - Room 115B TR Sink Faucet			1	1	1	1	1	1	1	1	1	Lead (DW 200.8)		
	6:57	21 - Room 115B Small TR Sink Faucet			1	1	1	1	1	1	1	1	1	Lead (DW 200.8)		
	7:00	22 - Room 117 2-Bay Left Sink Faucet			1	1	1	1	1	1	1	1	1	Lead (DW 200.8)		
	7:01	23 - Room 117 2-Bay 2nd From Left Sink Faucet			1	1	1	1	1	1	1	1	1	Lead (DW 200.8)		
	7:02	24 - Room 117 2-Bay 3rd From Left Sink Faucet			1	1	1	1	1	1	1	1	1	Lead (DW 200.8)		
	7:02	25 - Room 117 2-Bay 3rd From Right Sink Faucet			1	1	1	1	1	1	1	1	1	Lead (DW 200.8)		
	7:02	26 - Room 117 2-Bay 2nd From Right Sink Faucet			1	1	1	1	1	1	1	1	1	Lead (DW 200.8)		
RELINQUISHED BY: (SIGNATURE) <i>Brian Glendon Ulster BOCES</i>		COMPANY Ulster BOCES	DATE 10/28/16	TIME 09:35	RECEIVED BY: (SIGNATURE)		COMP/DATE		TIME		RECEIVED BY: (SIGNATURE)		COMP/DATE		TIME	
SAMPLED BY: (SIGNATURE) <i>Brian Glendon Ulster BOCES</i>		COMPANY Ulster BOCES	DATE 10/29/16	TIME 13:04	RECEIVED BY: (SIGNATURE)		COMP/DATE		TIME		RECEIVED BY: (SIGNATURE)		COMP/DATE		TIME	
RELINQUISHED BY: (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)		COMP/DATE		TIME		RECEIVED BY: (SIGNATURE)		COMP/DATE		TIME	

RECEIVED FOR LABORATORY BY: (SIGNATURE) *[Signature]*

DATE: 10/28/16 TIME: 09:35

CUSTOMER INTACT: YES/NO

COOLER TEMP(C): 17.7

LABORATORY REMARKS: ICE (Y/N) PH 7 CL2 1843

112577

Lab Name: EnviroTest Laboratories  
 Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE New Palitz CSD - High School		PROJECT NO.	PROJECT LOCATION NPHS		MATRIX TYPE	REQUIRED ANALYSES				PAGE 1 of 3										
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN			40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	TURNAROUND TIME					
CLIENT (SITE) PM S. Callahan - results to morourke@ulsterbooces.org	CLIENT PHONE 845-256-4090	CLIENT FAX	CLIENT NAME New Palitz Central School District		COMPOSITE (C) OR GRAB (G) INDICATE	NUMBER OF CONTAINERS SUBMITTED				REMARKS										
CLIENT ADDRESS 196 Main Street, New Palitz, NY 12561		SAMPLE IDENTIFICATION		OTHER Specify																
COMPANY CONTRACTING THIS WORK (If applicable)																				
SAMPLE DATE	TIME	SAMPLE IDENTIFICATION		OTHER Specify	COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	D (Drinking Water) or W (Waste Water) Indicate	SOLID OR SEMISOLID	OTHER Specify	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	TURNAROUND TIME	
10/28/2016	7:02	27 - Room 117 Sink Faucet								1		1								Lead (DW 200.8)
	7:04	28 - Room 119 Sink Faucet								1		1								Lead (DW 200.8)
	7:06	29 - Room 119 Dark Room Left Sink Faucet								1		1								Lead (DW 200.8)
	7:06	30 - Room 119 Dark Room Middle Sink Faucet								1		1								Lead (DW 200.8)
	7:06	31 - Room 119 Dark Room Right Sink Faucet								1		1								Lead (DW 200.8)
	7:08	32 - Room 121 Small Sink Faucet								1		1								Lead (DW 200.8)
	7:09	33 - Room 121 Large Sink Faucet Left								1		1								Lead (DW 200.8)
	7:09	34 - Room 121 Large Sink Faucet Middle								1		1								Lead (DW 200.8)
	7:09	35 - Room 121 Large Sink Faucet Right								1		1								Lead (DW 200.8)
	7:13	36 - Room 131 South Wall Left Sink Faucet								1		1								Lead (DW 200.8)
	7:14	37 - Room 131 South Wall Middle Sink Faucet								1		1								Lead (DW 200.8)
	7:14	38 - Room 131 South Wall Right Sink Faucet								1		1								Lead (DW 200.8)
	7:15	39 - Room 131 North Wall Left Sink Faucet								1		1								Lead (DW 200.8)
RELINQUISHED BY: (SIGNATURE) <i>Bevan Colman</i>	DATE 10/28/16	COMPANY Ulster BOCES	TIME 0935	RECEIVED BY: (SIGNATURE)	DATE 10/28/16	COMPANY Ulster BOCES	TIME 1304	RECEIVED BY: (SIGNATURE)	DATE 10/28/16	COMPANY Ulster BOCES	TIME 17.7	RECEIVED BY: (SIGNATURE)	DATE 10/28/16	COMPANY Ulster BOCES	TIME 0935	RECEIVED BY: (SIGNATURE)	DATE 10/28/16	COMPANY Ulster BOCES	TIME 17.7	RECEIVED BY: (SIGNATURE)

RECEIVED FOR LABORATORY BY: (SIGNATURE) *[Signature]* DATE 10/28/16 TIME 0935

CUSTOMER INTACT: YES  NO

LABORATORY REMARKS: ICE (Y/N)  pH  CL2  Reviewed by: *[Signature]*

Lab Name: **EnviroTest Laboratories**  
 Address & Phone: **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

PROJECT REFERENCE New Paltz CSD - High School		PROJECT NO.	PROJECT LOCATION NPHS	MATRIX TYPE	REQUIRED ANALYSES						PAGE 1 of 4
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN	Other	Other	Terra Core	Other	Other	Other	TURNAROUND TIME	
CLIENT (SITE) PM S. Callahan - results to morourke@ulsterboce.com		CLIENT PHONE 845-256-4090	CLIENT FAX	AQUEOUS (WATER)	Other (Drinking Water) or W (Waste Water) Indicate	Other	Other	Other	Other	NORMAL	
CLIENT NAME New Paltz Central School District				COMPOSITE (C) OR GRAB (G) INDICATE	OTHER Specify	Other	Other	Other	Other	QUICK	
CLIENT ADDRESS 196 Main Street, New Paltz, NY 12561				COMPACT (C) OR GRAB (G) INDICATE	OTHER Specify	Other	Other	Other	Other	VERBAL	
COMPANY CONTRACTING THIS WORK (if applicable)				DATE	TIME	DATE	TIME	DATE	TIME	# OF COOLERS	
SAMPLE IDENTIFICATION				DATE	TIME	DATE	TIME	DATE	TIME	REMARKS	
10/28/2016	7:15	40 - Room 131 North Wall Middle Sink Faucet								Lead (DW 200.8)	
	7:15	41 - Room 131 North Wall Right Sink Faucet								Lead (DW 200.8)	
	7:17	42 - Room 132 Sink Faucet								Lead (DW 200.8)	
	7:18	43 - Room 133 South Wall Left Sink Faucet								Lead (DW 200.8)	
	7:18	44 - Room 133 South Wall Middle Sink Faucet								Lead (DW 200.8)	
	7:18	45 - Room 133 South Wall Right Sink Faucet								Lead (DW 200.8)	
	7:19	46 - Room 133 North Wall Left Sink Faucet								Lead (DW 200.8)	
	7:19	47 - Room 133 North Wall Middle Sink Faucet								Lead (DW 200.8)	
	7:19	48 - Room 133 North Wall Right Sink Faucet								Lead (DW 200.8)	
	7:21	49 - Room 146M Sink Faucet								Lead (DW 200.8)	
	7:21	50 - Room 146W Sink Faucet								Lead (DW 200.8)	
	7:23	51 - Room 152M Sink Faucet								Lead (DW 200.8)	
	7:23	52 - Room 152W Sink Faucet								Lead (DW 200.8)	
RELINQUISHED BY: (SIGNATURE) <i>Brian Coburn</i>		COMPANY Ulster Boce's	DATE 10/31/16	TIME 0935	RECEIVED BY: (SIGNATURE)	DATE	TIME	DATE	TIME	RECEIVED BY: (SIGNATURE)	
SAMPLER BY: (SIGNATURE) <i>Brian Coburn</i>		COMPANY Ulster Boce's	DATE 10/28/16	TIME 1304	RECEIVED BY: (SIGNATURE)	DATE	TIME	DATE	TIME	RECEIVED BY: (SIGNATURE)	
RELINQUISHED BY: (SIGNATURE) <i>C. Moore</i>		COMPANY	DATE 10/31/16	TIME 0935	RECEIVED BY: (SIGNATURE)	DATE	TIME	DATE	TIME	RECEIVED BY: (SIGNATURE)	

LABORATORY REMARKS: ICE Y    N    pH    CL2    Reviewed by:

112577

EnviroTest Laboratories  
315 Fullarton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE: New Paltz CSD - High School  
 ENVIROTEST PROJECT MANAGER: Debra Bayer  
 CLIENT (SITE) PM: S. Callahan - results to morourke@ulsterbooces.org  
 CLIENT NAME: New Paltz Central School District  
 CLIENT ADDRESS: 196 Main Street, New Paltz, NY 12561  
 COMPANY CONTRACTING THIS WORK (if applicable):

PROJECT NO.:  
 P.O. NUMBER:  
 CLIENT PHONE: 845-256-4090  
 CLIENT FAX:  
 PROJECT LOCATION: NPHS TOWN:  
 CLIENT FAX:

MATRIX TYPE:  
 AQUEOUS (WATER)  
 COMPOSITE (C) OR GRAB (G) MW/CAT#  
 D (Drinking Water) or W (Waste Water) Indicate  
 SOLID OR SEMISOLID  
 OTHER Specify:

REQUIRED ANALYSES:  
 40ml Vials HCl  
 250ml Plastic Nitric Acid  
 250ml Plastic Sulfuric Acid  
 Liter Plastic  
 250ml Plastic  
 Terra Core  
 Other  
 Other  
 Other  
 PAGE 1 of 5  
 TURNAROUND TIME  
 NORMAL  
 QUICK  
 VERBAL  
 #OF COOLERS  
 REMARKS

DATE	TIME	SAMPLE IDENTIFICATION	NUMBER OF CONTAINERS SUBMITTED										REMARKS		
			1	1	1	1	1	1	1	1	1	1			
10/29/2016	11:35	53 - Boy's Locker Room Left Sink Faucet	1												Lead (DW 200.8)
	11:35	54 - Boy's Locker Room Right Sink Faucet	1												Lead (DW 200.8)
	11:36	55 - Boy's Locker Room TR Sink Faucet	1												Lead (DW 200.8)
	11:37	56 - Boy's Locker Room PE TR Sink Faucet	1												Lead (DW 200.8)
	11:38	57 - Boy's Locker Room Coach's TR Sink Faucet	1												Lead (DW 200.8)
	11:41	58 - Girl's Locker Room Water Fountain	1												Lead (DW 200.8)
	11:42	59 - Girl's Locker Room Left Sink Faucet	1												Lead (DW 200.8)
	11:42	60 - Girl's Locker Room Right Sink Faucet	1												Lead (DW 200.8)
	11:42	61 - Girl's Locker Room Coach's TR Sink Faucet	1												Lead (DW 200.8)
	11:46	62 - Cafeteria Lower Water Fountain	1												Lead (DW 200.8)
	11:49	63 - Kitchen 3-Bay Sink Left Faucet	1												Lead (DW 200.8)
	11:50	64 - Kitchen 3-Bay Sink Center Faucet	1												Lead (DW 200.8)
	11:50	65 - Kitchen 3-Bay Sink Right Faucet	1												Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE) *Debra Bayer* COMPANY: *Ulster BOCES* DATE: *10/31/16* TIME: *0935*  
 RECEIVED BY: (SIGNATURE) \_\_\_\_\_ COMPAN DATE: \_\_\_\_\_ TIME: \_\_\_\_\_  
 SAMPLES BY: (SIGNATURE) *Debra Bayer* COMPANY: *Ulster BOCES* DATE: *10/29/16* TIME: *1804*  
 RELINQUISHED BY: (SIGNATURE) \_\_\_\_\_ COMPANY: \_\_\_\_\_ DATE: \_\_\_\_\_ TIME: \_\_\_\_\_  
 RECEIVED BY: (SIGNATURE) \_\_\_\_\_ COMPAN DATE: \_\_\_\_\_ TIME: \_\_\_\_\_

RECEIVED FOR LAB/DRAW BY: (SIGNATURE) *[Signature]* DATE: *10/31/16* TIME: *0935*  
 CUSTODY INTACT: YES  NO   
 COOLER Temp(C): *17.7*  
 LABORATORY REMARKS: ICE (Y/N) *1* pH *7* CL2 \_\_\_\_\_ Revisited by: *R#3*

Lab Name: **EnviroTest Laboratories**  
 Address & Phone: **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

PROJECT REFERENCE: **New Palitz CSD - High School**  
 ENVIROTEST PROJECT MANAGER: **Debra Bayer**  
 CLIENT (SITE) PM: **S. Callahan - results to mcorourke@ustestlab.com**  
 CLIENT NAME: **New Palitz Central School District**  
 CLIENT ADDRESS: **196 Main Street, New Palitz, NY 12561**  
 COMPANY CONTRACTING THIS WORK (if applicable):

PROJECT NO.	PROJECT LOCATION	MATRIX TYPE	REQUIRED ANALYSES	PAGE 1 of 5
P.O. NUMBER	TOWN	OTHER SPECIFY	Total # of Containers	
CLIENT PHONE	CLIENT FAX	OTHER SPECIFY	40ml Vials HCl	
845-256-4090		OTHER SPECIFY	Liter Amber HCl	
		OTHER SPECIFY	250ml Plastic Nitric Acid	
		OTHER SPECIFY	250ml Plastic Sulfuric Acid	
		OTHER SPECIFY	Liter Plastic	
		OTHER SPECIFY	250ml Plastic	
		OTHER SPECIFY	Terra Core	
		OTHER SPECIFY	Other	
		OTHER SPECIFY	Other	

SAMPLE DATE	TIME	SAMPLE IDENTIFICATION	NUMBER OF CONTAINERS SUBMITTED	REMARKS
10/29/2016	11:51	66 - Kitchen N. Wall Handwashing Sink Faucet	1	Lead (DW 200.8)
	11:51	67 - Kitchen North Wall Sink Faucet	1	Lead (DW 200.8)
	11:52	68 - Kitchen Sprayer Sink	1	Lead (DW 200.8)
	11:52	69 - Kitchen Handwashing Sink Near Sprayer	1	Lead (DW 200.8)
	11:57	70 - Lower Water Fountain Outside Gym B	1	Lead (DW 200.8)
	11:59	71 - Lower Water Fountain Outside Room 165	1	Lead (DW 200.8)
	12:03	72 - Room 216M Left Sink Faucet	1	Lead (DW 200.8)
	12:04	73 - Room 216M Center Sink Faucet	1	Lead (DW 200.8)
	12:04	74 - Room 216M Right Sink Faucet	1	Lead (DW 200.8)
	12:05	75 - Room 216 Left Sink Faucet	1	Lead (DW 200.8)
	12:05	76 - Room 216 2nd From Left Sink Faucet	1	Lead (DW 200.8)
	12:06	77 - Room 216 2nd From Right Sink Faucet	1	Lead (DW 200.8)
	12:06	78 - Room 216 Right Sink Faucet	1	Lead (DW 200.8)

RECEIVED BY: (SIGNATURE) *Debra Bayer* DATE: **10/31/16** TIME: **0935**  
 COMPANY: **Ustestlab**

SAMPLED BY: (SIGNATURE) *Debra Bayer* DATE: **10/29/16** TIME: **1304**  
 COMPANY: **Ustestlab**

RELIQUISHED BY: (SIGNATURE) \_\_\_\_\_ DATE: \_\_\_\_\_ TIME: \_\_\_\_\_  
 COMPANY: \_\_\_\_\_

RECEIVED FOR LABORATORY BY: (SIGNATURE) *[Signature]* DATE: **10/31/16** TIME: **0935**  
 COOLER TEMP (C): **17.3** CUSTODY INTACT: **YES**

LABORATORY REMARKS: **ICE (Y/N) PH (Y/N) CL2 \_\_\_\_\_ Revisited by: [Signature]**

Lab Name: **Enviro Test Laboratories**  
 Address & Phone: **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

PROJECT REFERENCE New Paltz CSD - High School	PROJECT NO.	PROJECT LOCATION NPHS	MATRIX TYPE	REQUIRED ANALYSES	PAGE 1 of 7
ENVIROTEST PROJECT MANAGER Debra Bayer	P.O. NUMBER	TOWN	OTHER Specify	40ml Vials HCl	TURNAROUND TIME
CLIENT (SITE) PH S. Callahan - results to morourke@ulsterbooces.org	CLIENT PHONE 845-256-4090	CLIENT FAX	COMPOSITE (C) OR GRAB (G) INDICATE	Liter Plastic	NORMAL
CLIENT NAME New Paltz Central School District	CLIENT ADDRESS 196 Main Street, New Paltz, NY 12561		AQUEOUS (WATER)	250ml Plastic Sulfuric Acid	QUICK
COMPANY CONTRACTING THIS WORK (If applicable):			D (Drinking Water) or W (Waste Water) Indicate	Liter Amber HCl	VERBAL
SAMPLE IDENTIFICATION			SOLID OR SEMISOLID	250ml Plastic Nitric Acid	#OF COOLERS

SAMPLE DATE	TIME	DESCRIPTION	COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	D (Drinking Water) or W (Waste Water) Indicate	MATRIX TYPE	REQUIRED ANALYSES	NUMBER OF CONTAINERS SUBMITTED	REMARKS
10/29/2016	12:08	79 - Room 213 W. Wall Left Sink Faucet					40ml Vials HCl	1	Lead (DW 200.8)
	12:08	80 - Room 213 W. Wall 2nd From Left Sink Faucet					Liter Amber HCl	1	Lead (DW 200.8)
	12:09	81 - Room 213 W. Wall 2nd From Right Sink Faucet					Liter Plastic	1	Lead (DW 200.8)
	12:09	82 - Room 213 W. Wall Right Sink Faucet					250ml Plastic Sulfuric Acid	1	Lead (DW 200.8)
	12:11	83 - Room 211 E. Wall Left Sink Faucet					250ml Plastic Nitric Acid	1	Lead (DW 200.8)
	12:12	84 - Room 211 E. Wall Center Sink Faucet					Terra Core	1	Lead (DW 200.8)
	12:12	85 - Room 211 E. Wall Right Sink Faucet					Other	1	Lead (DW 200.8)
	12:13	86 - Room 211 Left Bench SE Sink Faucet					Other	1	Lead (DW 200.8)
	12:14	87 - Room 211 Left Bench NE Sink Faucet					Other	1	Lead (DW 200.8)
	12:14	88 - Room 211 Left Bench SW Sink Faucet					Other	1	Lead (DW 200.8)
	12:14	89 - Room 211 Left Bench NW Sink Faucet					Other	1	Lead (DW 200.8)
	12:15	90 - Room 211 Center Bench SE Sink Faucet					Other	1	Lead (DW 200.8)
	12:15	91 - Room 211 Center Bench NE Sink Faucet					Other	1	Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE) <i>Brian Glendon Ulster</i>	COMPANY Ulster BOCES	DATE 10/21/16	TIME 0935
SAMPLER BY: (SIGNATURE) <i>Brian Glendon Ulster</i>	COMPANY Ulster BOCES	DATE 10/29/16	TIME 1304
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE) <i>[Signature]</i>	DATE 10/21/16	TIME 0935	CUSTODY INTACT YES	COOLER Temp(C): 17.7	LABORATORY REMARKS: ICE (Y/N) PH CL2
RECEIVED BY: (SIGNATURE)	DATE	TIME	NO		Revised by: <i>[Signature]</i>

112577

EnviroTest Laboratories  
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE: New Paltz CSD - High School  
 ENVIROTEST PROJECT MANAGER: Debra Bayer  
 CLIENT (SITE) PM: S. Callahan - results to morourke@ulsterbores.org  
 CLIENT NAME: New Paltz Central School District  
 CLIENT ADDRESS: 196 Main Street, New Paltz, NY 12561  
 COMPANY CONTRACTING THIS WORK (if applicable):

PROJECT NO.:  
 P.O. NUMBER:  
 CLIENT PHONE: 845-256-4090  
 CLIENT FAX:  
 PROJECT LOCATION: NPHS TOWN:  
 OTHER Specify:

MATRIX TYPE:  
 COMPOSITE (C) OR GRAB (G) INDICATE:  
 AQUEOUS (WATER):  
 D (Drinking Water) or V (Vase Water) Indicate:  
 SOLID OR SEMISOLID:  
 OTHER Specify:

REQUIRED ANALYSES:  
 40ml Vials HCl  
 Liter Amber HCl  
 250ml Plastic Nitric Acid  
 250ml Plastic Sulfuric Acid  
 Liter Plastic  
 250ml Plastic  
 Terra Core  
 Other  
 Other

DATE	TIME	SAMPLE IDENTIFICATION	NUMBER OF CONTAINERS SUBMITTED										REMARKS		
			Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other			
10/29/2016	12:15	92 - Room 211 Center Bench SW Sink Faucet	1			1									Lead (DW 200.8)
	12:16	93 - Room 211 Center Bench NW Sink Faucet	1			1									Lead (DW 200.8)
	12:17	94 - Room 211 Right Bench SE Sink Faucet	1			1									Lead (DW 200.8)
	12:17	95 - Room 211 Right Bench NE Sink Faucet	1			1									Lead (DW 200.8)
	12:17	96 - Room 211 Right Bench SW Sink Faucet	1			1									Lead (DW 200.8)
	12:17	97 - Room 211 Right Bench NW Sink Faucet	1			1									Lead (DW 200.8)
	12:20	98 - Room 214 Instructor's Sink Faucet	1			1									Lead (DW 200.8)
	12:21	99 - Room 214 East Wall Left Sink Faucet	1			1									Lead (DW 200.8)
	12:23	100 - Room 212 Instructor's Sink Faucet	1			1									Lead (DW 200.8)
	12:26	101 - Room 212 E. Wall Left Bench NW Sink Faucet	1			1									Lead (DW 200.8)
	12:27	102 - Room 212 E. Wall Left Bench SW Sink Faucet	1			1									Lead (DW 200.8)
	12:27	103 - Room 212 E. Wall Left Bench NE Sink Faucet	1			1									Lead (DW 200.8)
	12:27	104 - Room 212 E. Wall Left Bench SE Sink Faucet	1			1									Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE) *Debra Bayer* DATE: 10/31/16 TIME: 0935  
 COMPANY: *Ulster Bores*  
 RECEIVED BY: (SIGNATURE) \_\_\_\_\_ DATE: 10/29/16 TIME: 1304  
 COMPANY: *Ulster Bores*  
 RECEIVED BY: (SIGNATURE) \_\_\_\_\_ DATE: \_\_\_\_\_ TIME: \_\_\_\_\_  
 COMPANY: \_\_\_\_\_

RECEIVED FOR LABORATORY BY: (SIGNATURE) *AS Moore* DATE: 10/31/16 TIME: 0935  
 CUSTODY INTACT: YES/NO  
 COOLER TEMP (C): 17.7  
 LABORATORY REMARKS: ICE (Y/N) pH 7.4 CL2 Reversed by *12/3*



EnviroTest Laboratories  
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE: New Paltz CSD - High School  
 ENVROTEST PROJECT MANAGER: Debra Bayer  
 CLIENT (SITE) PM: S. Callahan - results to morourke@ulsterbocecs.org  
 CLIENT NAME: New Paltz Central School District  
 CLIENT ADDRESS: 196 Main Street, New Paltz, NY 12561  
 COMPANY CONTRACTING THIS WORK (if applicable):

DATE	TIME	SAMPLE IDENTIFICATION	REQUIRED ANALYSES										REMARKS	
			40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other		
10/29/2016	12:27	105 - Room 212 E. Wall Center Bench NW Sink Faucet	1		1									Lead (DW 200.8)
	12:28	106 - Room 212 E. Wall Center Bench SW Sink Faucet	1		1									Lead (DW 200.8)
	12:28	107 - Room 212 E. Wall Center Bench NE Sink Faucet	1		1									Lead (DW 200.8)
	12:28	108 - Room 212 E. Wall Center Bench SE Sink Faucet	1		1									Lead (DW 200.8)
	12:29	109 - Room 212 E. Wall Right Bench NW Sink Faucet	1		1									Lead (DW 200.8)
	12:29	110 - Room 212 E. Wall Right Bench SW Sink Faucet	1		1									Lead (DW 200.8)
	12:29	111 - Room 212 E. Wall Right Bench NE Sink Faucet	1		1									Lead (DW 200.8)
	12:29	112 - Room 212 E. Wall Right Bench SE Sink Faucet	1		1									Lead (DW 200.8)
	12:30	113 - Room 212 W. Wall Left Bench SW Sink Faucet	1		1									Lead (DW 200.8)
	12:30	114 - Room 212 W. Wall Left Bench NW Sink Faucet	1		1									Lead (DW 200.8)
	12:31	115 - Room 212 W. Wall Center Bench SE Sink Faucet	1		1									Lead (DW 200.8)
	12:31	116 - Room 212 W. Wall Center Bench NE Sink Faucet	1		1									Lead (DW 200.8)
	12:31	117 - Room 212 W. Wall Center Bench SW Sink Faucet	1		1									Lead (DW 200.8)

RECEIVED BY: (SIGNATURE) *[Signature]* DATE 10/31/16 TIME 09:35  
 COMPANY: Ulster Boces  
 SAMPLED BY: (SIGNATURE) *[Signature]* DATE 10/31/16 TIME 13:04  
 COMPANY: Ulster Boces  
 RECEIVED BY: (SIGNATURE) \_\_\_\_\_ DATE \_\_\_\_\_ TIME \_\_\_\_\_  
 RECEIVED BY: (SIGNATURE) \_\_\_\_\_ DATE \_\_\_\_\_ TIME \_\_\_\_\_  
 RECEIVED BY: (SIGNATURE) \_\_\_\_\_ DATE \_\_\_\_\_ TIME \_\_\_\_\_

LABORATORY REMARKS: ICE (Y\_N) pH \_\_\_\_\_ CL2 \_\_\_\_\_ Reviewed by: *[Signature]*  
 CUSTODY INTACT: YES [ ] NO [ ]  
 DATE: 10/31/16 TIME: 09:35  
 COOLER TEMP (C): 17.7  
 RECEIVED FOR LABORATORY BY: (SIGNATURE) *[Signature]*

Lab Name: **EnviroTest Laboratories**  
 Address & Phone: **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

PROJECT REFERENCE New Paltz CSD - High School		PROJECT NO.	PROJECT LOCATION NPHS	MATRIX TYPE	REQUIRED ANALYSES					PAGE 1 of 10			
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN	OTHER Specify	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other
CLIENT (SITE) PM S. Callahan - results to morourke@ulsterbores.org	CLIENT PHONE 845-256-4090	CLIENT FAX		D (Drinking Water) or W (Waste Water) Indicate									
CLIENT NAME New Paltz Central School District				AQUEOUS (WATER)									
CLIENT ADDRESS 196 Main Street, New Paltz, NY 12561				COMPOSITE (C) OR GRAB (G) INDICATE									
COMPANY CONTRACTING THIS WORK (if applicable):													
SAMPLE DATE		TIME		SAMPLE IDENTIFICATION		NUMBER OF CONTAINERS SUBMITTED		# OF COOLERS		REMARKS			
10/29/2016	12:31	118 - Room 212 W. Wall Center Bench NW Sink Faucet		1	1					Lead (DW 200.8)			
	12:33	119 - Room 212 W. Wall Right Bench SE Sink Faucet		1	1					Lead (DW 200.8)			
	12:33	120 - Room 212 W. Wall Right Bench NE Sink Faucet		1	1					Lead (DW 200.8)			
	12:33	121 - Room 212 W. Wall Right Bench SW Sink Faucet		1	1					Lead (DW 200.8)			
	12:33	122 - Room 212 W. Wall Right Benchy NW Sink Faucet		1	1					Lead (DW 200.8)			
	12:35	123 - Room 211A Prep Room Sink Faucet		1	1					Lead (DW 200.8)			
	12:36	124 - Room 209 Instructor's Sink Faucet		1	1					Lead (DW 200.8)			
	12:38	125 - Room 209 W. Wall Left Bench SE Sink Faucet		1	1					Lead (DW 200.8)			
	12:38	126 - Room 209 W. Wall Left Bench NE Sink Faucet		1	1					Lead (DW 200.8)			
	12:38	127 - Room 209 W. Wall Left Bench SW Sink Faucet		1	1					Lead (DW 200.8)			
	12:38	128 - Room 209 W. Wall Left Bench NW Sink Faucet		1	1					Lead (DW 200.8)			
	12:39	129 - Room 209 W. Wall Center Bench SE Sink Faucet		1	1					Lead (DW 200.8)			
	12:39	130 - Room 209 W. Wall Center Bench NE Sink Faucet		1	1					Lead (DW 200.8)			
RELINQUISHED BY: (SIGNATURE) <i>Bevan Conner</i>	COMPANY Wister Bores	DATE 10/31/16	TIME 0935	RECEIVED BY: (SIGNATURE)	COMPDATE	TIME							
SAMPLED BY: (SIGNATURE) <i>Bevan Conner</i>	COMPANY Wister Bores	DATE 10/29/16	TIME 1304	RECEIVED BY: (SIGNATURE)	COMPDATE	TIME							
RELINQUISHED BY: (SIGNATURE) <i>Debra Bayer</i>	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPDATE	TIME							

RECEIVED FOR LABORATORY BY: (SIGNATURE) <i>Debra Bayer</i>	DATE 10/31/16	TIME 0935	CUSTODY INTACT YES NO	Cooler Temp (C): 17.7	LABORATORY REMARKS: <i>Ratz</i>
ICE (Y_N) pH ____ Cl2 ____		Revised by: _____			

112577

Lab Name: EnviroTest Laboratories  
 Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE New Paltz CSD - High School		PROJECT NO.	PROJECT LOCATION NPHS	MATRIX TYPE	REQUIRED ANALYSES						PAGE 1 of 11
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN	OTHER Specify	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Turnaround Time
CLIENT (SITE) PM S. Callahan - results to morourke@uisterboeces.org		CLIENT PHONE 845-256-4090	CLIENT FAX	D (Drinking Water) or W (Waste Water) Indicate	Total # of Containers	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	Terra Core	NORMAL
CLIENT NAME New Paltz Central School District				AQUEOUS (WATER)	NUMBER OF CONTAINERS SUBMITTED	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	Terra Core	QUICK
CLIENT ADDRESS 196 Main Street, New Paltz, NY 12561				COMPOSITE (C) OR GRAB (G) INDICATE		Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	Terra Core	VERBAL
COMPANY CONTRACTING THIS WORK (if applicable):						Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	Terra Core	#OF COOLERS
SAMPLE IDENTIFICATION						Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	Terra Core	REMARKS
DATE	TIME	SAMPLE IDENTIFICATION				Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	Terra Core	
10/29/2016	12:39	131 - Room 209 W. Wall Center Bench SW Sink Faucet				Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	Terra Core	Lead (DW 200.8)
	12:39	132 - Room 209 W. Wall Center Bench NW Sink Faucet				Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	Terra Core	Lead (DW 200.8)
	12:40	133 - Room 209 W. Wall Right Bench SE Sink Faucet				Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	Terra Core	Lead (DW 200.8)
	12:40	134 - Room 209 W. Wall Right Bench NE Sink Faucet				Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	Terra Core	Lead (DW 200.8)
	12:40	135 - Room 209 W. Wall Right Bench SW Sink Faucet				Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	Terra Core	Lead (DW 200.8)
	12:40	136 - Room 209 W. Wall Right Bench NW Sink Faucet				Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	Terra Core	Lead (DW 200.8)
	12:41	137 - Room 209 E. Wall Left Bench SW Sink Faucet				Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	Terra Core	Lead (DW 200.8)
	12:41	138 - Room 209 E. Wall Left Bench NE Sink Faucet				Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	Terra Core	Lead (DW 200.8)
	12:41	139 - Room 209 E. Wall Left Bench SE Sink Faucet				Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	Terra Core	Lead (DW 200.8)
	12:43	140 - Room 209 E. Wall Center Bench NW Sink Faucet				Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	Terra Core	Lead (DW 200.8)
	12:43	141 - Room 209 E. Wall Center Bench SW Sink Faucet				Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	Terra Core	Lead (DW 200.8)
	12:43	142 - Room 209 E. Wall Center Bench NE Sink Faucet				Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	Terra Core	Lead (DW 200.8)
	12:43	143 - Room 209 E. Wall Center Bench SE Sink Faucet				Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	Terra Core	Lead (DW 200.8)
RELINQUISHED BY: (SIGNATURE) <i>Debra Bayer</i>		COMPANY Uister Boeces	DATE 10/29/16	TIME 0935	RECEIVED BY: (SIGNATURE)		COMP/DATE	RECEIVED BY: (SIGNATURE)		COMP/DATE	TIME
SAMPLED BY: (SIGNATURE) <i>Debra Bayer</i>		COMPANY Uister Boeces	DATE 10/29/16	TIME 1304	RECEIVED BY: (SIGNATURE)		COMP/DATE	RECEIVED BY: (SIGNATURE)		COMP/DATE	TIME
RELINQUISHED BY: (SIGNATURE)		COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)		COMP/DATE	RECEIVED BY: (SIGNATURE)		COMP/DATE	TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE) *[Signature]*

DATE: 10/29/16 TIME: 0935

CUSTOMER INTACT: YES [ ] NO [ ]

COOLER TEMP (C): 17.7

LABORATORY REMARKS: ICE (Y/N) pH CL2 Revisited by: *[Signature]*





**CHAIN OF CUSTODY**

REPORT# (Lab Use Only)

112577

EnviroTest Laboratories  
 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

Lab Name  
 Address & Phone

PROJECT REFERENCE New Paltz CSD - High School	PROJECT NO.	PROJECT LOCATION NPHS	MATRIX TYPE	REQUIRED ANALYSES	PAGE 1 of 13
ENVIROTEST PROJECT MANAGER Debra Bayer	P.O. NUMBER	TOWN	OTHER SPECIFY	40ml Vials HCl	TURNAROUND TIME
CLIENT (SITE) PM S. Callahan - results to morourke@ulsterbooces.org	CLIENT PHONE 845-256-4090	CLIENT FAX	OTHER SPECIFY	Liter Amber HCl	NORMAL
CLIENT NAME New Paltz Central School District			OTHER SPECIFY	Liter Plastic	QUICK
CLIENT ADDRESS 196 Main Street, New Paltz, NY 12561			OTHER SPECIFY	250ml Plastic Sulfuric Acid	VERBAL
COMPANY CONTRACTING THIS WORK (if applicable)			OTHER SPECIFY	250ml Plastic Nitric Acid	

SAMPLE DATE	TIME	SAMPLE IDENTIFICATION	NUMBER OF CONTAINERS SUBMITTED								REMARKS	
			Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core		Other
10/29/2016	12:57	157 - Room 131 S. Wall Right Sink Faucet	1									Lead (DW 200.8)
	12:58	158 - Room 232 Sink Faucet	1									Lead (DW 200.8)
	12:59	159 - Room 233 Sink Faucet	1									Lead (DW 200.8)
	1:01	160 - Lower Water Fountain Near Room 242	1									Lead (DW 200.8)
	1:02	161 - Room 246M Sink Faucet	1									Lead (DW 200.8)
	1:03	162 - Room 248W Sink Faucet	1									Lead (DW 200.8)
	1:03	163 - Room 252M Sink Faucet	1									Lead (DW 200.8)
	1:04	164 - Room 245W Sink Faucet	1									Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE) <i>Brian Chambers</i>	COMPANY Ulster Booces	DATE 10/31/16	TIME 0935
SAMPLED BY: (SIGNATURE) <i>Brian Chambers</i>	COMPANY Ulster Booces	DATE 10/29/16	TIME 1304
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE) <i>J. H. Rose</i>	DATE 10/31/16	TIME 0935	CUSTODY INTACT YES NO	COOLER TEMP (C): 17.7	LABORATORY REMARKS: ICE (Y/N) pH CL2	RECEIVED BY:
--------------------------------------------------------------	------------------	--------------	-----------------------------	--------------------------	-----------------------------------------	--------------

## LOGIN SAMPLE RECEIPT CHECK LIST

Client: Ulster BOCES

Job Number: 420-112577-1  
SDG Number: New Paltz CSD - High School

**Login Number: 112577**

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	17.7 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	

# **APPENDIX B**

## Caution Signage

**CAUTION: NONPOTABLE WATER – DO NOT DRINK**



**CAUTION: NONPOTABLE WATER – DO NOT DRINK**



# CAUTION



NON-POTABLE  
WATER  
DO NOT DRINK