



#112-1617

HEALTH, SAFETY & RISK MANAGEMENT
 Michael O'Rourke
 Program Administrator

175 Route 32 North • New Paltz, NY 12561
 Telephone: 845-255-1400 • Facsimile: 845-255-3826
 Email: morourke@ulsterboces.org



Environmental Hygiene Report

Attn: Maria C. Rice
 Superintendent of Schools
 New Paltz Central School District
 196 Main Street, New Paltz, NY 12561
 Prepared by: Michael O'Rourke, RPIH – No. 0500399

Location(s)	Middle School
Project No.	112-1617
Site Visit(s)	October 15, 2016
Report Date	December 8, 2016
Investigator(s)	Michael O'Rourke

Ulster County BOCES Health, Safety & Risk Management does not assert that all potential health or safety hazards at this site were evaluated during this survey. This survey is strictly limited to that which is identified in the Project Scope of the report.

BRINGING ULSTER COUNTY SCHOOLS TOGETHER TO ENHANCE TEACHING & LEARNING

Ellenville Central Schools • Highland Central Schools • Kingston City Schools • New Paltz Central Schools •
 Onteora Central Schools • Rondout Valley Central Schools • Saugerties Central Schools • Walkkill Central Schools

TABLE OF CONTENTS

Executive Summary	1
Project Scope	1
Materials & Methods	1
Results Summary	2
Discussion	3
Comments & Recommendations	4
References	4
Appendix A	Laboratory Report(s)
Appendix B	Caution Signage

Author's Note: Parenthetical numerals at the end of a sentence reference the work with the corresponding notation in the **References** section. *Please read this report in its entirety, including any attached appendices, to fully understand this investigation.*

Executive Summary

Per the requirements of Subpart 67-4: Lead Testing in School Drinking Water, we sampled water outlets in the New Paltz Central School District's Middle School on October 22, 2016. The regulation defines a water outlet as one that is currently or may potentially be used for cooking or drinking. We identified a total of 135 such water outlets in the middle school. There were 7 other locations sampled at the middle school using the DOH's protocol prior to the enactment of the law. Of these 142 locations, 56 exceeded the 15 parts per billion (ppb) action level. Per 67-4.4, these outlets must be taken out of service until remediation and re-testing indicate that the lead levels are at or below the action level. If a location, like a toilet room sink, is needed for hygiene purposes signage can be posted (see **Appendix B**) instructing building occupants this water is not intended for drinking purposes. Please note that this is a short-term solution only. We are still awaiting the official guidance from the state, but it is anticipated that lab fixtures that exceeded the action level will not have to be replaced so long as certain conditions are met.

Project Scope

Identify appropriate potable water sampling locations and collect samples from these locations at New Paltz Middle School for analysis for lead content. Review the data and information and prepare a written report for the New Paltz Central School District.

Materials & Methods

All samples were collected from the type of plumbing fixtures where potable water is commonly drawn using the NYSDOH protocol. First-draw samples for lead were collected after

the water had sat in the pipes for at least eight hours. All samples were collected in 250 ml containers provided by EnviroTest Laboratories in Newburgh, NY. The samples were returned to the laboratory two days after sampling for analysis per the lab's directives. EnviroTest is NYS ELAP-approved (#10142) for potable and non-potable water analysis.

Results Summary

All sample results and other data were reported to the administration of the local educational agency (LEA) via phone, fax, or e-mail as they became available to our department. **See Appendix A for full laboratory reports.**

Water Samples that Exceeded Action Level

October 22, 2016

New Paltz Middle School

Sample	Location	Result (ppb)
06	Room 5C TR Sink Faucet	16
07	Room 6 Sink Faucet	350
08	Room 6 TR Sink Faucet	110
13	Room 1 Sink Faucet	13
14	Room 1 Bubbler	16
22	Boy's Locker Room Left Sink Faucet	19
37	Men's TR Near Gym Left Sink Faucet	24
38	Men's TR Near Gym Right Sink Faucet	24
40	Women's TR Near Gym Right Sink Faucet	21
45	Room 25 Sink Faucet	38
59	Room 36 TR Sink Faucet	290
69	Room 42 Left Sink Faucet	46
70	Room 42 Center Sink Faucet	19
71	Room 42 Right Sink Faucet	16
77	Room 30 Sink Faucet	37
79	Room 31 Octagonal #1 SW Sink Faucet	19
81	Room 31 Octagonal #1 NE Sink Faucet	22
83	Room 31 Octagonal #2 SW Sink Faucet	21
86	Room 31 Octagonal #2 SE Sink Faucet	17
87	Room 31 Octagonal #3 SW Sink Faucet	32
88	Room 31 Octagonal #3 NW Sink Faucet	16
89	Room 31 Octagonal #3 NE Sink Faucet	31
91	Room 31 Octagonal #4 SW Sink Faucet	22
92	Room 31 Octagonal #4 NW Sink Faucet	32
93	Room 31 Octagonal #4 NE Sink Faucet	19
95	Room 31 Octagonal #5 SW Sink Faucet	16

96	Room 31 Octagonal #5 NW Sink Faucet	17
97	Room 31 Octagonal #5 NE Sink Faucet	16
99	Room 31 Octagonal #6 SW Sink Faucet	23
101	Room 31 Octagonal #6 NE Sink Faucet	19
103	Room 31 Octagonal #7 SW Sink Faucet	73
105	Room 31 Octagonal #7 NE Sink Faucet	22
106	Rom 31 Octagonal #7 SE Sink Faucet	38
108	Room 31/32 Prep Room Sink Faucet	160
109	Room 33 Octagonal #1 SW Sink Faucet	42
110	Room 33 Octagonal #1 NW Sink Faucet	23
111	Room 33 Octagonal #1 NE Sink Faucet	31
113	Room 33 Octagonal #2 SW Sink Faucet	48
114	Room Octagonal #2 NW Sink Faucet	26
115	Room 33 Octagonal #2 NE Sink Faucet	33
116	Room 33 Octagonal #2 SE Sink Faucet	20
117	Room 33 Octagonal #3 SW Sink Faucet	57
119	Room 33 Octagonal #3 SE Sink Faucet	31
120	Room 33 Octagonal #3 SE Sink Faucet	17
121	Room 33 Octagonal #4 SW Sink Faucet	230
122	Room 33 Octagonal #4 NW Sink Faucet	18
123	Room 33 Octagonal #4 NE Sink Faucet	71
125	Room 33 Octagonal #5 SW Sink Faucet	41
126	Room 33 Octagonal #5 NW Sink Faucet	21
127	Room 33 Octagonal #5 NE Sink Faucet	21
128	Room 33 Octagonal #5 SE Sink Faucet	21
129	Room 33 Octagonal #6 SW Sink Faucet	72
131	Room 33 Octagonal #6 NE Sink Faucet	170
134	Loading Dock Hose Bib	19
135	East Side Hose Bib	95
138	Principal's TR Sink Faucet	210

Discussion

In order to be used as healthful fluid for human consumption, water must be free from organisms that are capable of causing disease and from minerals and organic substances that could produce adverse physiological effects. (1) The Safe Drinking Water Act sets maximum contaminant levels (MCLs) for numerous contaminants. These include various inorganic, volatile organic, and synthetic organic compounds. Public water systems are required to do initial and periodic testing of their source water.

Comments & Recommendations

Per the requirements of Subpart 67-4: Lead Testing in School Drinking Water, we sampled water outlets in the New Paltz Central School District's Middle School on October 22, 2016. This was nine days prior to the 10/31/16 deadline for Grade 6-12 schools. The regulation defines a water outlet as one that is currently or may potentially be used for cooking or drinking. We identified a total of 135 such water outlets in the middle school. There were 7 other locations sampled at the middle school using the DOH's protocol prior to the enactment of the law. Of these 142 locations, 56 exceeded the 15 parts per billion (ppb) action level. Per 67-4.4, these outlets must be taken out of service until remediation and re-testing indicate that the lead levels are at or below the action level. If a location, like a toilet room sink, is needed for hygiene purposes signage can be posted (see **Appendix B**) instructing building occupants this water is not intended for drinking purposes. Please note that this is a short-term solution only. More than 50% of the locations that exceeded 15 ppb were laboratory sink. We are still awaiting the official guidance from the state, but it is anticipated that lab fixtures that exceeded the action level will not have to be replaced so long as certain conditions are met.

References

1. **American Water Works Association:** *Water Quality and Treatment*. New York, NY: McGraw-Hill, 1990
2. **Bailey, R.A. et. al.:** *Chemistry of the Environment*. New York, NY: Academic Press, 1978.
3. **USEPA:** *3Ts for Reducing Lead in Drinking Water in Schools*. Washington, DC: USEPA, 2006.

APPENDIX A

Laboratory Reports

ANALYTICAL REPORT

Job Number: 420-112525-1

SDG Number: New Paltz CSD - Middle School

Job Description: Ulster BOCES

For:

Ulster BOCES

175 Roue 32 North

New Paltz, NY 12561

Attention: Michael O'Rourke



Meredith W Ruthven

Customer Service Manager

mruthven@envirotestlaboratories.com

12/08/2016

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories Inc. certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative.

EnviroTest Laboratories, Inc. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

METHOD SUMMARY

Client: Ulster BOCES

Job Number: 420-112525-1
SDG Number: New Paltz CSD - Middle School

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Ulster BOCES

Job Number: 420-112525-1
SDG Number: New Paltz CSD - Middle School

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Sirico, Derek	DS

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-112525-1
SDG Number: New Paltz CSD - Middle School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112525-1	01- Room 10 Sink Faucet	Drinking Water	10/22/2016 0747	10/31/2016 0935
420-112525-2	02- Room 7 Sink Faucet	Drinking Water	10/22/2016 0749	10/31/2016 0935
420-112525-3	03- Room 9 Sink Faucet	Drinking Water	10/22/2016 0750	10/31/2016 0935
420-112525-4	04- Room 8 Sink Faucet	Drinking Water	10/22/2016 0751	10/31/2016 0935
420-112525-5	05- Room 5C Sink Faucet	Drinking Water	10/22/2016 0754	10/31/2016 0935
420-112525-6	06- Room 5C TR Sink Faucet	Drinking Water	10/22/2016 0754	10/31/2016 0935
420-112525-7	07- Room 6 Sink Faucet	Drinking Water	10/22/2016 0757	10/31/2016 0935
420-112525-8	08- Room 6 TR Sink Faucet	Drinking Water	10/22/2016 0759	10/31/2016 0935
420-112525-9	09- Room 3 TR Sink Faucet	Drinking Water	10/22/2016 0803	10/31/2016 0935
420-112525-10	10- Room 4 Sink Faucet	Drinking Water	10/22/2016 0804	10/31/2016 0935
420-112525-11	11- Room 4 Bubbler	Drinking Water	10/22/2016 0806	10/31/2016 0935
420-112525-12	12- Room 4 TR Sink Faucet	Drinking Water	10/22/2016 0808	10/31/2016 0935
420-112525-13	13- Room 1 Sink Faucet	Drinking Water	10/22/2016 0811	10/31/2016 0935
420-112525-14	14- Room 1 Bubbler	Drinking Water	10/22/2016 0812	10/31/2016 0935
420-112525-15	15- Room 1 TR Sink Faucet	Drinking Water	10/22/2016 0813	10/31/2016 0935
420-112525-16	16- Room 2 Sink Faucet	Drinking Water	10/22/2016 0814	10/31/2016 0935
420-112525-17	17- Room 2 Bubbler	Drinking Water	10/22/2016 0815	10/31/2016 0935
420-112525-18	18- Room 2 TR Sink Faucet	Drinking Water	10/22/2016 0816	10/31/2016 0935
420-112525-19	19- Faculty Room Sink Faucet	Drinking Water	10/22/2016 0819	10/31/2016 0935
420-112525-20	20- Women's TR Sink Faucet near cafeteria	Drinking Water	10/22/2016 0823	10/31/2016 0935
420-112525-21	21- Men's TR Sink Faucet near cafeteria	Drinking Water	10/22/2016 0824	10/31/2016 0935
420-112525-22	22- Boy's Locker room Left Sink Faucet	Drinking Water	10/22/2016 0826	10/31/2016 0935
420-112525-23	23- Boy's Locker room Right Sink Faucet	Drinking Water	10/22/2016 0828	10/31/2016 0935
420-112525-24	24- Boy's Locker room Water Fountain	Drinking Water	10/22/2016 0830	10/31/2016 0935
420-112525-25	25- Girl's PE Coach's TR Sink Faucet	Drinking Water	10/22/2016 0834	10/31/2016 0935
420-112525-26	26- Girl's Locker room left Sink Faucet	Drinking Water	10/22/2016 0836	10/31/2016 0935
420-112525-27	27- Girl's Locker Room Right Sink Faucet	Drinking Water	10/22/2016 0837	10/31/2016 0935
420-112525-28	28- Girl's Locker Room water fountain	Drinking Water	10/22/2016 0838	10/31/2016 0935
420-112525-29	29- Kitchen W. Wall 1-Bay Sink Faucet	Drinking Water	10/22/2016 0845	10/31/2016 0935
420-112525-30	30- Kitchen W.Wall Groen Pot filler	Drinking Water	10/22/2016 0847	10/31/2016 0935
420-112525-31	31- Kitchen W. Wall Kettle Sprayer	Drinking Water	10/22/2016 0849	10/31/2016 0935
420-112525-32	32- Kitchen Center 1-Bay Sink Faucet	Drinking Water	10/22/2016 0851	10/31/2016 0935

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-112525-1
SDG Number: New Paltz CSD - Middle School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112525-33	33- Kitchen S. Side 1-Bay Sink Faucet	Drinking Water	10/22/2016 0853	10/31/2016 0935
420-112525-34	34- Kitchen Dish Room 1-Bay Sink Faucet	Drinking Water	10/22/2016 0854	10/31/2016 0935
420-112525-35	35- Kitchen TR Sink Faucet	Drinking Water	10/22/2016 0855	10/31/2016 0935
420-112525-36	36- Boiler Room TR Sink Faucet	Drinking Water	10/22/2016 0900	10/31/2016 0935
420-112525-37	37- Men's TR Near Gym Left Sink Faucet	Drinking Water	10/22/2016 0906	10/31/2016 0935
420-112525-38	38- Men's TR near Gym Right Sink Faucet	Drinking Water	10/22/2016 0906	10/31/2016 0935
420-112525-39	39- Women's TR near Gym Left Sink Faucet	Drinking Water	10/22/2016 0914	10/31/2016 0935
420-112525-40	40- Women's TR Near Gym Right Sink Faucet	Drinking Water	10/22/2016 0915	10/31/2016 0935
420-112525-41	41- Room 21 Sink Faucet	Drinking Water	10/22/2016 0927	10/31/2016 0935
420-112525-42	42- Room 22 Sink Faucet	Drinking Water	10/22/2016 0929	10/31/2016 0935
420-112525-43	43- Room 23 Sink Faucet	Drinking Water	10/22/2016 0930	10/31/2016 0935
420-112525-44	44- Room 24 Sink Faucet	Drinking Water	10/22/2016 0931	10/31/2016 0935
420-112525-45	45- Room 25 Sink Faucet	Drinking Water	10/22/2016 0933	10/31/2016 0935
420-112525-46	46- Girl's TR Near Room 25 Left Sink Faucet	Drinking Water	10/22/2016 0935	10/31/2016 0935
420-112525-47	47- Girl's TR Near Room 25 Center Sink Sink Faucet	Drinking Water	10/22/2016 0935	10/31/2016 0935
420-112525-48	48- Girl's TR Near Room 25 Right Sink Faucet	Drinking Water	10/22/2016 0935	10/31/2016 0935
420-112525-49	49- Boy's TR Near Room 25 Left Sink Faucet	Drinking Water	10/22/2016 0939	10/31/2016 0935
420-112525-50	50- Boy's TR Near room 25 center Sink Faucet	Drinking Water	10/22/2016 0939	10/31/2016 0935
420-112525-51	51- Boy's TR Near room 25 right Sink Faucet	Drinking Water	10/22/2016 0939	10/31/2016 0935
420-112525-52	52- TR Across from main office Sink Faucet	Drinking Water	10/22/2016 0955	10/31/2016 0935
420-112525-53	53- Room 36 Left Sink Faucet left Sink	Drinking Water	10/22/2016 0957	10/31/2016 0935
420-112525-54	54- Room 36 Center Sink Faucet left sink	Drinking Water	10/22/2016 0957	10/31/2016 0935
420-112525-55	55- Room 36 right Sink Faucet left sink	Drinking Water	10/22/2016 0957	10/31/2016 0935
420-112525-56	56- Room 36 left Sink Faucet right sink Room 36 center Sink Faucet right sink	Drinking Water	10/22/2016 1001	10/31/2016 0935
420-112525-57	57- Room 36 center Sink Faucet right sink	Drinking Water	10/22/2016 1002	10/31/2016 0935
420-112525-58	58- Room 36 Right Sink Faucet right sink	Drinking Water	10/22/2016 1003	10/31/2016 0935
420-112525-59	59- Room 36 TR Sink Faucet	Drinking Water	10/22/2016 1006	10/31/2016 0935
420-112525-60	60- Room 37 Sink Faucet	Drinking Water	10/22/2016 1010	10/31/2016 0935
420-112525-61	61- Boy's TR across from 38 left Sink Faucet	Drinking Water	10/22/2016 1012	10/31/2016 0935

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-112525-1
SDG Number: New Paltz CSD - Middle School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112525-62	62- Boy's TR across from room 38 Right Sink Faucet	Drinking Water	10/22/2016 1012	10/31/2016 0935
420-112525-63	63- Girl's TR near room 34 left Sink Faucet	Drinking Water	10/22/2016 1016	10/31/2016 0935
420-112525-64	64- Girl's TR near Room 34 Center Sink Faucet	Drinking Water	10/22/2016 1016	10/31/2016 0935
420-112525-65	65- Girl's TR near Room 34 Right Sink Faucet	Drinking Water	10/22/2016 1016	10/31/2016 0935
420-112525-66	66- Room 27 Left Sink Faucet	Drinking Water	10/22/2016 1021	10/31/2016 0935
420-112525-67	67- Room 27 Right Sink Faucet	Drinking Water	10/22/2016 1022	10/31/2016 0935
420-112525-68	68- Room 28 Sink Faucet	Drinking Water	10/22/2016 1026	10/31/2016 0935
420-112525-69	69- Room 42 Faucet Left Sink	Drinking Water	10/22/2016 1041	10/31/2016 0935
420-112525-70	70- Room 42 Faucet Center Sink	Drinking Water	10/22/2016 1042	10/31/2016 0935
420-112525-71	71- Room 42 Faucet Right Sink	Drinking Water	10/22/2016 1042	10/31/2016 0935
420-112525-72	72- Girl's TR near Room 40 Left Sink Faucet	Drinking Water	10/22/2016 1049	10/31/2016 0935
420-112525-73	73- Girl's TR near Room 40 Center Sink Faucet	Drinking Water	10/22/2016 1049	10/31/2016 0935
420-112525-74	74- Girl's TR near Room 40 Right Sink Faucet	Drinking Water	10/22/2016 1050	10/31/2016 0935
420-112525-75	75- Boy's TR Adjacent Room 45 Left Sink Faucet	Drinking Water	10/22/2016 1054	10/31/2016 0935
420-112525-76	76- Boy's TR Adjacent Room 45 Right Sink Faucet	Drinking Water	10/22/2016 1054	10/31/2016 0935
420-112525-77	77- Room 30 Sink Faucet	Drinking Water	10/22/2016 1115	10/31/2016 0935
420-112525-78	78- Room 31 Utility Sink Faucet	Drinking Water	10/22/2016 1117	10/31/2016 0935
420-112525-79	79- Room 31 Octagonal #1 SW Sink Faucet	Drinking Water	10/22/2016 1120	10/31/2016 0935
420-112525-80	80- Room 31 Octagonal #1 NW Sink Faucet	Drinking Water	10/22/2016 1120	10/31/2016 0935
420-112525-81	81- Room 31 Octagonal #1 NE Sink Faucet	Drinking Water	10/22/2016 1120	10/31/2016 0935
420-112525-82	82- Room 31 Octagonal #1 SE Sink Faucet	Drinking Water	10/22/2016 1120	10/31/2016 0935
420-112525-83	83- Room 31 Octagonal #2 SW Sink Faucet	Drinking Water	10/22/2016 1123	10/31/2016 0935
420-112525-84	84- Room 31 Octagonal #2 NW Sink Faucet	Drinking Water	10/22/2016 1123	10/31/2016 0935
420-112525-85	85- Room 31 Octagonal #2 NE Sink Faucet	Drinking Water	10/22/2016 1123	10/31/2016 0935
420-112525-86	86- Room 31 Octagonal #2 SE Sink Faucet	Drinking Water	10/22/2016 1123	10/31/2016 0935
420-112525-87	87- Room 31 Octagonal #3 SW Sink Faucet	Drinking Water	10/22/2016 1126	10/31/2016 0935
420-112525-88	88- Room 31 Octagonal #3 NW Sink Faucet	Drinking Water	10/22/2016 1126	10/31/2016 0935
420-112525-89	89- Room 31 Octagonal #3 NE Sink Faucet	Drinking Water	10/22/2016 1126	10/31/2016 0935

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-112525-1
SDG Number: New Paltz CSD - Middle School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112525-90	90- Room 31 Octogonal #3 SE Sink Faucet	Drinking Water	10/22/2016 1126	10/31/2016 0935
420-112525-91	91- Room 31 Octogonal #4 SW Sink Faucet	Drinking Water	10/22/2016 1130	10/31/2016 0935
420-112525-92	92- Room 31 Octogonal #4 NW Sink Faucet	Drinking Water	10/22/2016 1130	10/31/2016 0935
420-112525-93	93- Room 31 Octogonal #4 NE Sink Faucet	Drinking Water	10/22/2016 1130	10/31/2016 0935
420-112525-94	94- Room 31 Octogonal #4 SE Sink Faucet	Drinking Water	10/22/2016 1130	10/31/2016 0935
420-112525-95	95- Room 31 Octogonal #5 SW Sink Faucet	Drinking Water	10/22/2016 1133	10/31/2016 0935
420-112525-96	96- Room 31 Octogonal #5 NW Sink Faucet	Drinking Water	10/22/2016 1133	10/31/2016 0935
420-112525-97	97- Room 31 Octogonal #5 NE Sink Faucet	Drinking Water	10/22/2016 1133	10/31/2016 0935
420-112525-98	98- Room 31 Octogonal #5 SE Sink Faucet	Drinking Water	10/22/2016 1133	10/31/2016 0935
420-112525-99	99- Room 31 Octogonal #6 SW Sink Faucet	Drinking Water	10/22/2016 1135	10/31/2016 0935
420-112525-100	100- Room 31 Octogonal #6 NW Sink Faucet	Drinking Water	10/22/2016 1135	10/31/2016 0935
420-112525-101	101- Room 31 Octogonal #6 NE Sink Faucet	Drinking Water	10/22/2016 1137	10/31/2016 0935
420-112525-102	102- Room 31 Octogonal #6 SE Sink Faucet	Drinking Water	10/22/2016 1137	10/31/2016 0935
420-112525-103	103- Room 31 Octogonal #7 SW Sink Faucet	Drinking Water	10/22/2016 1141	10/31/2016 0935
420-112525-104	104- Room 31 Octogonal #7 NW Sink Faucet	Drinking Water	10/22/2016 1141	10/31/2016 0935
420-112525-105	105- Room 31 Octogonal #7 NE Sink Faucet	Drinking Water	10/22/2016 1141	10/31/2016 0935
420-112525-106	106- Room 31 Octogonal #7 SE Sink Faucet	Drinking Water	10/22/2016 1141	10/31/2016 0935
420-112525-107	107- Room 31 Insturctor's Sink Faucet	Drinking Water	10/22/2016 1143	10/31/2016 0935
420-112525-108	108- Room 31/32 Prep Room Sink Faucet	Drinking Water	10/22/2016 1144	10/31/2016 0935
420-112525-109	109- Room 33 Octogonal #1 SW Sink Faucet	Drinking Water	10/22/2016 1146	10/31/2016 0935
420-112525-110	110- Room 33 Octogonal #1 NW Sink Faucet	Drinking Water	10/22/2016 1146	10/31/2016 0935
420-112525-111	111- Room 33 Octogonal #1 NE Sink Faucet	Drinking Water	10/22/2016 1146	10/31/2016 0935
420-112525-112	112- Room 33 Octogonal #1 SE Sink Faucet	Drinking Water	10/22/2016 1146	10/31/2016 0935
420-112525-113	113- Room 33 Octogonal #2 SW Sink Faucet	Drinking Water	10/22/2016 1159	10/31/2016 0935
420-112525-114	114- Room 33 Octogonal #2 NW Sink Faucet	Drinking Water	10/22/2016 1159	10/31/2016 0935
420-112525-115	115- Room 33 Octogonal #2 NE Sink Faucet	Drinking Water	10/22/2016 1159	10/31/2016 0935
420-112525-116	116- Room 33 Octogonal #2 SE Sink Faucet	Drinking Water	10/22/2016 1159	10/31/2016 0935

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-112525-1
SDG Number: New Paltz CSD - Middle School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-112525-117	117- Room 33 Octagonal #3 SW Sink Faucet	Drinking Water	10/22/2016 1204	10/31/2016 0935
420-112525-118	118- Room 33 Octagonal #3 NW Sink Faucet	Drinking Water	10/22/2016 1204	10/31/2016 0935
420-112525-119	119- Room 33 Octagonal #3 NE Sink Faucet	Drinking Water	10/22/2016 1204	10/31/2016 0935
420-112525-120	120- Room 33 Octagonal #3 SE Sink Faucet	Drinking Water	10/22/2016 1204	10/31/2016 0935
420-112525-121	121- Room 33 Octagonal #4 SW Sink Faucet	Drinking Water	10/22/2016 1209	10/31/2016 0935
420-112525-122	122- Room 33 Octagonal #4 NW Sink Faucet	Drinking Water	10/22/2016 1209	10/31/2016 0935
420-112525-123	123- Room 33 Octagonal #4 NE Sink Faucet	Drinking Water	10/22/2016 1209	10/31/2016 0935
420-112525-124	124- Room 33 Octagonal #4 SE Sink Faucet	Drinking Water	10/22/2016 1209	10/31/2016 0935
420-112525-125	125- Room 33 Octagonal #5 SW Sink Faucet	Drinking Water	10/22/2016 1212	10/31/2016 0935
420-112525-126	126- Room 33 Octagonal #5 NW Sink Faucet	Drinking Water	10/22/2016 1212	10/31/2016 0935
420-112525-127	127- Room 33 Octagonal #5 NE Sink Faucet	Drinking Water	10/22/2016 1214	10/31/2016 0935
420-112525-128	128- Room 33 Octagonal #5 SE Sink Faucet	Drinking Water	10/22/2016 1214	10/31/2016 0935
420-112525-129	129- Room 33 Octagonal #6 SW Sink Faucet	Drinking Water	10/22/2016 1217	10/31/2016 0935
420-112525-130	130- Room 33 Octagonal #6 NW Sink Faucet	Drinking Water	10/22/2016 1217	10/31/2016 0935
420-112525-131	131- Room 33 Octagonal #6 NE Sink Faucet	Drinking Water	10/22/2016 1217	10/31/2016 0935
420-112525-132	132- Room 33 Utility Sink Faucet	Drinking Water	10/22/2016 1221	10/31/2016 0935
420-112525-133	133- Room 32 Utility Sink Faucet	Drinking Water	10/22/2016 1224	10/31/2016 0935
420-112525-134	134- Loading Dock Hose Bib	Drinking Water	10/22/2016 1247	10/31/2016 0935
420-112525-135	135- East Side Hose Bib	Drinking Water	10/22/2016 1300	10/31/2016 0935
420-112525-136	136- Health Office Sink Faucet	Drinking Water	10/22/2016 0550	10/31/2016 0935
420-112525-137	137- Health office TR Sink Faucet	Drinking Water	10/22/2016 0550	10/31/2016 0935
420-112525-138	138- Principal's TR Sink Faucet	Drinking Water	10/22/2016 0551	10/31/2016 0935
420-112525-139	139- Library Sink Faucet	Drinking Water	10/22/2016 0555	10/31/2016 0935

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 01- Room 10 Sink Faucet
Lab Sample ID: 420-112525-1

Date Sampled: 10/22/2016 0747
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1218	
Prep Method: 200			Date Prepared:	11/20/2016 1235	
Pb	12	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 02- Room 7 Sink Faucet
Lab Sample ID: 420-112525-2

Date Sampled: 10/22/2016 0749
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1219	
Prep Method: 200			Date Prepared:	11/20/2016 1235	
Pb	1.9	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 03- Room 9 Sink Faucet
Lab Sample ID: 420-112525-3

Date Sampled: 10/22/2016 0750
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1219	
Prep Method: 200			Date Prepared:	11/20/2016 1315	
Pb	5.3	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 04- Room 8 Sink Faucet
Lab Sample ID: 420-112525-4

Date Sampled: 10/22/2016 0751
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1224	
Prep Method: 200			Date Prepared:	11/20/2016 1315	
Pb	2.2	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 05- Room 5C Sink Faucet
Lab Sample ID: 420-112525-5

Date Sampled: 10/22/2016 0754
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1225	
Prep Method: 200			Date Prepared:	11/20/2016 1315	
Pb	5.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 06- Room 5C TR Sink Faucet
Lab Sample ID: 420-112525-6

Date Sampled: 10/22/2016 0754
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1226	
Prep Method: 200			Date Prepared:	11/20/2016 1315	
Pb	16 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 07- Room 6 Sink Faucet
Lab Sample ID: 420-112525-7

Date Sampled: 10/22/2016 0757
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1226	
Prep Method: 200			Date Prepared:	11/20/2016 1315	
Pb	350 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 08- Room 6 TR Sink Faucet
Lab Sample ID: 420-112525-8

Date Sampled: 10/22/2016 0759
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1227	
Prep Method: 200			Date Prepared:	11/20/2016 1315	
Pb	110 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 09- Room 3 TR Sink Faucet
Lab Sample ID: 420-112525-9

Date Sampled: 10/22/2016 0803
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1228	
Prep Method: 200			Date Prepared:	11/20/2016 1315	
Pb	5.2	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 10- Room 4 Sink Faucet
Lab Sample ID: 420-112525-10

Date Sampled: 10/22/2016 0804
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1229	
Prep Method: 200			Date Prepared:	11/20/2016 1315	
Pb	4.2	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 11- Room 4 Bubblers
Lab Sample ID: 420-112525-11

Date Sampled: 10/22/2016 0806
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1229	
Prep Method: 200			Date Prepared:	11/20/2016 1315	
Pb	4.2	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 12- Room 4 TR Sink Faucet
Lab Sample ID: 420-112525-12

Date Sampled: 10/22/2016 0808
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1230	
Prep Method: 200			Date Prepared:	11/20/2016 1315	
Pb	4.9	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 13- Room 1 Sink Faucet
Lab Sample ID: 420-112525-13

Date Sampled: 10/22/2016 0811
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1231	
Prep Method: 200			Date Prepared:	11/20/2016 1315	
Pb	28	g	ug/L	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 14- Room 1 Bubblers
Lab Sample ID: 420-112525-14

Date Sampled: 10/22/2016 0812
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1233	
Prep Method: 200			Date Prepared:	11/20/2016 1315	
Pb	16	g	ug/L	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 15- Room 1 TR Sink Faucet
Lab Sample ID: 420-112525-15

Date Sampled: 10/22/2016 0813
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1234	
Prep Method: 200			Date Prepared:	11/20/2016 1315	
Pb	8.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 16- Room 2 Sink Faucet
Lab Sample ID: 420-112525-16

Date Sampled: 10/22/2016 0814
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1235	
Prep Method: 200			Date Prepared:	11/20/2016 1315	
Pb	7.9	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 17- Room 2 Bubblers
Lab Sample ID: 420-112525-17

Date Sampled: 10/22/2016 0815
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1236	
Prep Method: 200			Date Prepared:	11/20/2016 1315	
Pb	13	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 18- Room 2 TR Sink Faucet
Lab Sample ID: 420-112525-18

Date Sampled: 10/22/2016 0816
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1236	
Prep Method: 200			Date Prepared:	11/20/2016 1315	
Pb	15	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 19- Faculty Room Sink Faucet
Lab Sample ID: 420-112525-19

Date Sampled: 10/22/2016 0819
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1237	
Prep Method: 200			Date Prepared:	11/20/2016 1315	
Pb	2.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 20- Women's TR Sink Faucet near cafeteria
Lab Sample ID: 420-112525-20

Date Sampled: 10/22/2016 0823
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1238	
Prep Method: 200			Date Prepared:	11/20/2016 1315	
Pb	6.2	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 21- Men's TR Sink Faucet near cafeteria
Lab Sample ID: 420-112525-21

Date Sampled: 10/22/2016 0824
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1239	
Prep Method: 200			Date Prepared:	11/20/2016 1315	
Pb	4.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 22- Boy's Locker room Left Sink Faucet
Lab Sample ID: 420-112525-22

Date Sampled: 10/22/2016 0826
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1239	
Prep Method: 200			Date Prepared:	11/20/2016 1315	
Pb	19 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 23- Boy's Locker room Right Sink Faucet
Lab Sample ID: 420-112525-23

Date Sampled: 10/22/2016 0828
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1240	
Prep Method: 200			Date Prepared:	11/20/2016 1355	
Pb	3.2	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 24- Boy's Locker room Water Fountain
Lab Sample ID: 420-112525-24

Date Sampled: 10/22/2016 0830
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1245	
Prep Method: 200			Date Prepared:	11/20/2016 1355	
Pb	9.0	ug/L	5.0	5.0	5.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 25- Girl's PE Coach's TR Sink Faucet
Lab Sample ID: 420-112525-25

Date Sampled: 10/22/2016 0834
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1246	
Prep Method: 200			Date Prepared:	11/20/2016 1355	
Pb	13	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 26- Girl's Locker room left Sink Faucet
Lab Sample ID: 420-112525-26

Date Sampled: 10/22/2016 0836
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1246	
Prep Method: 200			Date Prepared:	11/20/2016 1355	
Pb	4.7	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 27- Girl's Locker Room Right Sink Faucet
Lab Sample ID: 420-112525-27

Date Sampled: 10/22/2016 0837
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1247	
Prep Method: 200			Date Prepared:	11/20/2016 1355	
Pb	6.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 28- Girl's Locker Room water fountain
Lab Sample ID: 420-112525-28

Date Sampled: 10/22/2016 0838
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1248	
Prep Method: 200			Date Prepared:	11/20/2016 1355	
Pb	3.3	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 29- Kitchen W. Wall 1-Bay Sink Faucet
Lab Sample ID: 420-112525-29

Date Sampled: 10/22/2016 0845
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1249	
Prep Method: 200			Date Prepared:	11/20/2016 1355	
Pb	3.4	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 30- Kitchen W.Wall Groen Pot filler
Lab Sample ID: 420-112525-30

Date Sampled: 10/22/2016 0847
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1249	
Prep Method: 200			Date Prepared:	11/20/2016 1355	
Pb	10	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 31- Kitchen W. Wall Kettle Sprayer
Lab Sample ID: 420-112525-31

Date Sampled: 10/22/2016 0849
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1252	
Prep Method: 200			Date Prepared:	11/20/2016 1355	
Pb	2.2	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 32- Kitchen Center 1-Bay Sink Faucet
Lab Sample ID: 420-112525-32

Date Sampled: 10/22/2016 0851
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1253	
Prep Method: 200			Date Prepared:	11/20/2016 1355	
Pb	4.9	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 33- Kitchen S. Side 1-Bay Sink Faucet
Lab Sample ID: 420-112525-33

Date Sampled: 10/22/2016 0853
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1253	
Prep Method: 200			Date Prepared:	11/20/2016 1355	
Pb	1.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 34- Kitchen Dish Room 1-Bay Sink Faucet
Lab Sample ID: 420-112525-34

Date Sampled: 10/22/2016 0854
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1254	
Prep Method: 200			Date Prepared:	11/20/2016 1355	
Pb	14	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 35- Kitchen TR Sink Faucet
Lab Sample ID: 420-112525-35

Date Sampled: 10/22/2016 0855
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1255	
Prep Method: 200			Date Prepared:	11/20/2016 1355	
Pb	4.6	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 36- Boiler Room TR Sink Faucet
Lab Sample ID: 420-112525-36

Date Sampled: 10/22/2016 0900
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	12/06/2016 1511	
Prep Method: 200			Date Prepared:	12/05/2016 1500	
Pb	8.9	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 37- Men's TR Near Gym Left Sink Faucet
Lab Sample ID: 420-112525-37

Date Sampled: 10/22/2016 0906
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1256	
Prep Method: 200			Date Prepared:	11/20/2016 1355	
Pb	24 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 38- Men's TR near Gym Right Sink Faucet
Lab Sample ID: 420-112525-38

Date Sampled: 10/22/2016 0906
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1256	
Prep Method: 200			Date Prepared:	11/20/2016 1355	
Pb	24 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 39- Women's TR near Gym Left Sink Faucet
Lab Sample ID: 420-112525-39

Date Sampled: 10/22/2016 0914
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1257	
Prep Method: 200			Date Prepared:	11/20/2016 1355	
Pb	8.6	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 40- Women's TR Near Gym Right Sink Faucet
Lab Sample ID: 420-112525-40

Date Sampled: 10/22/2016 0915
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1258	
Prep Method: 200			Date Prepared:	11/20/2016 1355	
Pb	21 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 41- Room 21 Sink Faucet
Lab Sample ID: 420-112525-41

Date Sampled: 10/22/2016 0927
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1259	
Prep Method: 200			Date Prepared:	11/20/2016 1355	
Pb	2.6	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 42- Room 22 Sink Faucet
Lab Sample ID: 420-112525-42

Date Sampled: 10/22/2016 0929
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1301	
Prep Method: 200			Date Prepared:	11/20/2016 1355	
Pb	1.9	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 43- Room 23 Sink Faucet
Lab Sample ID: 420-112525-43

Date Sampled: 10/22/2016 0930
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1302	
Prep Method: 200			Date Prepared:	11/20/2016 1355	
Pb	3.3	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 44- Room 24 Sink Faucet
Lab Sample ID: 420-112525-44

Date Sampled: 10/22/2016 0931
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1303	
Prep Method: 200			Date Prepared:	11/20/2016 1435	
Pb	1.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 45- Room 25 Sink Faucet
Lab Sample ID: 420-112525-45

Date Sampled: 10/22/2016 0933
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1306	
Prep Method: 200			Date Prepared:	11/20/2016 1435	
Pb	38 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 46- Girl's TR Near Room 25 Left Sink Faucet
Lab Sample ID: 420-112525-46

Date Sampled: 10/22/2016 0935
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1306	
Prep Method: 200			Date Prepared:	11/20/2016 1435	
Pb	1.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 47- Girl's TR Near Room 25 Center Sink Sink
Lab Sample ID: 420-112525-47

Date Sampled: 10/22/2016 0935
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1307	
Prep Method: 200			Date Prepared:	11/20/2016 1435	
Pb	1.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 48- Girl's TR Near Room 25 Right Sink Faucet
Lab Sample ID: 420-112525-48

Date Sampled: 10/22/2016 0935
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1308	
Prep Method: 200			Date Prepared:	11/20/2016 1435	
Pb	1.6	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 49- Boy's TR Near Room 25 Left Sink Faucet
Lab Sample ID: 420-112525-49

Date Sampled: 10/22/2016 0939
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1310	
Prep Method: 200			Date Prepared:	11/20/2016 1435	
Pb	4.5	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 50- Boy's TR Near room 25 center Sink Faucet
Lab Sample ID: 420-112525-50

Date Sampled: 10/22/2016 0939
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1311	
Prep Method: 200			Date Prepared:	11/20/2016 1435	
Pb	1.3	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 51- Boy's TR Near room 25 right Sink Faucet
Lab Sample ID: 420-112525-51

Date Sampled: 10/22/2016 0939
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1312	
Prep Method: 200			Date Prepared:	11/20/2016 1435	
Pb	1.4	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 52- TR Across from main office Sink Faucet
Lab Sample ID: 420-112525-52

Date Sampled: 10/22/2016 0955
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1313	
Prep Method: 200			Date Prepared:	11/20/2016 1435	
Pb	3.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 53- Room 36 Left Sink Faucet left Sink
Lab Sample ID: 420-112525-53

Date Sampled: 10/22/2016 0957
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1313	
Prep Method: 200			Date Prepared:	11/20/2016 1435	
Pb	6.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 54- Room 36 Center Sink Faucet left sink
Lab Sample ID: 420-112525-54

Date Sampled: 10/22/2016 0957
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1314	
Prep Method: 200			Date Prepared:	11/20/2016 1435	
Pb	1.9	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 55- Room 36 right Sink Faucet left sink
Lab Sample ID: 420-112525-55

Date Sampled: 10/22/2016 0957
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1315	
Prep Method: 200			Date Prepared:	11/20/2016 1435	
Pb	4.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 56- Room 36 left Sink Faucet right sink Room
Lab Sample ID: 420-112525-56

Date Sampled: 10/22/2016 1001
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1316	
Prep Method: 200			Date Prepared:	11/20/2016 1435	
Pb	3.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 57- Room 36 center Sink Faucet right sink
Lab Sample ID: 420-112525-57

Date Sampled: 10/22/2016 1002
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1316	
Prep Method: 200			Date Prepared:	11/20/2016 1435	
Pb	1.7	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 58- Room 36 Right Sink Faucet right sink
Lab Sample ID: 420-112525-58

Date Sampled: 10/22/2016 1003
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1317	
Prep Method: 200			Date Prepared:	11/20/2016 1435	
Pb	1.9	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 59- Room 36 TR Sink Faucet
Lab Sample ID: 420-112525-59

Date Sampled: 10/22/2016 1006
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	12/02/2016 0933	
Prep Method: 200			Date Prepared:	11/23/2016 1000	
Pb	290	g	ug/L	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 60- Room 37 Sink Faucet
Lab Sample ID: 420-112525-60

Date Sampled: 10/22/2016 1010
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1706	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	3.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 61- Boy's TR across from 38 left Sink Faucet
Lab Sample ID: 420-112525-61

Date Sampled: 10/22/2016 1012
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1706	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 62- Boy's TR across from room 38 Right Sink
Lab Sample ID: 420-112525-62

Date Sampled: 10/22/2016 1012
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1707	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 63- Girl's TR near room 34 left Sink Faucet
Lab Sample ID: 420-112525-63

Date Sampled: 10/22/2016 1016
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1708	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 64- Girl's TR near Room 34 Center Sink Faucet
Lab Sample ID: 420-112525-64

Date Sampled: 10/22/2016 1016
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1709	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	1.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 65- Girl's TR near Room 34 Right Sink Faucet
Lab Sample ID: 420-112525-65

Date Sampled: 10/22/2016 1016
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1709	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 66- Room 27 Left Sink Faucet
Lab Sample ID: 420-112525-66

Date Sampled: 10/22/2016 1021
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1710	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	12	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 67- Room 27 Right Sink Faucet
Lab Sample ID: 420-112525-67

Date Sampled: 10/22/2016 1022
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1715	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	13	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 68- Room 28 Sink Faucet
Lab Sample ID: 420-112525-68

Date Sampled: 10/22/2016 1026
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1716	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	12	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 69- Room 42 Faucet Left Sink
Lab Sample ID: 420-112525-69

Date Sampled: 10/22/2016 1041
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1716	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	46 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 70- Room 42 Faucet Center Sink
Lab Sample ID: 420-112525-70

Date Sampled: 10/22/2016 1042
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1717	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	19 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 71- Room 42 Faucet Right Sink
Lab Sample ID: 420-112525-71

Date Sampled: 10/22/2016 1042
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1718	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	16 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 72- Girl's TR near Room 40 Left Sink Faucet
Lab Sample ID: 420-112525-72

Date Sampled: 10/22/2016 1049
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1719	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 73- Girl's TR near Room 40 Center Sink Faucet
Lab Sample ID: 420-112525-73

Date Sampled: 10/22/2016 1049
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1719	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 74- Girl's TR near Room 40 Right Sink Faucet
Lab Sample ID: 420-112525-74

Date Sampled: 10/22/2016 1050
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1720	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 75- Boy's TR Adjacent Room 45 Left Sink
Lab Sample ID: 420-112525-75

Date Sampled: 10/22/2016 1054
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1723	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 76- Boy's TR Adjacent Room 45 Right Sink
Lab Sample ID: 420-112525-76

Date Sampled: 10/22/2016 1054
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1723	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 77- Room 30 Sink Faucet
Lab Sample ID: 420-112525-77

Date Sampled: 10/22/2016 1115
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1724	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	37 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 78- Room 31 Utility Sink Faucet
Lab Sample ID: 420-112525-78

Date Sampled: 10/22/2016 1117
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1725	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	6.5	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 79- Room 31 Octogonal #1 SW Sink Faucet
Lab Sample ID: 420-112525-79

Date Sampled: 10/22/2016 1120
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1726	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	19 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 80- Room 31 Octogonal #1 NW Sink Faucet
Lab Sample ID: 420-112525-80

Date Sampled: 10/22/2016 1120
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1726	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	10	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 81- Room 31 Octogonal #1 NE Sink Faucet
Lab Sample ID: 420-112525-81

Date Sampled: 10/22/2016 1120
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1727	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	22 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 82- Room 31 Octogonal #1 SE Sink Faucet
Lab Sample ID: 420-112525-82

Date Sampled: 10/22/2016 1120
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1728	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	12	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 83- Room 31 Octogonal #2 SW Sink Faucet
Lab Sample ID: 420-112525-83

Date Sampled: 10/22/2016 1123
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1729	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	21	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 84- Room 31 Octogonal #2 NW Sink Faucet
Lab Sample ID: 420-112525-84

Date Sampled: 10/22/2016 1123
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1729	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	11	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 85- Room 31 Octogonal #2 NE Sink Faucet
Lab Sample ID: 420-112525-85

Date Sampled: 10/22/2016 1123
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1732	
Prep Method: 200			Date Prepared:	11/21/2016 1005	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 86- Room 31 Octagonal #2 SE Sink Faucet
Lab Sample ID: 420-112525-86

Date Sampled: 10/22/2016 1123
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1733	
Prep Method: 200			Date Prepared:	11/21/2016 1110	
Pb	17 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 87- Room 31 Octogonal #3 SW Sink Faucet
Lab Sample ID: 420-112525-87

Date Sampled: 10/22/2016 1126
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1736	
Prep Method: 200			Date Prepared:	11/21/2016 1110	
Pb	32 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 88- Room 31 Octogonal #3 NW Sink Faucet
Lab Sample ID: 420-112525-88

Date Sampled: 10/22/2016 1126
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1736	
Prep Method: 200			Date Prepared:	11/21/2016 1110	
Pb	16 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 89- Room 31 Octogonal #3 NE Sink Faucet
Lab Sample ID: 420-112525-89

Date Sampled: 10/22/2016 1126
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1737	
Prep Method: 200			Date Prepared:	11/21/2016 1110	
Pb	31 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 90- Room 31 Octogonal #3 SE Sink Faucet
Lab Sample ID: 420-112525-90

Date Sampled: 10/22/2016 1126
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1738	
Prep Method: 200			Date Prepared:	11/21/2016 1110	
Pb	12	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 91- Room 31 Octogonal #4 SW Sink Faucet
Lab Sample ID: 420-112525-91

Date Sampled: 10/22/2016 1130
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1739	
Prep Method: 200			Date Prepared:	11/21/2016 1110	
Pb	22 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 92- Room 31 Octogonal #4 NW Sink Faucet
Lab Sample ID: 420-112525-92

Date Sampled: 10/22/2016 1130
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1741	
Prep Method: 200			Date Prepared:	11/21/2016 1110	
Pb	32 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 93- Room 31 Octogonal #4 NE Sink Faucet
Lab Sample ID: 420-112525-93

Date Sampled: 10/22/2016 1130
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1742	
Prep Method: 200			Date Prepared:	11/21/2016 1110	
Pb	19 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 94- Room 31 Octogonal #4 SE Sink Faucet
Lab Sample ID: 420-112525-94

Date Sampled: 10/22/2016 1130
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1743	
Prep Method: 200			Date Prepared:	11/21/2016 1110	
Pb	14	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 95- Room 31 Octogonal #5 SW Sink Faucet
Lab Sample ID: 420-112525-95

Date Sampled: 10/22/2016 1133
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1743	
Prep Method: 200			Date Prepared:	11/21/2016 1110	
Pb	16 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 96- Room 31 Octogonal #5 NW Sink Faucet
Lab Sample ID: 420-112525-96

Date Sampled: 10/22/2016 1133
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1744	
Prep Method: 200			Date Prepared:	11/21/2016 1110	
Pb	17 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 97- Room 31 Octogonal #5 NE Sink Faucet
Lab Sample ID: 420-112525-97

Date Sampled: 10/22/2016 1133
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1745	
Prep Method: 200			Date Prepared:	11/21/2016 1110	
Pb	16 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 98-Room 31 Octagonal #5 SE Sink Faucet
Lab Sample ID: 420-112525-98

Date Sampled: 10/22/2016 1133
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1746	
Prep Method: 200			Date Prepared:	11/21/2016 1110	
Pb	12	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 99- Room 31 Octogonal #6 SW Sink Faucet
Lab Sample ID: 420-112525-99

Date Sampled: 10/22/2016 1135
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1747	
Prep Method: 200			Date Prepared:	11/21/2016 1110	
Pb	23 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 100- Room 31 Octagonal #6 NW Sink Faucet
Lab Sample ID: 420-112525-100

Date Sampled: 10/22/2016 1135
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1747	
Prep Method: 200			Date Prepared:	11/21/2016 1110	
Pb	13	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 101- Room 31 Octagonal #6 NE Sink Faucet
Lab Sample ID: 420-112525-101

Date Sampled: 10/22/2016 1137
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1748	
Prep Method: 200			Date Prepared:	11/21/2016 1110	
Pb	19 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 102- Room 31 Octagonal #6 SE Sink Faucet
Lab Sample ID: 420-112525-102

Date Sampled: 10/22/2016 1137
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1750	
Prep Method: 200			Date Prepared:	11/21/2016 1110	
Pb	13	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 103- Room 31 Octogonal #7 SW Sink Faucet
Lab Sample ID: 420-112525-103

Date Sampled: 10/22/2016 1141
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1751	
Prep Method: 200			Date Prepared:	11/21/2016 1110	
Pb	73 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 104- Room 31 Octogonal #7 NW Sink Faucet
Lab Sample ID: 420-112525-104

Date Sampled: 10/22/2016 1141
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1752	
Prep Method: 200			Date Prepared:	11/21/2016 1110	
Pb	12	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 105- Room 31 Octagonal #7 NE Sink Faucet
Lab Sample ID: 420-112525-105

Date Sampled: 10/22/2016 1141
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1753	
Prep Method: 200			Date Prepared:	11/21/2016 1110	
Pb	22 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 106- Room 31 Octogonal #7 SE Sink Faucet
Lab Sample ID: 420-112525-106

Date Sampled: 10/22/2016 1141
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1753	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	38 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 107- Room 31 Instructor's Sink Faucet
Lab Sample ID: 420-112525-107

Date Sampled: 10/22/2016 1143
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1757	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	13	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 108- Room 31/32 Prep Room Sink Faucet
Lab Sample ID: 420-112525-108

Date Sampled: 10/22/2016 1144
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1757	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	160 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 109- Room 33 Octagonal #1 SW Sink Faucet
Lab Sample ID: 420-112525-109

Date Sampled: 10/22/2016 1146
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1800	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	42 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 110- Room 33 Octagonal #1 NW Sink Faucet
Lab Sample ID: 420-112525-110

Date Sampled: 10/22/2016 1146
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1800	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	23 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 111- Room 33 Octagonal #1 NE Sink Faucet
Lab Sample ID: 420-112525-111

Date Sampled: 10/22/2016 1146
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1801	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	31 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 112-Room 33 Octagonal #1 SE Sink Faucet
Lab Sample ID: 420-112525-112

Date Sampled: 10/22/2016 1146
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1802	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	13	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 113- Room 33 Octagonal #2 SW Sink Faucet
Lab Sample ID: 420-112525-113

Date Sampled: 10/22/2016 1159
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1803	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	48 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 114- Room 33 Octagonal #2 NW Sink Faucet
Lab Sample ID: 420-112525-114

Date Sampled: 10/22/2016 1159
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1803	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	26 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 115- Room 33 Octagonal #2 NE Sink Faucet
Lab Sample ID: 420-112525-115

Date Sampled: 10/22/2016 1159
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1804	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	33 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 116- Room 33 Octagonal #2 SE Sink Faucet
Lab Sample ID: 420-112525-116

Date Sampled: 10/22/2016 1159
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1805	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	20 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 117- Room 33 Octagonal #3 SW Sink Faucet
Lab Sample ID: 420-112525-117

Date Sampled: 10/22/2016 1204
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1806	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	57 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 118- Room 33 Octagonal #3 NW Sink Faucet
Lab Sample ID: 420-112525-118

Date Sampled: 10/22/2016 1204
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1807	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	9.7	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 119- Room 33 Octagonal #3 NE Sink Faucet
Lab Sample ID: 420-112525-119

Date Sampled: 10/22/2016 1204
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1809	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	31 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 120- Room 33 Octagonal #3 SE Sink Faucet
Lab Sample ID: 420-112525-120

Date Sampled: 10/22/2016 1204
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1810	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	17 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 121- Room 33 Octagonal #4 SW Sink Faucet
Lab Sample ID: 420-112525-121

Date Sampled: 10/22/2016 1209
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	12/02/2016 0937	
Prep Method: 200			Date Prepared:	11/23/2016 1000	
Pb	230 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 122- Room 33 Octagonal #4 NW Sink Faucet
Lab Sample ID: 420-112525-122

Date Sampled: 10/22/2016 1209
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1810	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	18 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 123- Room 33 Octagonal #4 NE Sink Faucet
Lab Sample ID: 420-112525-123

Date Sampled: 10/22/2016 1209
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	12/02/2016 0941	
Prep Method: 200			Date Prepared:	11/23/2016 1000	
Pb	71 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 124- Room 33 Octagonal #4 SE Sink Faucet
Lab Sample ID: 420-112525-124

Date Sampled: 10/22/2016 1209
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1811	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	14	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 125- Room 33 Octagonal #5 SW Sink Faucet
Lab Sample ID: 420-112525-125

Date Sampled: 10/22/2016 1212
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1812	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	41 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 126- Room 33 Octagonal #5 NW Sink Faucet
Lab Sample ID: 420-112525-126

Date Sampled: 10/22/2016 1212
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1813	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	21 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 127- Room 33 Octagonal #5 NE Sink Faucet
Lab Sample ID: 420-112525-127

Date Sampled: 10/22/2016 1214
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1814	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	21 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 128- Room 33 Octagonal #5 SE Sink Faucet
Lab Sample ID: 420-112525-128

Date Sampled: 10/22/2016 1214
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1814	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	21 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 129- Room 33 Octagonal #6 SW Sink Faucet
Lab Sample ID: 420-112525-129

Date Sampled: 10/22/2016 1217
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1819	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	72 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 130- Room 33 Octagonal #6 NW Sink Faucet
Lab Sample ID: 420-112525-130

Date Sampled: 10/22/2016 1217
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1820	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	12	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 131- Room 33 Octagonal #6 NE Sink Faucet
Lab Sample ID: 420-112525-131

Date Sampled: 10/22/2016 1217
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1820	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	170 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 132- Room 33 Utility Sink Faucet
Lab Sample ID: 420-112525-132

Date Sampled: 10/22/2016 1221
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1821	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	7.3	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 133- Room 32 Utility Sink Faucet
Lab Sample ID: 420-112525-133

Date Sampled: 10/22/2016 1224
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1822	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	14	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 134- Loading Dock Hose Bib
Lab Sample ID: 420-112525-134

Date Sampled: 10/22/2016 1247
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1823	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	19 g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 135- East Side Hose Bib
Lab Sample ID: 420-112525-135

Date Sampled: 10/22/2016 1300
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1824	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	95	g	ug/L	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 136- Health Office Sink Faucet
Lab Sample ID: 420-112525-136

Date Sampled: 10/22/2016 0550
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1824	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	8.9	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 137- Health office TR Sink Faucet
Lab Sample ID: 420-112525-137

Date Sampled: 10/22/2016 0550
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1825	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	2.2	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 138- Principal's TR Sink Faucet
Lab Sample ID: 420-112525-138

Date Sampled: 10/22/2016 0551
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1827	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	210	g	ug/L	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-112525-1
Sdg Number: New Paltz CSD - Middle School

Client Sample ID: 139- Library Sink Faucet
Lab Sample ID: 420-112525-139

Date Sampled: 10/22/2016 0555
Date Received: 10/31/2016 0935
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/21/2016 1828	
Prep Method: 200			Date Prepared:	11/21/2016 1200	
Pb	12	ug/L	1.0	1.0	1.0

DATA REPORTING QUALIFIERS

Client: Ulster BOCES

Job Number:
Sdg Number: New Paltz CSD - Middle School

Lab Section	Qualifier	Description
Metals		
	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

Certification Information

Client: Ulster BOCES

Job Number:

Sdg Number: New Paltz CSD - Middle School

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Silicon, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Phenolphthalein Alkalinity, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), Total Inorganic Carbon, Volatile Acids as Acetic Acid, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, Iron Bacteria, Salmonella, & Sulfur Reducing Bacteria.

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Cobalt (200.7, 200.8), Tin (200.7), Strontium (200.7), Gold (200.7), Platinum (200.7), Palladium (200.7), Titanium (200.7), Phosphorus (365.3), Nitrate-Nitrite (10-107-4-1C, 353.2), m-Xylene & p-Xylene (502.2, 524), Naphthalene (502.2), o-Xylene (502.2, 524), & Fecal Coliform (9222D).

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), & MCPA (8151A).

Definitions and Glossary

Client: Ulster BOCES

Job Number:

Sdg Number: New Paltz CSD - Middle School

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.

112525

EnviroTest Laboratories
315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE New Paltz CSD - Middle School		PROJECT NO.	PROJECT LOCATION NPMS	MATRIX TYPE	REQUIRED ANALYSES					PAGE 1 of 1
ENVIROTEST PROJECT MANAGER Debra Bayer		P.O. NUMBER	TOWN		40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	Liter Plastic	250ml Plastic	Turnaround Time
CLIENT (SITE) PM S. Callahan - results to morourke@ulsterbocef.com		CLIENT PHONE 845-256-4090	CLIENT FAX							NORMAL
CLIENT NAME New Paltz Central School District										QUICK
CLIENT ADDRESS 196 Main Street, New Paltz, NY 12561										VERBAL
COMPANY CONTRACTING THIS WORK (if applicable):										
SAMPLE DATE		SAMPLE IDENTIFICATION		OTHER SPECIFY	NUMBER OF CONTAINERS SUBMITTED					REMARKS
10/22/2016	7:47	01 - Room 10 Sink Faucet			1					Lead (DW 200.8)
	7:49	02 - Room 7 Sink Faucet			1					Lead (DW 200.8)
	7:50	03 - Room 9 Sink Faucet			1					Lead (DW 200.8)
	7:51	04 - Room 8 Sink Faucet			1					Lead (DW 200.8)
	7:54	05 - Room 5C Sink Faucet			1					Lead (DW 200.8)
	7:54	06 - Room 5C TR Sink Faucet			1					Lead (DW 200.8)
	7:57	07 - Room 6 Sink Faucet			1					Lead (DW 200.8)
	7:59	08 - Room 6 TR Sink Faucet			1					Lead (DW 200.8)
	8:03	09 - Room 3 TR Sink Faucet			1					Lead (DW 200.8)
	8:04	10 - Room 4 Sink Faucet			1					Lead (DW 200.8)
	8:06	11 - Room 4 Bubbler			1					Lead (DW 200.8)
	8:08	12 - Room 4 TR Sink Faucet			1					Lead (DW 200.8)
	8:11	13 - Room 1 Sink Faucet			1					Lead (DW 200.8)
RELINQUISHED BY: (SIGNATURE) <i>Brian Colandrea</i>		DATE 10/31/16	TIME 9:35 am	COMP/DATE	RECEIVED BY: (SIGNATURE)					TIME
COMPANY Ulster BOCEFS		DATE 10/31/16	TIME 9:35 am	COMP/DATE	RECEIVED BY: (SIGNATURE)					TIME
RELINQUISHED BY: (SIGNATURE) <i>Brian Colandrea</i>		DATE	TIME	COMP/DATE	RECEIVED BY: (SIGNATURE)					TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE) *[Signature]* DATE 10/31/16 TIME 09:35

CUSTODY INTACT
YES NO

COOLER TEMP (C): 17.7

LABORATORY REMARKS: ICE (Y/N) PH 10.43 CL2 Reviewed by: _____

112525

Lab Name: EnviroTest Laboratories
 Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE: New Palitz CSD - Middle School
 ENVIROTEST PROJECT MANAGER: Debra Bayer
 CLIENT (SITE) PW: S. Callahan - results to morourke@ulsterbocees.org
 CLIENT NAME: New Palitz Central School District
 CLIENT ADDRESS: 196 Main Street, New Palitz, NY 12561
 COMPANY CONTRACTING THIS WORK (if applicable):

SAMPLE DATE	TIME	SAMPLE IDENTIFICATION	MATRIX TYPE		COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	D (Drinking Water) or V (Vase Water) Indicate	SOLID OR SEMISOLID	OTHER Specify	Total # of Containers	REQUIRED ANALYSES						# OF COOLERS	REMARKS
			NPWS	TOWN							40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic		
10/22/2016	8:12	14 - Room 1 Bubbler								1	1						Lead (DW 200.8)	
	8:13	15 - Room 1 TR Sink Faucet								1	1						Lead (DW 200.8)	
	8:14	16 - Room 2 Sink Faucet								1	1						Lead (DW 200.8)	
	8:15	17 - Room 2 Bubbler								1	1						Lead (DW 200.8)	
	8:16	18 - Room 2 TR Sink Faucet								1	1						Lead (DW 200.8)	
	8:19	19 - Faculty Room Sink Faucet								1	1						Lead (DW 200.8)	
	8:23	20 - Women's TR Sink Faucet Near Cafeteria								1	1						Lead (DW 200.8)	
	8:24	21 - Men's TR Sink Faucet Near Cafeteria								1	1						Lead (DW 200.8)	
	8:26	22 - Boy's Locker Room Left Sink Faucet								1	1						Lead (DW 200.8)	
	8:28	23 - Boy's Locker Room Right Sink Faucet								1	1						Lead (DW 200.8)	
	8:30	24 - Boy's Locker Room Water Fountain								1	1						Lead (DW 200.8)	
	8:34	25 - Girl's PE Coach's TR Sink Faucet								1	1						Lead (DW 200.8)	
	8:36	26 - Girl's Locker Room Left Sink Faucet								1	1						Lead (DW 200.8)	

RELINQUISHED BY: (SIGNATURE) *Debra Bayer* COMPANY *ULSTER BOCEES* DATE *10/31/16* TIME *9:35 am*
 SAMPLED BY: (SIGNATURE) *Debra Bayer* COMPANY *ULSTER BOCEES* DATE *10/31/16* TIME *9:35 am*
 RELINQUISHED BY: (SIGNATURE) _____ COMPANY _____ DATE _____ TIME _____

RECEIVED BY: (SIGNATURE) *[Signature]* DATE *10/31/16* TIME *9:35*
 RECEIVED BY: (SIGNATURE) _____ DATE _____ TIME _____
 RECEIVED BY: (SIGNATURE) _____ DATE _____ TIME _____

LABORATORY REMARKS: ICE (Y/N) *N* pH *7.7* CL2 *12#3*
 CUSTODY INTACT: YES NO
 Cooler Temp (C): *17.7*

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

REPORT# (Lab Use Only)

112525

Lab Name EnviroTest Laboratories
Address & Phone 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE New Paltz CSD - Middle School		PROJECT LOCATION NPMIS	MATRIX TYPE		REQUIRED ANALYSES		PAGE 1 of 3
ENVIROTEST PROJECT MANAGER Debra Bayer		TOWN	OTHER SPECIFY	OTHER	Other	Other	TURNAROUND TIME
CLIENT (SITE) PM S. Callahan - results to morourke@ulsterbooces.org		CLIENT PHONE 845-256-4090	ACQUEOUS (WATER)	250ml Plastic Nitrile Acid	250ml Plastic Nitrile Acid	250ml Plastic Nitrile Acid	NORMAL
CLIENT NAME New Paltz Central School District		CLIENT FAX	D (Drinking Water) or W (Waste Water) indicate	Liter Amber HCl	Liter Plastic	Terra Core	QUICK
CLIENT ADDRESS 196 Main Street, New Paltz, NY 12561			SOLID OR SEMISOLID	40ml Vials HCl	250ml Plastic Surfactant Acid		VERBAL
COMPANY CONTRACTING THIS WORK (if applicable)			COMPOSITE (C) OR GRAB (G) INDICATE	Total # of Containers	250ml Plastic Surfactant Acid		
SAMPLE IDENTIFICATION				NUMBER OF CONTAINERS SUBMITTED	250ml Plastic Nitrile Acid		#OF COOLERS
DATE	TIME				250ml Plastic Nitrile Acid		REMARKS
10/22/2016	8:37	27 - Girl's Locker Room Right Sink Faucet		1	Liter Amber HCl		Lead (DW 200.8)
	8:38	28 - Girl's Locker Room Water Fountain		1	40ml Vials HCl		Lead (DW 200.8)
	8:45	29 - Kitchen W. Wall 1-Bay Sink Faucet		1	250ml Plastic Nitrile Acid		Lead (DW 200.8)
	8:47	30 - Kitchen W. Wall Green Pot Filler		1	Liter Plastic		Lead (DW 200.8)
	8:49	31 - Kitchen W. Wall Kettle Sprayer		1	250ml Plastic Nitrile Acid		Lead (DW 200.8)
	8:51	32 - Kitchen Center 1-Bay Sink Faucet		1	Liter Amber HCl		Lead (DW 200.8)
	8:53	33 - Kitchen S. Side 1-Bay Sink Faucet		1	250ml Plastic Nitrile Acid		Lead (DW 200.8)
	8:54	34 - Kitchen Dish Room 1-Bay Sink Faucet		1	Liter Plastic		Lead (DW 200.8)
	8:55	35 - Kitchen TR Sink Faucet		1	250ml Plastic Nitrile Acid		Lead (DW 200.8)
	9:00	36 - Boiler Room TR Sink Faucet		1	Liter Amber HCl		Lead (DW 200.8)
	9:06	37 - Men's TR Near Gym Left Sink Faucet		1	250ml Plastic Nitrile Acid		Lead (DW 200.8)
	9:06	38 - Men's TR Near Gym Right Sink Faucet		1	Liter Plastic		Lead (DW 200.8)
	9:14	39 - Women's TR Near Gym Left Sink Faucet		1	250ml Plastic Nitrile Acid		Lead (DW 200.8)
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP/DATE	TIME	
<i>Brian Colanin</i>	Ulster BOCES	10/31/16	9:35am				
SAMPLED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP/DATE	TIME	
<i>Brian Colanin</i>	Ulster BOCES	10/31/16	9:35am				
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP/DATE	TIME	
<i>[Signature]</i>							

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT	Cooler Temp(C):	LABORATORY REMARKS:	ICE (Y/N)	pH	CL2	Revalued by:
<i>[Signature]</i>	10/31/16	0935	YES	17.7					<i>[Signature]</i>

112525

Lab Name **EnviroTest Laboratories**
Address & Phone **315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890**

PROJECT REFERENCE: **New Paltz CSD - Middle School**
 ENVIROTEST PROJECT MANAGER: **Debra Bayer**
 CLIENT (SITE) PM: **S. Callahan - results to morourke@ulsterbocees.org**
 CLIENT NAME: **New Paltz Central School District**
 CLIENT ADDRESS: **196 Main Street, New Paltz, NY 12561**
 COMPANY CONTRACTING THIS WORK (if applicable):

PROJECT NO.:
 P.O. NUMBER:
 CLIENT PHONE: **845-256-4090**
 CLIENT FAX:
 PROJECT LOCATION: **NPMS TOWN**
 MATRIX TYPE:
 OTHER Specify:

REQUIRED ANALYSES:
 Total # of Containers
 40ml Vials HCl
 250ml Plastic Nitric Acid
 250ml Plastic Sulfuric Acid
 Liter Plastic
 250ml Plastic
 Terra Core
 Other
 Other

PAGE 1 of 4
 TURNAROUND TIME
 NORMAL
 QUICK
 VERBAL

SAMPLE DATE	TIME	SAMPLE IDENTIFICATION	NUMBER OF CONTAINERS SUBMITTED										REMARKS		
			1	1	1	1	1	1	1	1	1	1		1	1
10/22/2016	9:15	40 - Women's TR Near Gym Right Sink Faucet	1												Lead (DW 200.8)
	9:27	41 - Room 21 Sink Faucet	1												Lead (DW 200.8)
	9:29	42 - Room 22 Sink Faucet	1												Lead (DW 200.8)
	9:30	43 - Room 23 Sink Faucet	1												Lead (DW 200.8)
	9:31	44 - Room 24 Sink Faucet	1												Lead (DW 200.8)
	9:33	45 - Room 25 Sink Faucet	1												Lead (DW 200.8)
	9:35	46 - Girl's TR Near Room 25 Left Sink Faucet	1												Lead (DW 200.8)
	9:35	47 - Girl's TR Near Room 25 Center Sink Faucet	1												Lead (DW 200.8)
	9:35	48 - Girl's TR Near Room 25 Right Sink Faucet	1												Lead (DW 200.8)
	9:39	49 - Boy's TR Near Room 25 Left Sink Faucet	1												Lead (DW 200.8)
	9:39	50 - Boy's TR Near Room 25 Center Sink Faucet	1												Lead (DW 200.8)
	9:39	51 - Boy's TR Near Room 25 Right Sink Faucet	1												Lead (DW 200.8)
	9:55	52 - TR Across From Main Office Sink Faucet	1												Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE) *Benjamin Gorman* COMPANY **Ulster BOCES** DATE **10/31/16** TIME **9:35am**
 SAMPLED BY: (SIGNATURE) *Benjamin Gorman* COMPANY **Ulster BOCES** DATE **10/31/16** TIME **9:35am**
 RELINQUISHED BY: (SIGNATURE) COMPANY DATE TIME

RECEIVED BY: (SIGNATURE) COMP/DATE TIME
 RECEIVED BY: (SIGNATURE) COMP/DATE TIME
 RECEIVED BY: (SIGNATURE) COMP/DATE TIME

LABORATORY REMARKS: ICE (Y/N) pH **7.7** Revisited by *CS*

EnviroTest Laboratories, Inc.



CHAIN OF CUSTODY

REPORT# (Lab Use Only)

112525

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE	PROJECT NO.	PROJECT LOCATION	MATRIX TYPE	REQUIRED ANALYSES	PAGE 1 of 5
New Paltz CSD - Middle School	NPWIS	NPWIS TOWN	OTHER Specify	Other	
ENVIROTEST PROJECT MANAGER Debra Bayer	P.O. NUMBER	CLIENT FAX	SOLID OR SEMISOLID	Terra Core	TURNAROUND TIME
CLIENT (SITE) PM S. Callahan - results to mcorourke@ulsterbooces.org	CLIENT PHONE 845-256-4090	COMPOSITE (C) OR GRAB (G) (M/C) DATE	D (Drinking Water) or W (Waste Water) Indicate	250ml Plastic	NORMAL
CLIENT NAME New Paltz Central School District		AQUEOUS (M/T/R)		Liter Plastic	QUICK
CLIENT ADDRESS 196 Main Street, New Paltz, NY 12561				250ml Plastic Sulfuric Acid	VERBAL
COMPANY CONTRACTING THIS WORK (if applicable):					
SAMPLE	DATE	TIME	SAMPLE IDENTIFICATION	NUMBER OF CONTAINERS SUBMITTED	REMARKS
	10/22/2016	9:57	53 - Room 36 Left Sink Faucet Left Sink	1	Lead (DW 200.8)
		9:57	54 - Room 36 Center Sink Faucet Left Sink	1	Lead (DW 200.8)
		9:57	55 - Room 36 Right Sink Faucet Left Sink	1	Lead (DW 200.8)
		10:01	56 - Room 36 Left Sink Faucet Right Sink	1	Lead (DW 200.8)
		10:02	57 - Room 36 Center Sink Faucet Right Sink	1	Lead (DW 200.8)
		10:03	58 - Room 36 Right Sink Faucet Right Sink	1	Lead (DW 200.8)
		10:06	59 - Room 36 TR Sink Faucet	1	Lead (DW 200.8)
		10:10	60 - Room 37 Sink Faucet	1	Lead (DW 200.8)
		10:12	61 - Boy's TR Across From Room 38 Left Sink Faucet	1	Lead (DW 200.8)
		10:12	62 - Boy's TR Across From Room 38 Right Sink Faucet	1	Lead (DW 200.8)
		10:16	63 - Girl's TR Near Room 34 Left Sink Faucet	1	Lead (DW 200.8)
		10:16	64 - Girl's TR Near Room 34 Center Sink Faucet	1	Lead (DW 200.8)
		10:16	65 - Girl's TR Near Room 34 Right Sink Faucet	1	Lead (DW 200.8)
RELINQUISHED BY: (SIGNATURE) <i>Debra Bayer</i>	COMPANY Ulster BOCES	DATE 10/31/16	TIME 9:35am	RECEIVED BY: (SIGNATURE)	COMP/DATE
SAMPLED BY: (SIGNATURE) <i>Debra Bayer</i>	COMPANY Ulster BOCES	DATE 10/31/16	TIME 9:35am	RECEIVED BY: (SIGNATURE)	COMP/DATE
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP/DATE

RECEIVED FOR LABORATORY BY: (SIGNATURE) <i>[Signature]</i>	DATE 10/31/16	TIME 0925	CUSTODY INTACT YES	COOLER TEMP (C): 17.7	LABORATORY REMARKS: ICE (Y/N) pH CL2 Reversed by: [Signature]
---------------------------------------------------------------	------------------	--------------	-----------------------	--------------------------	------------------------------------------------------------------

EnviroTest Laboratories, Inc.



CHAIN OF CUSTODY

REPORT# (Lab Use Only)

112525

Lab Name: EnviroTest Laboratories
 Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE New Palitz CSD - Middle School	PROJECT NO.	PROJECT LOCATION NPMIS	MATRIX TYPE	REQUIRED ANALYSES	PAGE 1 of 6
ENVIROTEST PROJECT MANAGER Debra Bayer	P.O. NUMBER	TOWN	OTHER SPECIFY	Other	TURNAROUND TIME
CLIENT (SITE) PM S. Callahan - results to morourke@uisterboecs.org	CLIENT PHONE 845-256-4090	CLIENT FAX	D (Drinking Water) or W (Waste Water) Indicate	Terra Core	NORMAL
CLIENT NAME New Palitz Central School District			AQUEOUS (WATER)	250ml Plastic	QUICK
CLIENT ADDRESS 196 Main Street, New Palitz, NY 12561			COMPOSITE (C) OR GRAB (G) INDICATE	250ml Plastic Sulfuric Acid	VERBAL
COMPANY CONTRACTING THIS WORK (if applicable)				40ml Vials HCl	# OF COOLERS
				Liter Amber HCl	REMARKS
				Liter Plastic	
				250ml Plastic Nitric Acid	
				250ml Plastic Sulfuric Acid	
				Other	

SAMPLE DATE	TIME	SAMPLE IDENTIFICATION	NUMBER OF CONTAINERS SUBMITTED	RECEIVED BY: (SIGNATURE)	COMP/DATE	TIME
10/22/2016	10:21	66 - Room 27 Left Sink Faucet	1			
	10:22	67 - Room 27 Right Sink Faucet	1			
	10:26	68 - Room 28 Sink Faucet	1			
	10:41	69 - Room 42 Faucet Left Sink	1			
	10:42	70 - Room 42 Faucet Center Sink	1			
	10:42	71 - Room 42 Faucet Right Sink	1			
	10:49	72 - Girl's TR Near Room 40 Left Sink Faucet	1			
	10:49	73 - Girl's TR Near Room 40 Center Sink Faucet	1			
	10:50	74 - Girl's TR Near Room 40 Right Sink Faucet	1			
	10:54	75 - Boy's TR Adjacent Room 45 Left Sink Faucet	1			
	10:54	76 - Boy's TR Adjacent Room 45 Right Sink Faucet	1			
	11:15	77 - Room 30 Sink Faucet	1			
	11:17	78 - Room 31 Utility Sink Faucet	1			

RELINQUISHED BY: (SIGNATURE) <i>Brian Coburn Uster BOECS</i>	DATE 10/31/16	TIME 9:35am
SAMPLED BY: (SIGNATURE) <i>Brian Coburn Uster BOECS</i>	DATE 10/31/16	TIME 9:35am
RELINQUISHED BY: (SIGNATURE)	DATE	TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE) <i>[Signature]</i>	DATE 10/31/16	TIME 09:35	CUSTOMER INTACT YES NO	Cooler Temp (C): 17.7	LABORATORY REMARKS: ICE (Y/N) PH CL2 10-2-3
---------------------------------------------------------------	------------------	---------------	------------------------------	--------------------------	---------------------------------------------------



CHAIN OF CUSTODY

112525

REPORT# (Lab Use Only)

EnviroTest Laboratories, Inc.
 Lab Name: EnviroTest Laboratories
 Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE: New Palitz CSD - Middle School
 ENVIROTEST PROJECT MANAGER: Debra Bayer
 CLIENT (SITE) PM: S. Callahan - results to morourke@ulsterboces.org
 CLIENT NAME: New Palitz Central School District
 CLIENT ADDRESS: 196 Main Street, New Palitz, NY 12561
 COMPANY CONTRACTING THIS WORK (IF APPLICABLE):

PROJECT NO.	PROJECT LOCATION	MATRIX TYPE	REQUIRED ANALYSES								TURNAROUND TIME	
			Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core		Other
10/22/2016	79 - Room 31 Octogonal #1 SW Sink Faucet		1			1						Lead (DW 200.8)
11:20	80 - Room 31 Octogonal #1 NW Sink Faucet		1			1						Lead (DW 200.8)
11:20	81 - Room 31 Octogonal #1 NE Sink Faucet		1			1						Lead (DW 200.8)
11:20	82 - Room 31 Octogonal #1 SE Sink Faucet		1			1						Lead (DW 200.8)
11:23	83 - Room 31 Octogonal #2 SW Sink Faucet		1			1						Lead (DW 200.8)
11:23	84 - Room 31 Octogonal #2 NW Sink Faucet		1			1						Lead (DW 200.8)
11:23	85 - Room 31 Octogonal #2 NE Sink Faucet		1			1						Lead (DW 200.8)
11:23	86 - Room 31 Octogonal #2 SE Sink Faucet		1			1						Lead (DW 200.8)
11:26	87 - Room 31 Octogonal #3 SW Sink Faucet		1			1						Lead (DW 200.8)
11:26	88 - Room 31 Octogonal #3 NW Sink Faucet		1			1						Lead (DW 200.8)
11:26	89 - Room 31 Octogonal #3 NE Sink Faucet		1			1						Lead (DW 200.8)
11:26	90 - Room 31 Octogonal #3 SE Sink Faucet		1			1						Lead (DW 200.8)

RECEIVED BY: (SIGNATURE) *Bevan Glendon Ulster Boces* DATE: 10/31/16 TIME: 9:35am
 RECEIVED BY: (SIGNATURE) *Bevan Glendon Ulster Boces* DATE: 10/31/16 TIME: 9:35am
 RECEIVED BY: (SIGNATURE) _____ DATE: _____ TIME: _____

RECEIVED FOR LABORATORY BY: (SIGNATURE) *[Signature]* DATE: 10/31/16 TIME: 8:35 AM
 CUSTODY INTACT: YES [] NO [X]
 COOLER TEMP (C): 17.7
 LABORATORY REMARKS: ICE (Y/N) [N] pH [] CL2 [] Revisited by: *[Signature]*

EnviroTest Laboratories, Inc.



CHAIN OF CUSTODY

REPORT# (Lab Use Only)

112525

Lab Name: EnviroTest Laboratories
 Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE: New Paltz CSD - Middle School
 ENVIROTEST PROJECT MANAGER: Debra Bayer
 CLIENT (SITE) PM: S. Callahan - results to morourke@ulsterbocees.org
 CLIENT NAME: New Paltz Central School District
 CLIENT ADDRESS: 196 Main Street, New Paltz, NY 12561
 COMPANY CONTRACTING THIS WORK (if applicable):

SAMPLE DATE	TIME	SAMPLE IDENTIFICATION	REQUIRED ANALYSES										# OF COOLERS	REMARKS	
			Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other			
10/22/2016	11:30	91 - Room 31 Octagonal #4 SW Sink Faucet	1												Lead (DW 200.8)
	11:30	92 - Room 31 Octagonal #4 NW Sink Faucet	1												Lead (DW 200.8)
	11:30	93 - Room 31 Octagonal #4 NE Sink Faucet	1												Lead (DW 200.8)
	11:30	94 - Room 31 Octagonal #4 SE Sink Faucet	1												Lead (DW 200.8)
	11:33	95 - Room 31 Octagonal #5 SW Sink Faucet	1												Lead (DW 200.8)
	11:33	96 - Room 31 Octagonal #5 NW Sink Faucet	1												Lead (DW 200.8)
	11:33	97 - Room 31 Octagonal #5 NE Sink Faucet	1												Lead (DW 200.8)
	11:33	98 - Room 31 Octagonal #5 SE Sink Faucet	1												Lead (DW 200.8)
	11:35	99 - Room 31 Octagonal #6 SW Sink Faucet	1												Lead (DW 200.8)
	11:35	100 Room 31 Octagonal #6 NW Sink Faucet	1												Lead (DW 200.8)
	11:37	101 - Room 31 Octagonal #6 NE Sink Faucet	1												Lead (DW 200.8)
	11:37	102 - Room 31 Octagonal #6 SE Sink Faucet	1												Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE) *Brian Glavin* COMPANY *Ulster BOCEs* DATE *10/31/16* TIME *9:35am*
 SAMPLED BY: (SIGNATURE) *Brian Glavin* COMPANY *Ulster BOCEs* DATE *10/31/16* TIME *9:35am*
 RELINQUISHED BY: (SIGNATURE) _____ COMPANY _____ DATE _____ TIME _____

RECEIVED FOR LABORATORY BY: (SIGNATURE) *[Signature]* DATE *10/31/16* TIME *10:35*
 CUSTODY INTACT: YES NO
 Cooler Temp(C): *17.7*
 LABORATORY REMARKS: ICE (Y/N) *N* PH *7.3* C12 _____ Revisited by _____

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

REPORT# (Lab Use Only)

112525

Lab Name: EnviroTest Laboratories
 Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE: New Paltz CSD - Middle School
 ENVIROTEST PROJECT MANAGER: Debra Bayer
 CLIENT (SITE) PM: S. Callahan - results to morourke@ulsterboes.org
 CLIENT NAME: New Paltz Central School District
 CLIENT ADDRESS: 196 Main Street, New Paltz, NY 12561
 COMPANY CONTRACTING THIS WORK (if applicable):

PROJECT NO.:
 P.O. NUMBER:
 PROJECT LOCATION: NIPMS TOWN:
 CLIENT PHONE: 845-256-4090
 CLIENT FAX:
 MATRIX TYPE:
 AQUEOUS (WATER)
 COMPOSITE (C) OR GRAB (G) IN/CANISTER

REQUIRED ANALYSES:
 40ml Vials HCl
 250ml Plastic Nitric Acid
 250ml Plastic Sulfuric Acid
 Lier Plastic
 250ml Plastic
 Terra Core
 Other
 Other

PAGE 1 of 9
 TURNAROUND TIME:
 NORMAL
 QUICK
 VERBAL

SAMPLE	DATE	TIME	SAMPLE IDENTIFICATION	MATRIX TYPE	OTHER SPECIFY	NUMBER OF CONTAINERS SUBMITTED	REMARKS
10/22/2016	11:41		103 - Room 31 Octagonal #7 SW Sink Faucet			1	Lead (DW 200.8)
	11:41		104 - Room 31 Octagonal #7 NW Sink Faucet			1	Lead (DW 200.8)
	11:41		105 - Room 31 Octagonal #7 NE Sink Faucet			1	Lead (DW 200.8)
	11:41		106 - Room 31 Octagonal #7 SE Sink Faucet			1	Lead (DW 200.8)
	11:43		107 - Room 31 Instructor's Sink Faucet			1	Lead (DW 200.8)
	11:44		108 - Room 31/32 Prep Room Sink Faucet			1	Lead (DW 200.8)
	11:46		109 - Room 33 Octagonal #1 SW Sink Faucet			1	Lead (DW 200.8)
	11:46		110 - Room 33 Octagonal #1 NW Sink Faucet			1	Lead (DW 200.8)
	11:46		111 - Room 33 Octagonal #1 NE Sink Faucet			1	Lead (DW 200.8)
	11:46		112 - Room 33 Octagonal #1 SE Sink Faucet			1	Lead (DW 200.8)
	11:59		113 - Room 33 Octagonal #2 SW Sink Faucet			1	Lead (DW 200.8)
	11:59		114 - Room 33 Octagonal #2 NW Sink Faucet			1	Lead (DW 200.8)
	11:59		115 - Room 33 Octagonal #2 NE Sink Faucet			1	Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE) *Brian Glendon Ulster BOES* DATE: 10/31/16 TIME: 9:35 am
 COMPANY: Ulster BOES
 SAMPLED BY: (SIGNATURE) *Brian Glendon Ulster BOES* DATE: 10/31/16 TIME: 9:35 am
 COMPANY: Ulster BOES
 RECEIVED BY: (SIGNATURE) _____ DATE: _____ TIME: _____
 RECEIVED BY: (SIGNATURE) _____ DATE: _____ TIME: _____
 RECEIVED BY: (SIGNATURE) _____ DATE: _____ TIME: _____

RECEIVED FOR LABORATORY BY: (SIGNATURE) *[Signature]* DATE: 10/31/16 0935 TIME: 17:07
 CUSTODY INTACT: YES/NO
 COOLER Temp (C):
 LABORATORY REMARKS: ICE (Y/N) PH: CL2 Revisited by: *[Signature]*

Lab Name: EnviroTest Laboratories
 Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE: New Paltz CSD - Middle School
 ENVIROTEST PROJECT MANAGER: Debra Bayer
 CLIENT (SITE) PM: S. Callahan - results to morourke@ulsterbocees.org
 CLIENT NAME: New Paltz Central School District
 CLIENT ADDRESS: 196 Main Street, New Paltz, NY 12561
 COMPANY CONTRACTING THIS WORK (if applicable):

PROJECT NO.:
 P.O. NUMBER:
 CLIENT PHONE: 845-256-4090
 CLIENT FAX:
 PROJECT LOCATION: NPIMS
 TOWN:
 MATRIX TYPE:
 OTHER Specify:

REQUIRED ANALYSES:
 Total # of Containers: 40ml Vials HCl, 250ml Plastic Nitric Acid, 250ml Plastic Sulfuric Acid, Liter Plastic, 250ml Plastic
 Turnaround Time: 10
 NORMAL
 QUICK
 VERBAL

SAMPLE	DATE	TIME	SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	D (Drinking Water) or W (Waste Water) Indicate	SOLID OR SEMISOLID	OTHER Specify	NUMBER OF CONTAINERS SUBMITTED	REMARKS
	10/22/2016	11:59	116 - Room 33 Octagonal #2 SE Sink Faucet						1	Lead (DW 200.8)
		12:04	117 - Room 33 Octagonal #3 SW Sink Faucet						1	Lead (DW 200.8)
		12:04	118 - Room 33 Octagonal #3 NW Sink Faucet						1	Lead (DW 200.8)
		12:04	119 - Room 33 Octagonal #3 NE Sink Faucet						1	Lead (DW 200.8)
		12:04	120 - Room 33 Octagonal #3 SE Sink Faucet						1	Lead (DW 200.8)
		12:09	121 - Room 33 Octagonal #4 SW Sink Faucet						1	Lead (DW 200.8)
		12:09	122 - Room 33 Octagonal #4 NW Sink Faucet						1	Lead (DW 200.8)
		12:09	123 - Room 33 Octagonal #4 NE Sink Faucet						1	Lead (DW 200.8)
		12:09	124 - Room 33 Octagonal #4 SE Sink Faucet						1	Lead (DW 200.8)
		12:12	125 - Room 33 Octagonal #5 SW Sink Faucet						1	Lead (DW 200.8)
		12:12	126 - Room 33 Octagonal #5 NW Sink Faucet						1	Lead (DW 200.8)
		12:14	127 - Room 33 Octagonal #5 NE Sink Faucet						1	Lead (DW 200.8)
		12:14	128 - Room 33 Octagonal #5 SE Sink Faucet						1	Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE) *Debra Bayer* COMPANY: *Ulster BOCEES* DATE: *10/31/16* TIME: *9:35am*
 RECEIVED BY: (SIGNATURE) _____ COMP/DATE: _____
 RELINQUISHED BY: (SIGNATURE) *Debra Bayer* COMPANY: *Ulster BOCEES* DATE: *10/31/16* TIME: *9:35am*
 RECEIVED BY: (SIGNATURE) _____ COMP/DATE: _____

RECEIVED FOR LABORATORY BY: (SIGNATURE) *[Signature]* DATE: *10/31/16* TIME: *0935*
 CUSTODY INTACT: YES NO
 COOLER Temp (C): *17.7*
 LABORATORY REMARKS: ICE (Y/N) pH *7.2* Revisited by: *[Signature]*

112525

Lab Name: EnviroTest Laboratories
 Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE New Paltz CSD - Middle School	PROJECT NO.	PROJECT LOCATION NPWS	MATRIX TYPE	REQUIRED ANALYSES	PAGE 1 of 11
ENVIROTEST PROJECT MANAGER Debra Bayer	P.O. NUMBER	TOWN		40ml Vials HCl	TURNAROUND TIME
CLIENT (SITE) PM S. Callahan - results to morourke@ulsterbocecs.org	CLIENT PHONE 845-256-4090	CLIENT FAX		Liter Amber HCl	NORMAL
CLIENT NAME New Paltz central School District				250ml Plastic Nitric Acid	QUICK
CLIENT ADDRESS 196 Main Street, New Paltz, New York 12561				Liter Plastic	VERBAL
COMPANY CONTRACTING THIS WORK (if applicable)				250ml Plastic Sulfuric Acid	
				250ml Plastic Nitric Acid	
				Terra Core	
				Other	
				Other	

SAMPLE DATE	TIME	SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INVCNTR	AQUEOUS (WATER)	D (Drinking Water) or V (Vaste Water) Inconc	SOLID OR SEMISOLID	OTHER Specify	NUMBER OF CONTAINERS SUBMITTED							REMARKS	
								Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic		Terra Core
10/22/2016	12:17	129 - Room 33 Octognal #6 SW Sink faucet						1	1							Lead (DW 200.8)
10/22/2016	12:17	130 - Room 33 octognal #6 NW Sink faucet						1	1							Lead (DW 200.8)
10/22/2016	12:17	131 - Room 33 octognal #6 NE Sink faucet						1	1							Lead (DW 200.8)
10/22/2016	12:21	132 - Room 33 Utility sink faucet						1	1							Lead (DW 200.8)
10/22/2016	12:24	133 - Room 32 Utility sink faucet						1	1							Lead (DW 200.8)
10/22/2016	12:47	134 - loading Dock Hose Bib						1	1							Lead (DW 200.8)
10/22/2016	13:00	135 - East Side Hose Bib						1	1							Lead (DW 200.8)
10/28/2016	5:50	136 - Health office Sink faucet						1	1							Lead (DW 200.8)
10/28/2016	5:50	137 - Health office TR sink faucet						1	1							Lead (DW 200.8)
10/28/2016	5:51	138 - Principal's TR sink faucet						1	1							Lead (DW 200.8)
10/28/2016	5:55	139 - Library sink faucet						1	1							Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE) <i>Brian Glushko</i>	COMPANY Ulster BOCES	DATE 10/31/16	TIME 9:35 am	RECEIVED BY: (SIGNATURE)	COMP/DATE	TIME
SAMPLED BY: (SIGNATURE) <i>Brian Glushko</i>	COMPANY Ulster BOCES	DATE 10/31/16	TIME 9:35 am	RECEIVED BY: (SIGNATURE)	COMP/DATE	TIME
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMP/DATE	TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE) <i>D. Moore</i>	DATE 10/31/16	TIME 09:35	CUSTODY INTACT YES NO	Cooler Temp(C): 17.7	LABORATORY REMARKS: ICE (Y_N) pH CL2 Revised by <i>10/31/16</i>
------------------------------------------------------------	------------------	---------------	-----------------------------	-------------------------	--------------------------------------------------------------------------

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Ulster BOCES

Job Number: 420-112525-1
SDG Number: New Paltz CSD - Middle School

Login Number: 112525

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	17.7 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	

APPENDIX B

Caution Signage

CAUTION: NONPOTABLE WATER – DO NOT DRINK



CAUTION: NONPOTABLE WATER – DO NOT DRINK

CAUTION



NON-POTABLE
WATER
DO NOT DRINK