

## ANALYTICAL REPORT

Job Number: 420-195418-1  
SDG Number: Duzine Elementary School  
Job Description: Ulster BOCES

For:  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Attention: Christy Fischer



---

Designee for  
Meredith W Ruthven  
Customer Service Manager  
mruthven@envirotestlaboratories.com  
06/23/2021

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories LLC certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative. All services performed by EnviroTest Laboratories LLC are subject to our Terms and Conditions available at [Envirotestlabs/terms.com](http://Envirotestlabs/terms.com). As of 12/23/19, EnviroTest Laboratories LLC acquired substantially all of the lab and testing assets of EnviroTest Laboratories Inc, including its name.

EnviroTest Laboratories, LLC. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

## METHOD SUMMARY

Client: Ulster BOCES

Job Number: 420-195418-1  
SDG Number: Duzine Elementary School

<b>Description</b>	<b>Lab Location</b>	<b>Method</b>	<b>Preparation Method</b>
<b>Matrix: Water</b>			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200.7/200.8

### Lab References:

EnvTest = EnviroTest

### Method References:

EPA = US Environmental Protection Agency

## METHOD / ANALYST SUMMARY

Client: Ulster BOCES

Job Number: 420-195418-1  
SDG Number: Duzine Elementary School

<b>Method</b>	<b>Analyst</b>	<b>Analyst ID</b>
EPA 200.8 Rev.5.4	Luis, Carlos	CL

## SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-195418-1  
SDG Number: Duzine Elementary School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-195418-1	Nurse's Office Toilet Room Sink	Drinking Water	04/13/2021 0610	04/14/2021 1246
420-195418-2	Principal's Office Toilet Room Sink	Drinking Water	04/13/2021 0613	04/14/2021 1246
420-195418-3	Faculty Toilet Room Sink By Library	Drinking Water	04/13/2021 0614	04/14/2021 1246
420-195418-4	Boys Room Left Sink by Library	Drinking Water	04/13/2021 0615	04/14/2021 1246
420-195418-5	Boys Room Center Sink by Library	Drinking Water	04/13/2021 0616	04/14/2021 1246
420-195418-6	Boys Room Right Sink by Library	Drinking Water	04/13/2021 0617	04/14/2021 1246
420-195418-7	Girls Room Left Sink by Library	Drinking Water	04/13/2021 0617	04/14/2021 1246
420-195418-8	Girls Room Center Sink by Library	Drinking Water	04/13/2021 0618	04/14/2021 1246
420-195418-9	Girls Room Right Sink by Library	Drinking Water	04/13/2021 0618	04/14/2021 1246
420-195418-10	Room 14 Sink in Library	Drinking Water	04/13/2021 0619	04/14/2021 1246
420-195418-11	Room 13 Sink	Drinking Water	04/13/2021 0621	04/14/2021 1246
420-195418-12	Room 16 Sink	Drinking Water	04/13/2021 0623	04/14/2021 1246
420-195418-13	Room 15 Sink	Drinking Water	04/13/2021 0624	04/14/2021 1246
420-195418-14	Room 18 Sink	Drinking Water	04/13/2021 0625	04/14/2021 1246
420-195418-15	Room 17 Sink	Drinking Water	04/13/2021 0626	04/14/2021 1246
420-195418-18	Room 20 Sink	Drinking Water	04/13/2021 0627	04/14/2021 1246
420-195418-19	Room 19 Sink	Drinking Water	04/13/2021 0628	04/14/2021 1246
420-195418-20	Room 21 Sink	Drinking Water	04/13/2021 0630	04/14/2021 1246
420-195418-21	Room 23 Toilet Room Sink	Drinking Water	04/13/2021 0632	04/14/2021 1246
420-195418-22	Room 23 Sink	Drinking Water	04/13/2021 0632	04/14/2021 1246
420-195418-23	Fountain Outside Boys Room by Library	Drinking Water	04/13/2021 0635	04/14/2021 1246
420-195418-24	Fountain Outside Girls Room by Library	Drinking Water	04/13/2021 0636	04/14/2021 1246
420-195418-25	Sink in Center of Kitchen	Drinking Water	04/13/2021 0604	04/14/2021 1246
420-195418-26	Kitchen Bath Sink	Drinking Water	04/13/2021 0606	04/14/2021 1246
420-195418-27	Sink Back of Kitchen	Drinking Water	04/13/2021 0607	04/14/2021 1246
420-195418-28	Boys Bath Outside 23 Sink 1	Drinking Water	04/13/2021 0608	04/14/2021 1246
420-195418-29	Boys Bath Outside 23 Sink 2	Drinking Water	04/13/2021 0608	04/14/2021 1246
420-195418-30	Girls Bath 25 Sink 1	Drinking Water	04/13/2021 0610	04/14/2021 1246
420-195418-31	Girls Bath 25 Sink 2	Drinking Water	04/13/2021 0610	04/14/2021 1246
420-195418-32	24 Sink	Drinking Water	04/13/2021 0610	04/14/2021 1246
420-195418-33	24 Bath Sink	Drinking Water	04/13/2021 0611	04/14/2021 1246
420-195418-34	Faculty Room Sink	Drinking Water	04/13/2021 0611	04/14/2021 1246
420-195418-35	27 Bath Sink	Drinking Water	04/13/2021 0611	04/14/2021 1246
420-195418-36	27 Sink	Drinking Water	04/13/2021 0611	04/14/2021 1246
420-195418-37	26 Bath Sink	Drinking Water	04/13/2021 0612	04/14/2021 1246
420-195418-38	26 Sink	Drinking Water	04/13/2021 0612	04/14/2021 1246
420-195418-39	28 Sink	Drinking Water	04/13/2021 0613	04/14/2021 1246

## SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-195418-1  
SDG Number: Duzine Elementary School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-195418-40	28 Bath Sink	Drinking Water	04/13/2021 0613	04/14/2021 1246
420-195418-41	29 Bath Sink	Drinking Water	04/13/2021 0614	04/14/2021 1246
420-195418-42	31 Sink	Drinking Water	04/13/2021 0616	04/14/2021 1246
420-195418-43	31 Bath Sink	Drinking Water	04/13/2021 0616	04/14/2021 1246
420-195418-44	30 Sink	Drinking Water	04/13/2021 0616	04/14/2021 1246
420-195418-45	30 Bath Sink	Drinking Water	04/13/2021 0616	04/14/2021 1246
420-195418-46	32 Sink	Drinking Water	04/13/2021 0617	04/14/2021 1246
420-195418-47	32 Bath Sink	Drinking Water	04/13/2021 0617	04/14/2021 1246
420-195418-48	33 Sink	Drinking Water	04/13/2021 0618	04/14/2021 1246
420-195418-49	33 Bath Sink	Drinking Water	04/13/2021 0618	04/14/2021 1246
420-195418-50	Men's Faculty Bath Outside 33	Drinking Water	04/13/2021 0619	04/14/2021 1246
420-195418-51	Women's Faculty Bath Outside 33	Drinking Water	04/13/2021 0619	04/14/2021 1246
420-195418-52	35 Sink	Drinking Water	04/13/2021 0620	04/14/2021 1246
420-195418-53	35 Bath Sink	Drinking Water	04/13/2021 0620	04/14/2021 1246
420-195418-54	34 Sink	Drinking Water	04/13/2021 0621	04/14/2021 1246
420-195418-55	34 Bath Sink	Drinking Water	04/13/2021 0621	04/14/2021 1246
420-195418-56	12 Sink	Drinking Water	04/13/2021 0623	04/14/2021 1246
420-195418-57	12 Bath Sink	Drinking Water	04/13/2021 0623	04/14/2021 1246
420-195418-58	11 Bath Sink	Drinking Water	04/13/2021 0624	04/14/2021 1246
420-195418-59	11 Sink	Drinking Water	04/13/2021 0624	04/14/2021 1246
420-195418-60	Gym Office Bath Sink	Drinking Water	04/13/2021 0626	04/14/2021 1246
420-195418-61	Water Cooler on Left Outside 12	Drinking Water	04/13/2021 0626	04/14/2021 1246
420-195418-62	Water Cooler on Right Outside 12	Drinking Water	04/13/2021 0627	04/14/2021 1246
420-195418-63	Boys Bath Outside 9 Sink 1	Drinking Water	04/13/2021 0628	04/14/2021 1246
420-195418-64	Boys Bath Outside 9 Sink 2	Drinking Water	04/13/2021 0628	04/14/2021 1246
420-195418-65	Boys Bath Outside 9 Sink 3	Drinking Water	04/13/2021 0628	04/14/2021 1246
420-195418-66	Girls Bath Outside 9 Sink 1	Drinking Water	04/13/2021 0629	04/14/2021 1246
420-195418-67	Girls Bath Outside 9 Sink 2	Drinking Water	04/13/2021 0629	04/14/2021 1246
420-195418-68	Girls Bath Outside 9 Sink 3	Drinking Water	04/13/2021 0629	04/14/2021 1246
420-195418-69	Individual Water Cooler Outside Boys Bath by 9	Drinking Water	04/13/2021 0630	04/14/2021 1246
420-195418-70	Bottle Fill Outside Girls Bath by 9	Drinking Water	04/13/2021 0630	04/14/2021 1246
420-195418-71	Water Cooler Outside Girls Bath 9	Drinking Water	04/13/2021 0630	04/14/2021 1246
420-195418-72	9 Sink	Drinking Water	04/13/2021 0632	04/14/2021 1246
420-195418-73	10 Sink	Drinking Water	04/13/2021 0633	04/14/2021 1246
420-195418-74	7 Sink	Drinking Water	04/13/2021 0633	04/14/2021 1246
420-195418-75	5 Sink	Drinking Water	04/13/2021 0634	04/14/2021 1246
420-195418-76	8 Sink	Drinking Water	04/13/2021 0634	04/14/2021 1246
420-195418-77	6 Sink	Drinking Water	04/13/2021 0635	04/14/2021 1246
420-195418-78	4 Sink	Drinking Water	04/13/2021 0635	04/14/2021 1246
420-195418-79	3 Sink	Drinking Water	04/13/2021 0636	04/14/2021 1246
420-195418-80	1 Sink	Drinking Water	04/13/2021 0637	04/14/2021 1246

## SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-195418-1  
SDG Number: Duzine Elementary School

<b>Lab Sample ID</b>	<b>Client Sample ID</b>	<b>Client Matrix</b>	<b>Date/Time Sampled</b>	<b>Date/Time Received</b>
420-195418-81	2 Sink	Drinking Water	04/13/2021 0637	04/14/2021 1246

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Nurse's Office Toilet Room Sink  
**Lab Sample ID:** 420-195418-1

Date Sampled: 04/13/2021 0610  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021	2021
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021	1400
Pb	15	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Principal's Office Toilet Room Sink  
**Lab Sample ID:** 420-195418-2

Date Sampled: 04/13/2021 0613  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 2035	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1400	
Pb	20	g	ug/L	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Faculty Toilet Room Sink By Library  
**Lab Sample ID:** 420-195418-3

Date Sampled: 04/13/2021 0614  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 2037	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1400	
Pb	3.9	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Boys Room Left Sink by Library  
**Lab Sample ID:** 420-195418-4

Date Sampled: 04/13/2021 0615  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 2039	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1400	
Pb	4.5	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Boys Room Center Sink by Library  
**Lab Sample ID:** 420-195418-5

Date Sampled: 04/13/2021 0616  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 2041	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1400	
Pb	5.1	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Boys Room Right Sink by Library  
**Lab Sample ID:** 420-195418-6

Date Sampled: 04/13/2021 0617  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 2043	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1400	
Pb	6.0	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Girls Room Left Sink by Library  
**Lab Sample ID:** 420-195418-7

Date Sampled: 04/13/2021 0617  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/20/2021 1719	
Prep Method: 200.7/200.8			Date Prepared:	06/16/2021 1915	
Pb	8.0	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Girls Room Center Sink by Library  
**Lab Sample ID:** 420-195418-8

Date Sampled: 04/13/2021 0618  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/20/2021 1721	
Prep Method: 200.7/200.8			Date Prepared:	06/16/2021 1915	
Pb	7.3	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Girls Room Right Sink by Library  
**Lab Sample ID:** 420-195418-9

Date Sampled: 04/13/2021 0618  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/20/2021 1723	
Prep Method: 200.7/200.8			Date Prepared:	06/16/2021 1915	
Pb	8.2	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Room 14 Sink in Library  
**Lab Sample ID:** 420-195418-10

Date Sampled: 04/13/2021 0619  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/20/2021 1725	
Prep Method: 200.7/200.8			Date Prepared:	06/16/2021 1915	
Pb	39 g	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Room 13 Sink  
**Lab Sample ID:** 420-195418-11

Date Sampled: 04/13/2021 0621  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 2045	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1400	
Pb	26	g	ug/L	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Room 16 Sink  
**Lab Sample ID:** 420-195418-12

Date Sampled: 04/13/2021 0623  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 2048	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1400	
Pb	18 g	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Room 15 Sink  
**Lab Sample ID:** 420-195418-13

Date Sampled: 04/13/2021 0624  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 2054	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1400	
Pb	20	g	ug/L	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Room 18 Sink  
**Lab Sample ID:** 420-195418-14

Date Sampled: 04/13/2021 0625  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 2056	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1400	
Pb	14	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Room 17 Sink  
**Lab Sample ID:** 420-195418-15

Date Sampled: 04/13/2021 0626  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 2101	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1400	
Pb	20	g	ug/L	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Room 20 Sink  
**Lab Sample ID:** 420-195418-18

Date Sampled: 04/13/2021 0627  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 2103	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1400	
Pb	11	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Room 19 Sink  
**Lab Sample ID:** 420-195418-19

Date Sampled: 04/13/2021 0628  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 2105	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1400	
Pb	46 g	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Room 21 Sink  
**Lab Sample ID:** 420-195418-20

Date Sampled: 04/13/2021 0630  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 2107	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1400	
Pb	3.2	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Room 23 Toilet Room Sink  
**Lab Sample ID:** 420-195418-21

Date Sampled: 04/13/2021 0632  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 2109	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1400	
Pb	3.7	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Room 23 Sink  
**Lab Sample ID:** 420-195418-22

Date Sampled: 04/13/2021 0632  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 2112	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1400	
Pb	6.6	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Fountain Outside Boys Room by Library  
**Lab Sample ID:** 420-195418-23

Date Sampled: 04/13/2021 0635  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 2114	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1400	
Pb	1.0	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Fountain Outside Girls Room by Library  
**Lab Sample ID:** 420-195418-24

Date Sampled: 04/13/2021 0636  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 1750	
Prep Method: 200.7/200.8			Date Prepared:	06/04/2021 1430	
Pb	2.4	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Sink in Center of Kitchen  
**Lab Sample ID:** 420-195418-25

Date Sampled: 04/13/2021 0604  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 1759	
Prep Method: 200.7/200.8			Date Prepared:	06/04/2021 1430	
Pb	17	g	ug/L	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Kitchen Bath Sink  
**Lab Sample ID:** 420-195418-26

Date Sampled: 04/13/2021 0606  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 1801	
Prep Method: 200.7/200.8			Date Prepared:	06/04/2021 1430	
Pb	36	g	ug/L	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Sink Back of Kitchen  
**Lab Sample ID:** 420-195418-27

Date Sampled: 04/13/2021 0607  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 1803	
Prep Method: 200.7/200.8			Date Prepared:	06/04/2021 1430	
Pb	14	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Boys Bath Outside 23 Sink 1  
**Lab Sample ID:** 420-195418-28

Date Sampled: 04/13/2021 0608  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 1810	
Prep Method: 200.7/200.8			Date Prepared:	06/04/2021 1430	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Boys Bath Outside 23 Sink 2  
**Lab Sample ID:** 420-195418-29

Date Sampled: 04/13/2021 0608  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 1812	
Prep Method: 200.7/200.8			Date Prepared:	06/04/2021 1430	
Pb	3.1	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Girls Bath 25 Sink 1  
**Lab Sample ID:** 420-195418-30

Date Sampled: 04/13/2021 0610  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 1814	
Prep Method: 200.7/200.8			Date Prepared:	06/04/2021 1430	
Pb	1.0	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Girls Bath 25 Sink 2  
**Lab Sample ID:** 420-195418-31

Date Sampled: 04/13/2021 0610  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 1817	
Prep Method: 200.7/200.8			Date Prepared:	06/04/2021 1430	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 24 Sink  
**Lab Sample ID:** 420-195418-32

Date Sampled: 04/13/2021 0610  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 1819	
Prep Method: 200.7/200.8			Date Prepared:	06/04/2021 1430	
Pb	8.5	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 24 Bath Sink  
**Lab Sample ID:** 420-195418-33

Date Sampled: 04/13/2021 0611  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 1821	
Prep Method: 200.7/200.8			Date Prepared:	06/04/2021 1430	
Pb	27	g	ug/L	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Faculty Room Sink  
**Lab Sample ID:** 420-195418-34

Date Sampled: 04/13/2021 0611  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 1823	
Prep Method: 200.7/200.8			Date Prepared:	06/04/2021 1430	
Pb	13	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 27 Bath Sink  
**Lab Sample ID:** 420-195418-35

Date Sampled: 04/13/2021 0611  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 1827	
Prep Method: 200.7/200.8			Date Prepared:	06/04/2021 1430	
Pb	14	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 27 Sink  
**Lab Sample ID:** 420-195418-36

Date Sampled: 04/13/2021 0611  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 1830	
Prep Method: 200.7/200.8			Date Prepared:	06/04/2021 1430	
Pb	27	g	ug/L	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 26 Bath Sink  
**Lab Sample ID:** 420-195418-37

Date Sampled: 04/13/2021 0612  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 1836	
Prep Method: 200.7/200.8			Date Prepared:	06/04/2021 1430	
Pb	7.2	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 26 Sink  
**Lab Sample ID:** 420-195418-38

Date Sampled: 04/13/2021 0612  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 1838	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1040	
Pb	6.8	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 28 Sink  
**Lab Sample ID:** 420-195418-39

Date Sampled: 04/13/2021 0613  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 1847	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1040	
Pb	5.5	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 28 Bath Sink  
**Lab Sample ID:** 420-195418-40

Date Sampled: 04/13/2021 0613  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 1849	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1040	
Pb	20	g	ug/L	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 29 Bath Sink  
**Lab Sample ID:** 420-195418-41

Date Sampled: 04/13/2021 0614  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 1852	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1040	
Pb	5.4	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 31 Sink  
**Lab Sample ID:** 420-195418-42

Date Sampled: 04/13/2021 0616  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 1854	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1040	
Pb	6.9	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 31 Bath Sink  
**Lab Sample ID:** 420-195418-43

Date Sampled: 04/13/2021 0616  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 1856	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1040	
Pb	6.1	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 30 Sink  
**Lab Sample ID:** 420-195418-44

Date Sampled: 04/13/2021 0616  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2002	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1040	
Pb	12	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 30 Bath Sink  
**Lab Sample ID:** 420-195418-45

Date Sampled: 04/13/2021 0616  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2004	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1040	
Pb	18 g	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 32 Sink  
**Lab Sample ID:** 420-195418-46

Date Sampled: 04/13/2021 0617  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2006	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1040	
Pb	11	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 32 Bath Sink  
**Lab Sample ID:** 420-195418-47

Date Sampled: 04/13/2021 0617  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2008	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1040	
Pb	620 g	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 33 Sink  
**Lab Sample ID:** 420-195418-48

Date Sampled: 04/13/2021 0618  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2010	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1105	
Pb	11	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 33 Bath Sink  
**Lab Sample ID:** 420-195418-49

Date Sampled: 04/13/2021 0618  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2015	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1105	
Pb	21 g	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Men's Faculty Bath Outside 33  
**Lab Sample ID:** 420-195418-50

Date Sampled: 04/13/2021 0619  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2017	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1105	
Pb	21	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Women's Faculty Bath Outside 33  
**Lab Sample ID:** 420-195418-51

Date Sampled: 04/13/2021 0619  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2019	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1105	
Pb	1.7	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 35 Sink  
**Lab Sample ID:** 420-195418-52

Date Sampled: 04/13/2021 0620  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2026	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1105	
Pb	4.2	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 35 Bath Sink  
**Lab Sample ID:** 420-195418-53

Date Sampled: 04/13/2021 0620  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2028	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1105	
Pb	5.6	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 34 Sink  
**Lab Sample ID:** 420-195418-54

Date Sampled: 04/13/2021 0621  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2030	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1105	
Pb	15	g	ug/L	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 34 Bath Sink  
**Lab Sample ID:** 420-195418-55

Date Sampled: 04/13/2021 0621  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2032	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1105	
Pb	4.8	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 12 Sink  
**Lab Sample ID:** 420-195418-56

Date Sampled: 04/13/2021 0623  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2034	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1105	
Pb	3.6	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 12 Bath Sink  
**Lab Sample ID:** 420-195418-57

Date Sampled: 04/13/2021 0623  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2037	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1105	
Pb	37	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 11 Bath Sink  
**Lab Sample ID:** 420-195418-58

Date Sampled: 04/13/2021 0624  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2039	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1105	
Pb	31	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 11 Sink  
**Lab Sample ID:** 420-195418-59

Date Sampled: 04/13/2021 0624  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2052	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1105	
Pb	77	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Gym Office Bath Sink  
**Lab Sample ID:** 420-195418-60

Date Sampled: 04/13/2021 0626  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Pb	28	g ug/L	Date Analyzed: 1.0	06/11/2021 1955 1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Water Cooler on Left Outside 12  
**Lab Sample ID:** 420-195418-61

Date Sampled: 04/13/2021 0626  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Pb	64	g	ug/L	1.0	1.0
			Date Analyzed:	06/11/2021 1957	

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Water Cooler on Right Outside 12  
**Lab Sample ID:** 420-195418-62

Date Sampled: 04/13/2021 0627  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Pb	89	g	ug/L	1.0	1.0
			Date Analyzed:	06/11/2021 1959	

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Boys Bath Outside 9 Sink 1  
**Lab Sample ID:** 420-195418-63

Date Sampled: 04/13/2021 0628  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Pb	6.4	ug/L	1.0	1.0	1.0

Date Analyzed: 06/11/2021 2002

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Boys Bath Outside 9 Sink 2  
**Lab Sample ID:** 420-195418-64

Date Sampled: 04/13/2021 0628  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Pb	8.3	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Boys Bath Outside 9 Sink 3  
**Lab Sample ID:** 420-195418-65

Date Sampled: 04/13/2021 0628  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Pb	5.3	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Girls Bath Outside 9 Sink 1  
**Lab Sample ID:** 420-195418-66

Date Sampled: 04/13/2021 0629  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Pb	6.2	ug/L	1.0	1.0	1.0

Date Analyzed: 06/11/2021 2008

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Girls Bath Outside 9 Sink 2  
**Lab Sample ID:** 420-195418-67

Date Sampled: 04/13/2021 0629  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Pb	28	g	ug/L	1.0	1.0
			Date Analyzed: 06/11/2021	2010	

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Girls Bath Outside 9 Sink 3  
**Lab Sample ID:** 420-195418-68

Date Sampled: 04/13/2021 0629  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Pb	4.2	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Individual Water Cooler Outside Boys Bath by 9  
**Lab Sample ID:** 420-195418-69

Date Sampled: 04/13/2021 0630  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2054	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1300	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Bottle Fill Outside Girls Bath by 9  
**Lab Sample ID:** 420-195418-70

Date Sampled: 04/13/2021 0630  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2056	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1300	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** Water Cooler Outside Girls Bath 9  
**Lab Sample ID:** 420-195418-71

Date Sampled: 04/13/2021 0630  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2058	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1300	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 9 Sink  
**Lab Sample ID:** 420-195418-72

Date Sampled: 04/13/2021 0632  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2101	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1300	
Pb	45	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 10 Sink  
**Lab Sample ID:** 420-195418-73

Date Sampled: 04/13/2021 0633  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2103	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1300	
Pb	13	g	ug/L	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 7 Sink  
**Lab Sample ID:** 420-195418-74

Date Sampled: 04/13/2021 0633  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2105	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1300	
Pb	99	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 5 Sink  
**Lab Sample ID:** 420-195418-75

Date Sampled: 04/13/2021 0634  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2107	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1300	
Pb	24	g	ug/L	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 8 Sink  
**Lab Sample ID:** 420-195418-76

Date Sampled: 04/13/2021 0634  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2109	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1326	
Pb	24 g	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 6 Sink  
**Lab Sample ID:** 420-195418-77

Date Sampled: 04/13/2021 0635  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2112	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1326	
Pb	18 g	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 4 Sink  
**Lab Sample ID:** 420-195418-78

Date Sampled: 04/13/2021 0635  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2118	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1326	
Pb	19 g	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 3 Sink  
**Lab Sample ID:** 420-195418-79

Date Sampled: 04/13/2021 0636  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2127	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1326	
Pb	23 g	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 1 Sink  
**Lab Sample ID:** 420-195418-80

Date Sampled: 04/13/2021 0637  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2129	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1326	
Pb	15	g	ug/L	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-195418-1  
Sdg Number: Duzine Elementary School

**Client Sample ID:** 2 Sink  
**Lab Sample ID:** 420-195418-81

Date Sampled: 04/13/2021 0637  
Date Received: 04/14/2021 1246  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2131	
Prep Method: 200.7/200.8			Date Prepared:	06/07/2021 1326	
Pb	34	g	ug/L	1.0	1.0

## DATA REPORTING QUALIFIERS

Client: Ulster BOCES

Job Number:  
Sdg Number: Duzine Elementary School

<b>Lab Section</b>	<b>Qualifier</b>	<b>Description</b>
Metals		
	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

## Certification Information

Client: Ulster BOCES

Job Number:

Sdg Number: Duzine Elementary School

---

### **The following analytes are Not Part of the ELAP scope of accreditation:**

Sulfur, Tungsten, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), COD (Soluble), Total Inorganic Carbon, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, 1,2,4,5-Tetramethylbenzene, 4-Ethyl toluene, p-Diethylbenzene, Iron Bacteria, Salmonella, Sulfur Reducing Bacteria, & UOD (Ultimate Oxygen Demand).

### **The following analytes are Not Part of ELAP Potable Water scope of accreditation:**

Ammonia (SM 4500NH3G), Biochemical Oxygen Demand (SM 5210B), Chemical Oxygen Demand (EPA 410.4), Dissolved Oxygen (SM 4500 O C), TKN (351.2), Phosphorus (365.3), Nitrate-Nitrite (353.2), Settable Solids (SM 2540F), Total Suspended Solids (SM 2540 C), m-Xylene & p-Xylene (502.2, 524), o-Xylene (502.2, 524), Sulfide (SM4500SD), Acenaphthene (525.2), Acenaphthylene (525.2), Fluoranthene (525.2), Fluorene (525.2), Phenanthrene (525.2), Anthracene (525.2), Pyrene (525.2), Benzo[a]anthracene (525.2), Benzo[b]fluoranthene (525.2), Benzo[g,h,i]perylene (525.2), Benzo[k]fluoranthene (525.2), Indeno[1,2,3-cd]pyrene (525.2), & Dibenz(a,h)anthracene (525.2). Pyridine

### **The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:**

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

### **The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:**

Dissolved Organic Carbon (5310C), Mecoprop (8151A), MCPA (8151A).

## Definitions and Glossary

Client: Ulster BOCES

Job Number:

Sdg Number: Duzine Elementary School

---

<u>Abbreviation</u>	<u>These commonly used abbreviations may or may not be present in this report.</u>
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points



**EnviroTest Laboratories, LLC**

315 Fullerton Avenue  
Newburgh, NY 12550  
Phone (845) 562-0890 Fax (845) 562-0841

**Chain of Custody Record**



<b>Client Information</b>		Sampler: C Fischer/G Gardner		Lab PM:		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: <b>195418</b> <i>2 of 6</i>		
Client Contact: C Fischer		Phone: 845 255-1400 X1361		E-Mail:				Page: Page <b>2 of 6</b>		
Company: New Paltz Central School District C/OUlster BOCES				<b>Analysis Requested</b>				Preservation Codes:		
Address: 196 Main Street		Due Date Requested:		Total Number of containers				A - HCL		
City: New Paltz		TAT Requested (days):						L - EDA		
State, Zip: NY, 12561								M - Sodium Sulfite		
Phone: 845-255-1400 X1361		PO #:						N - None		
Email: cfischer@ulsterboces.org		PWS #:						O - MCAA		
Project Name: Ulster BOCES		Project #:						P - Other (specify)		
Site: Duzine Elementary School		Additional Contacts: Please Email Results to both: <u>cfischer@ulsterboces.org</u> & <u>ggardner@newpaltz.k12.ny.us</u>						Other:		
								Upon Receipt Preservation verified: Y / N		
<b>Sample Identification Client ID (Lab ID)</b>		<b>Sample Date</b>	<b>Sample Time</b>	<b>Sample Type (C=Comp, G=grab)</b>	<b>Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)</b>	<b>Field Filtered Sample (Yes or No)</b>	<b>Perform MS/MSD (Yes or No)</b>	<b>Chlorine Present (Yes or No)</b>	<b>Lead (DW 200.8)</b>	<b>Special Instructions/Note:</b>
Room 18 Sink *		4/13/21	625	G	DW				X	<i>* Samples not received. cc</i>
Room 17 Sink *		4/13/21	626	G	DW				X	
Room 20 Sink		4/13/21	627	G	DW				X	
Room 19 Sink		4/13/21	628	G	DW				X	
Room 21 Sink		4/13/21	630	G	DW				X	
Room 23 Toilet Room Sink		4/13/21	632	G	DW				X	
Room 23 Sink		4/13/21	632	G	DW				X	
Fountain Outside Boys Room by Library		4/13/21	635	G	DW				X	
Fountain Outside Girls Room by Library		4/13/21	636	G	DW				X	
Sink in Center of Kitchen		4/13/21	604	G	DW				X	
Kitchen Bath Sink		4/13/21	606	G	DW				X	
Sink Back of Kitchen		4/13/21	607	G	DW				X	
Boys Bath Outside 23 Sink 1		4/13/21	608	G	DW				X	
Boys Bath Outside 23 Sink 2		4/13/21	608	G	DW				X	
Girls Bath 25 Sink 1		4/13/21	610	G	DW				X	
<b>Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle</b>								<b>Container Type P</b>		
<b>Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other</b>								<b>Container Size 2</b>		
Preservation Added Upon Receipt:				Date:		Time:		Sample # (s):		
Manufacturer/Lot #:										
Relinquished by: <i>[Signature]</i>		Date/Time: <b>4/14/21 1246</b>		Company: <b>ulsterboces</b>		Received by: <i>[Signature]</i>		Date/Time: <b>4/14/21 1246</b>		
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:		
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:		
ICE Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Custody Seal No.:		Custody Seal No. <b>90</b>		Temperature(s) °C/ IR GUN #: <b>21.9°C</b>		06/23/2021		

**EnviroTest Laboratories, LLC**

315 Fullerton Avenue  
Newburgh, NY 12550  
Phone (845) 562-0890 Fax (845) 562-0841

**Chain of Custody Record**



<b>Client Information</b>		Sampler: C Fischer/G Gardner		Lab PM:		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: <b>195418 3 of 6</b>							
Client Contact: C Fischer		Phone: 845 255-1400 X1361		E-Mail:											
Company: New Paltz Central School District C/O Ulster BOCES					<b>Analysis Requested</b>										
Address: 196 Main Street		Due Date Requested:		Field Filtered Sample (Yes or No)		Perform MS/MSD (Yes or No)		Chlorine Present (Yes or No)		Lead (DW 200.8)		Total Number of Containers		Page: <b>3 of 6</b>	
City: New Paltz		TAT Requested (days):												Preservation Codes:	
State, Zip: NY, 12561		PO #:												A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)	
Phone: 845-255-1400 X1361		PWS #:												Other:	
Email: cfischer@ulsterboces.org		Project #:												Upon Receipt Preservation verified: Y / N	
Project Name: Ulster BOCES		Additional Contacts: Please Email Results to both: & ggardner@newpaltz.k12.ny.us												Special Instructions/Note:	
Site: Duzine Elementary School <u>cfischer@ulsterboces.org</u>															
<b>Sample Identification Client ID (Lab ID)</b>		<b>Sample Date</b>	<b>Sample Time</b>	<b>Sample Type (C=comp, G=grab)</b>	<b>Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)</b>										
Girls Bath 25 Sink 2		4/13/21	610	G	DW										
24 Sink		4/13/21	610	G	DW										
24 Bath Sink		4/13/21	611	G	DW										
Faculty Room Sink		4/13/21	611	G	DW										
27 Bath Sink		4/13/21	611	G	DW										
27 Sink		4/13/21	611	G	DW										
26 Bath Sink		4/13/21	612	G	DW										
26 Sink		4/13/21	612	G	DW										
28 Sink		4/13/21	613	G	DW										
28 Bath Sink		4/13/21	613	G	DW										
29 Bath Sink		4/13/21	614	G	DW										
31 Sink		4/13/21	616	G	DW										
31 Bath Sink		4/13/21	616	G	DW										
30 Sink		4/13/21	616	G	DW										
30 Bath Sink		4/13/21	616	G	DW										
<b>Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle</b>										<b>Container Type P</b>					
<b>Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other</b>										<b>Container Size 2</b>					
Preservation Added Upon Receipt:				Date:		Time:		Sample # (s):							
Manufacturer/Lot #:															
Relinquished by: <i>[Signature]</i>		Date/Time: <b>4/14/21 1246</b>		Company: <b>Wishard</b>		Received by: <i>[Signature]</i>		Date/Time: <b>4/14/21 1246</b>		Company: <b>ETC</b>					
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:		Company:					
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:		Company:					
ICE Present <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Custody Seal No.:		Custody Seal No. <b>01</b>		Temp: <b>24.9 C</b>		Date: <b>06/23/2021</b>							







## LOGIN SAMPLE RECEIPT CHECK LIST

Client: Ulster BOCES

Job Number: 420-195418-1  
SDG Number: Duzine Elementary School

**Login Number: 195418**

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	24.4 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	True	
If false, was sample received on ice within 6 hours of collection.	NA	
Based on above criteria cooler temperature is acceptable.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	